

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 7-Jul-20

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Enerov Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2'55	85	35	714000	Unit-2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1'210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1'210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1'243*1'122	365	300	7184991	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2'40	78	65	1431584	Engine problem
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	93	2177681	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273*1'139	412	334	8176640	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1'235*1'125	360	352	7824000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150*1'150	450	450	9222000	
9	Meghnaghat 100 MW (IEL)	QRPP		100	0	0	
10	Meghnaghat CCPP(Summit)	IPP	2'110*1'110	305	130	3242415	FGMO & GT-1 Under S/D
11	Madanganj 102 PP(Summit)	QRPP	6'17	100	90	1983144	Engine problem
12	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	47	1135073	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	100	1570413	
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	376020	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	0	Fuel Shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	0	1047360	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1'217*1'118	335	328	7366485	
19	Gazipur 102 MW PP (Digital Power)	IPP	12'8.924	102	85	1895040	Engine problem
20	Katpotti 52 MW PP (Sinha)	IPP	7'7.9	51	48	274080	
21	Karnalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	53	981720	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	100	721920	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	1044475	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	1062743	
25	Bosila 108MW PP(CLO)	IPP	12'8.775*1'3.5	108	0	0	Fuel Shortage
26	Summit Power (Madhabadi+Ashulla)	SIPP, REB	3'3.67*4'8.73	80	54	1230720	Engine problem
27	Masna 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	709400	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	803900	
29	Gazipur 52 MW PP	IPP	6'8.9	52	0	0	Reserve
30	Tongi 80 MW GTPP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	288	4493780	
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	230856	Reserve
33	Bramhangaoan 100 MW PP (Aggreko)	IPP	100	100	0	440724	Reserve
34	Auraha 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	945573	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	4'8.73	149	131	2766240	Engine problem
36	Gazipur 100 MW PP	RPCL	100 MW	105	70	696276	Low demand
	Meghnaghat 104 MW PP (OPCL)	IPP	18'5'6	104	0	0	On test
Dhaka area Total				5895	3348	71749053	
37	Chattogram TPP-1	PDB	1'210	180	90	2100000	Gas shortage.
	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage.
38	Raozan 25 MW PP	IPP	3'8.9	25	0	1260	Reserve
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	96255	
40	Patenga 50MW PP (Baraka)	IPP	6'6.98	50	32	229920	Low demand
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	73	1684107	Low water level
42	Sikalbaha 225MW	PDB	1'150*1'175	225	0	0	Under S/D.
43	Sikalbaha Peaking GT	PDB	1'150	150	140	3338112	FGMO
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	17	153053	Low demand
45	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	14072	Under maint.
46	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	85	564835	
47	Juldah 100 MW Unit-1 (Acom)	QRPP	8'13.45	100	0	0	Reserve
48	Juldah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	2333760	
49	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	17	372768	Engine problem
**	Mitancha, Cto, EPZ (Unit-1)	IPP	5'8.73*3'9.34	22	35	463300	
50	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	71	418560	Low demand
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	33600	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	308	6320399	
53	Jodiac Power	IPP	3'18.55+1'3.6	54	54	455843	
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
	Juldah unit-2 (Acom)	IPP	8'13.6	100	100	2377920	
Chattogram area Total				2266	1122	20957664	
55	Ashuganj TPP Unit-3	APSCL	1'150	135	0	0	Gas shortage.
	Ashuganj TPP Unit-4	APSCL	1'150	129	80	1958210	Gas shortage.
	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	Gas shortage.
56	Ashuganj 225 MW CCPP	APSCL	1'142*1'175	221	189	4846000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	295	7211300	FGMO
58	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	255	6381000	FGMO
59	Ashuganj 50 MW PP	APSCL	14'3.968	45	20	499608	Gas shortage.
60	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	5	136800	Gas shortage.
62	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'11.6	195	8	217454	Gas shortage.
63	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	43	1021572	Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	29'7.015	150	137	891563	
66	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	3184	Reserve
67	Chandpur 150 MW CCPP	PDB	1'106*1'57	163	90	2085000	Engine problem
68	Chandpur 200MW (Desh energy)	IPP	0	200	34	176160	Low demand
69	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	18	418176	Engine problem
70	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	8	203940	Engine problem
**	Impropr (Tripura)	Imported power	0	160	166	3369600	
71	Jangalia 35MW PP (Summit)	SIPP, PDB	4'8.73	35	33	650900	
72	Jangalia 52 MW PP (Lakshman)	IPP	6'8.92	52	43	315610	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3'67+2'6'97	25	21	462360	Engine problem
74	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Reserve
	Feni Lanka Power	IPP	7'18.415+1'9.78	114	85	440040	Low demand
	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	47	912240	Engine problem
Cumilla Area Total				2980	1577	32201717	
75	RPCL 210MW CCPP	IPP	4'35+1'70	202	110	2894360	Gas shortage.
76	Tangal 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	463284	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	95	1506240	
78	Sarshabara 3 MW Solar Plant	IPP	1'3	3	0	8550	
79	Mymensingh 200 MW PP (United)	IPP	200	200	175	2478900	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	109	2509200	#REF!
Mymensingh Area Total				637	511	9859434	
81	Fenchugonj CCPP Phase-1	PDB	2'32*1'33	70	91	2117000	
82	Fenchugonj CCPP Phase-2	PDB	2'35*1'35	90	30	722040	# 4 under maint.
83	Kushiara 163 MW CCPP (KP)	IPP	1'109*1'54	163	163	3355282	
84	Shahjibazar 330 MW CCPP	PDB	3'110	330	313	6903000	FGMO
85	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	50	1092000	
86	Fenchugonj 144MW PP (Energyprima)	RPP	12'3.3+5'92	44	45	1024248	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	219168	
88	Shahjibazar GTTP Unit. 8 & 9	PDB	2'35	66	59	1357132	FGMO
89	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	76	1590720	Engine problem
91	Sylhet 225 MW CCPP	PDB	1'142*1'189	231	150	3120040	
92	Sylhet 20 MW GTTP	PDB	1'20	20	18	422000	
93	Sylhet 50MW PP (EPL)	RPP	27'2	50	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	24	548520	
95	Bibiyan-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	300	7396000	FGMO
96	Bibiyan-II 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	246240	
	Bibiyan South 400 MW	PDB	400 MW	0	0	0	On test
Sylhet Area Total				1988	1340	30113990	
98	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2'500	1000	937	22486545	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7'17	115	99	950400	Engine problem
100	Faridpur 50 MW Peaking PP	PDB	8'6.89	54	0	0	Reserve
101	Khulna 225 MW CCPP	NWPQCL	1'150*1'175	230	0	0	Reserve
102	Copalganj 100 MW Peaking PP	PDB	1'9.98	100	0	16612	Reserve
103	Bheramara 410 MW CCPP	NWPQCL	1'278*1'132	410	345	8949600	FGMO
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5'8.5	40	40	643125	
105	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	100	570240	
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	35	171360	Low demand
107	Madhumati 100 MW PP	IPP	100 MW	105	15	76752	Low demand
Khulna Area Total				2284	1571	33864534	
108	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	96	740736	High voltage
110	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	38	698395	
111	Bhola 225 MW CCPP	PDB	2'63+1'98	194	65	1538900	GT-2 & ST Under maint.
112	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	78	1811539	Engine problem
	Payra 1320 MW	BCPCL	1'622	622	573	13956900	
Barisal Area Total				1054	850	18756570	
113	Baghabari 71 MW GTTP	PDB	1'71	71	0	685000	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	50	176082	
115	Bera 70 MW Peaking PP	PDB	9'8.29	71	0	0	Reserve
116	Ammura 50 MW PP(Sinha)	QRPP	7'7.9	50	0	0	Fuel shortage
117	Kaakshali 50 MW PP (Northern)	QRPP	6'8.9	50	0	0	Reserve
118	Kaakshali 50 MW Peaking PP	PDB	6'8.7	50	39	203867	Engine problem
119	Sirajgonj Unit-1 225MW	NWPQCL	1'150*1'175	210	0	0	Gas shortage.
120	Sirajgonj Unit-2 225MW	NWPQCL	1'150*1'175	220	198	4475391	FGMO
121	Sirajgonj Unit-3 225MW	NWPQCL	1'141	220	185	4455318	FGMO
122	Sirajgonj 400 MW CCPP Unit-4	SNWPQCL	1'282*1'132	414	412	9178672	FGMO
123	Santahar 50 MW Peaking PP	PDB	6'8.7	50	33	220910	
124	Bogra 22 MW PP (GBB)	RPP	6'4	22	22	494880	
125	Bogura 20 MW PP (Energyprima)	RPP	5'3.3+5'2	10	9	202690	
126	Ujjapara 11 MW PP (Summit)	SIPP, REB	4'2.90	11	11	226440	
127	Natore 52 MW PP (Rajlanka)	IPP	6'8.92	52	52	292800	
128	Chapanawabganj 100 MW Peaking PP	PDB	12'8.924	104	100	816920	
129	Baghabari 200 MW PP (Paramount)	IPP	200 MW	200	0	0	Reserve
130	Bagura 113 MW PP (Confidence)-2	IPP	113 MW	113	90	755232	Engine problem
	Confidence Power Bogura Unit-1 113 MW	IPP	6'18.55	113	50	235680	Low demand
Rajshahi Area Total				2183	1251	22419872	
131	Barapukuria TPP Unit-1	PDB	1'125	85	0	0	Under maint.
	Barapukuria TPP Unit-2	PDB	1'125	85	0	0	Coal shortage.
132	Barapukuria 275 MW TPP Unit-3	PDB	1'275	274	151	3649400	Coal shortage.
133	Rangpur 20 MW GTTP	PDB	1'20	20	0	0	Under maint.
134	Saidpur 20 MW GTTP	PDB	1'20	20	0	85000	Engine problem
135	Rangpur 113 MW PP (Confidence)	IPP	113 MW	113	112	1228800	
136	Sympa Solar Power 8MW	IPP	8 MW	8	0	36051	
Rangpur Area Total				605	273	4999251	
Total				19892	1184		