

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : **22-Sep-20**

Page -2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour Generation | | Energy Generated | Remarks |
|-------------------------------|--------------------------------------------------|----------------|--------------------|------------------|----------------------|-----------------|------------------|---------------------------|
| | | | | | MW | MW | | |
| Unit No. X Capacity | | | | | | | | |
| 1 | Ghorasal TPP (Unit-1&2) | PDB | 2*55 | 85 | 0 | 0 | 0 | Unit-1,2 Under maint. |
| | Ghorasal Repowered CCPP Unit-1 | PDB | 1*210 | 170 | 0 | 0 | 0 | Under maint. |
| | Ghorasal Repowered CCPP Unit-2 | PDB | 1*210 | 180 | 0 | 0 | 0 | Under maint. |
| | Ghorasal TPP Unit-5 | PDB | 1*210 | 190 | 115 | 2740500 | 0 | Gas shortage |
| 2 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1*243+1*122 | 365 | 200 | 4725055 | 0 | Machine problem |
| | Ghorasal 76.5 MW PP(MAX) | QRPP | 2*40 | 78 | 68 | 1461376 | 0 | Engine problem |
| 4 | Ghorasal 108MW PP (Regent) | IPP | 34*3.35 | 108 | 92 | 2140045 | 0 | Engine problem |
| 5 | Hanpur GTPP | SBU, PDB | 2*32 | 20 | 0 | 0 | 0 | Under maint. |
| 6 | Hanpur 412 MW CCPP | EGCB | 1*273+1*139 | 412 | 348 | 8372536 | 0 | FGMO |
| 7 | Hanpur 380MW CCPP(HPL) | IPP | 1*235+1*125 | 360 | 353 | 8039000 | 0 | Engine problem |
| 8 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2*150+1*150 | 450 | 370 | 8973500 | 0 | Frequency control |
| 9 | Meghnaghat 100 MW(EL) | QRPP | 12*8.9 | 100 | 7 | 201600 | 0 | Fuel Shortage |
| 10 | Meghnaghat CCPP(Summit) | IPP | 2*110+1*110 | 305 | 0 | 0 | 0 | Gas shortage |
| 11 | Madanganj 102 PPI(Summit) | QRPP | 6*17 | 100 | 93 | 2026880 | 0 | |
| 12 | Madanganj-55 MW PPI(Summit) | (IPP) | | | 55 | 1247304 | 0 | |
| 13 | Karaniganj 100 MW Unit-3 | QRPP | 3*17.08+1*11.3 | 100 | 47 | 6260771 | 0 | Machine problem |
| 14 | Narshingdi 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 22 | 4240444 | 0 | |
| 15 | 210 MW Siddhirgonj TPP | PDB | 1*210 | 115 | 0 | 0 | 0 | Under maint. |
| 16 | Siddhirgonj 2*120 MW GTTP | EGCB | 2*105 | 210 | 0 | 0 | 0 | Gas shortage |
| 17 | Siddhirgonj 100 PPI(Dutch Bangla) | QRPP | 12*8.9 | 100 | 0 | 50880 | 0 | Fuel Shortage |
| 18 | Siddhirgonj 335 MW CCPP | EGCB | 12*17+1*18 | 335 | 258 | 7025667 | 0 | FGMO |
| 19 | Gagnagar 102 MW PP (Digital Po) | IPP | 12*8.924 | 102 | 93 | 2124864 | 0 | Engine problem |
| 20 | Katpoti 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 0 | 0 | 0 | Fuel Shortage |
| 21 | Kamalaghat 54 MW PP(Banco En) | IPP | 3*18 | 54 | 0 | 717120 | 0 | High voltage |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 150 | 964320 | 0 | |
| 23 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 1103455 | 0 | |
| 24 | Nabaganj 55 MW PP (Southern) | IPP | 3*19.3 | 55 | 55 | 1007937 | 0 | |
| 25 | Basia 108MW PPGCL | IPP | 12*8.775+1*3.5 | 108 | 0 | 0 | 0 | Machine problem |
| 26 | Summit Power (Maghabadi-Ashuli) | SIPP, REB | 3*3.67+4*8.73 | 80 | 52 | 1214520 | 0 | Engine problem |
| 27 | Maona 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 25 | 543600 | 0 | Engine problem |
| 28 | Rupganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 806800 | 0 | |
| 29 | Gazipur 52 MW PP | IPP | 6*8.9 | 52 | 42 | 301344 | 0 | |
| 30 | Tongi 80 MW GTTP | PDB | 1*105 | 105 | 0 | 0 | 0 | Under maint. |
| 31 | Kodda 300 MW PP Unit-2 (Summ) | IPP | 18*17.076 | 300 | 286 | 6626507 | 0 | Machine problem |
| 32 | Keraniganj 300 MW PP (APR) | IPP | 25*11.4 | 300 | 32 | 56098 | 0 | Low demand. |
| 33 | Bramhanganj 100 MW PP (Aggr) | IPP | 100 | 100 | 25 | 43242 | 0 | |
| 34 | Aurahati 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 30 | 40817 | 0 | |
| 35 | Kodda 149 MW PP Unit-1 (Summ) | IPP | 149 | 149 | 130 | 326740 | 0 | Engine problem |
| 36 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 84 | 1454352 | 0 | Engine problem |
| | Meghnaghat 104 MW PP (OPCL) | IPP | 18.5*6 | 104 | 17 | 439680 | 0 | |
| | | | | 5898 | 3137 | 6873860 | | |
| Dhaka area Total | | | | | | | | |
| 37 | Chattoagram TPP-1 | PDB | 1*210 | 180 | 120 | 2900000 | 0 | Gas shortage. |
| | Chattoagram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | 0 | Gas shortage. |
| 38 | Raozan 25 MW PP | IPP | 3*8.9 | 25 | 12 | 125317 | 0 | |
| 39 | Teknaf 20MW PP (Solartech)Teknaf Solartech Energ | | 20 | 20 | 0 | 20925 | 0 | |
| 40 | Palenga 50MW PP (Baraka) | IPP | 6*8.98 | 50 | 50 | 618720 | 0 | |
| 41 | Kaptai Hydro: Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 115 | 1306940 | 0 | Low water level |
| 42 | Sikalbaha 22MW PP (Doreen) | PDB | 1*150+1*75 | 225 | 0 | 0 | 0 | Gas shortage |
| 43 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 0 | 0 | 0 | Gas shortage |
| 44 | Sikalbaha 105 MW PP (Baraka S) | IPP | 105 MW | 105 | 17 | 465018 | 0 | Transformer OIL |
| 45 | Hathazari 100 MW peaking PP | PDB | 11*8.9 | 98 | 0 | 0 | 0 | Under maint. |
| 46 | Dohazari -Kalaish 100 MW Peakin | QRPP | 6*17 | 102 | 85 | 361001 | 0 | |
| 47 | Julidah 100 MW Unit-1 (Azom) | PDB | 8*13.45 | 100 | 50 | 191960 | 0 | High voltage |
| 48 | Julidah 100 MW Unit-3 (Azom) | IPP | 100 | 100 | 100 | 2333040 | 0 | |
| 49 | Baratkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 20 | 469440 | 0 | |
| | * Malarcha, Ctg, EPZ (Unite) | | 5*8.73+3*9.34 | 0 | 20 | 548160 | 0 | |
| 50 | Chattoagram 108 MW PP (ECPV) | IPP | 16*7 | 108 | 84 | 1590720 | 0 | Engine problem |
| 51 | Kaptai 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 16439 | 0 | |
| 52 | Anwara 300 MW PP (Unite) | IPP | 300 MW | 300 | 305 | 7143382 | 0 | |
| 53 | Jodda Power | IPP | 3*18.55+1*3.6 | 54 | 38 | 666976 | 0 | |
| 54 | Kamashuli Power Ltd. | IPP | 1*10 | 110 | 0 | 0 | 0 | Transformer OIL |
| | Julidah unit-2 (Azom) | IPP | 8*13.6 | 100 | 100 | 2354880 | 0 | |
| | | | | 2266 | 1116 | 21072518 | | |
| Chattoagram area Total | | | | | | | | |
| 55 | Ashuganj TPP Unit-3 | APSCL | 1*150 | 135 | 0 | 0 | 0 | Gas shortage. |
| | Ashuganj TPP Unit-4 | APSCL | 1*150 | 129 | 0 | 0 | 0 | Gas shortage. |
| | Ashuganj TPP Unit-5 | APSCL | 1*150 | 134 | 100 | 2394302 | 0 | Gas shortage. |
| 56 | Ashuganj 225 MW CCPP | APSCL | 1*142+1*75 | 221 | 181 | 4456000 | 0 | FGMO |
| 57 | Ashuganj 450 MW CCPP(North) | APSCL | 1*360 | 360 | 310 | 7900700 | 0 | FGMO |
| 58 | Ashuganj 450 MW CCPP(South) | APSCL | 1*360 | 360 | 0 | 0 | 0 | Under maint. |
| 59 | Ashuganj 50 MW PP | APSCL | 14*3.968 | 45 | 29 | 729792 | 0 | Gas shortage |
| 60 | Ashuganj 55 MW PP (Precision) | RPP | 15*4 | 55 | 5 | 281760 | 0 | Gas shortage. |
| 62 | Ashuganj 195MW PP (AFSCL-Un) | IPP | 20*9.73+1*16 | 195 | 8 | 217454 | 0 | Gas shortage. |
| 63 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 51 | 1252779 | 0 | |
| 64 | Ashuganj 150MW PP (Midland) | IPP | 23*10.15 | 150 | 103 | 1415345 | 0 | Engine problem |
| 66 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 42 | 108400 | 0 | Engine problem |
| 67 | Chandpur 150 MW CCPP | PDB | 1*106+1*57 | 163 | 85 | 2174130 | 0 | |
| 68 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 105 | 238560 | 0 | High voltage |
| 69 | Feni 22MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 18 | 375624 | 0 | Engine problem |
| 70 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 8 | 141680 | 0 | Engine problem |
| | * Imported (Tripura) | Imported power | 0 | 160 | 164 | 3508900 | 0 | |
| 71 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 25 | 562200 | 0 | Engine problem |
| 72 | Jangalia 52 MW PP (Lakdanavi) | IPP | 6*8.92 | 52 | 48 | 431275 | 0 | |
| 73 | Cumilla 25 MW PP (Summit) | SIPP, PDB | 3*3.67+2*6.97 | 25 | 18 | 427850 | 0 | Engine problem |
| 74 | Daudkandi 200 MW PP (B.Trac) | IPP | 154*1.4 | 200 | 0 | 0 | 0 | Low demand. |
| | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 100 | 603060 | 0 | |
| | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 113 | 2268940 | 0 | |
| | | | | 2860 | 1513 | 29506531 | | |
| Cumilla Area Total | | | | | | | | |
| 75 | RPCL 210MW CCPP | IPP | 4*35+1*70 | 202 | 143 | 3323300 | 0 | Machine problem & Gas sho |
| 76 | Tangal 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 16 | 359028 | 0 | Engine problem |
| 77 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 95 | 0 | 0 | 0 | Machine problem |
| 78 | Sarishabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 4200 | 0 | |
| 79 | Mymensingh 200 MW PP (Unite) | IPP | 200 | 200 | 200 | 4540800 | 0 | High voltage |
| 80 | Jamalpur 115 MW PP (Unite) | IPP | 115 MW | 115 | 100 | 1298400 | 0 | #REF! |
| | | | | 637 | 459 | 9531788 | | |
| Mymensingh Area Total | | | | | | | | |
| 81 | Fenchugonj CCPP Phase-1 | PDB | 2*32+1*33 | 70 | 69 | 2133300 | 0 | |
| 82 | Fenchugonj CCPP Phase-2 | PDB | 2*35+1*35 | 90 | 30 | 728640 | 0 | # 4 under maint. |
| 83 | Kushihara 163 MW CCPP (KP) | IPP | 1*109+1*54 | 163 | 163 | 3513354 | 0 | |
| 84 | Shahjibazar 330 MW CCPP | PDB | 3*110 | 330 | 217 | 4883000 | 0 | |
| 85 | Fenchugonj 51 MW PP (Barakati) | RPP | 19*2.90 | 51 | 52 | 1116000 | 0 | |
| 86 | Fenchugonj 44MW (Energyprima) | IPP | 12*3.3+5*2 | 44 | 47 | 1122048 | 0 | |
| 87 | Hobaganj 11 MW PP (Confidence-E) | SIPP, REB | 4*2.90 | 11 | 11 | 153000 | 0 | |
| 88 | Shahjibazar GTTP Unit- 8 & 9 | PDB | 2*35 | 66 | 67 | 1492128 | 0 | |
| 89 | Shahjibazar 86MW PP (Shahjibaz) | RPP | 32*2.90 | 86 | 87 | 1883520 | 0 | |
| 91 | Sylhet 225 MW CCPP | PDB | 1*142+1*89 | 231 | 205 | 4904640 | 0 | |
| 92 | Sylhet 20 MW GTTP | PDB | 1*20 | 20 | 18 | 431000 | 0 | |
| 93 | Sylhet 50MW PP (EPL) | RPP | 27*2 | 50 | 0 | 0 | 0 | Contract Expired |
| 94 | Shahjibazar 25 MW PP | SIPP, PDB | 3*3.34 | 25 | 24 | 542208 | 0 | |
| 95 | Bibiana-II 341 MW CCPP (Summ) | IPP | 1*222+1*119 | 341 | 280 | 7197200 | 0 | FGMO |
| 96 | Bibiana-III 400 MW CCPP | PDB | 400 MW | 400 | 0 | 0 | 0 | Under maint. |
| 97 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 9 | 204300 | 0 | |
| | Bibiana South 400 MW | PDB | 400 MW | 0 | 0 | 0 | 0 | On test |
| | | | | 1988 | 1299 | 30304038 | | |
| Sylhet Area Total | | | | | | | | |
| 98 | Bheramara GTTP Unit-3 | PDB | 1*20 | 16 | 0 | 0 | 0 | Reserve. |
| | Bheramara (WDC) | Imported power | 2*500 | 1000 | 919 | 22144727 | 0 | |
| 99 | Khulna 115 PP MW (KPCL-2) | QRPP | 7*17 | 115 | 115 | 2217600 | 0 | |
| 100 | Faridpur 50 MW Peaking PP | PDB | 8*6.89 | 54 | 9 | 16740 | 0 | |
| 101 | Khulna 225 MW CCPP | NWPGCL | 1*150+1*75 | 230 | 185 | 3438257 | 0 | |
| 102 | Gopalganj 100 MW Peaking PP | PDB | 16*6.98 | 109 | 0 | 6016 | 0 | Reserve. |
| 103 | Bheramara 410 MW CCPP | NWPGCL | 1*278+1*132 | 410 | 225 | 6065568 | 0 | Gas Shortage |
| 104 | Nopara 40 MW PP (Khanjahan A) | QRPP | 5*8.5 | 40 | 40 | 317625 | 0 | |
| 105 | Nopara 100 MW PP (Bangla Tr) | IPP | 70*1.4 | 100 | 67 | 447380 | 0 | Low voltage |
| 106 | Rupsha 105 MW PP (Orion rupsh) | IPP | 6*18.445 | 105 | 70 | 517440 | 0 | Engine problem |
| 107 | Madhumati 100 MW PP | IPP | 100 MW | 105 | 0 | 0 | 0 | Reserve. |
| | | | | 2284 | 1630 | 35171333 | | |
| Khulna Area Total | | | | | | | | |
| 108 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 80 | 960192 | 0 | |
| 110 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 30 | 562856 | 0 | |
| 111 | Bhola 225 MW CCPP | PDB | 2*63+1*98 | 194 | 60 | 1367000 | 0 | GT-2 Under maint. |
| 112 | Bhola 95 MW PP (Aggreko) | QRPP | 8*11.0 | 95 | 78 | 1861311 | 0 | Engine problem |
| | Payra 1320 MW | BCPCL | 1*6 | | | | | |