

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : **28-Sep-20**

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	200	476600	
	Ghorasal TPP Unit-5	PDB	1*210	190	115	2740500	Gas shortage
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Machine problem
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	43	1003636	Gas shortage
5	Hanpur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Hanpur 412 MW CCPP	EGCB	1*273+1*38	412	0	0	Under maint.
7	Hanpur 360MW CCPP(HPL)	IPP	1*235+1*125	360	323	7834000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	370	7846500	Frequency control
9	Meghnaghat 100 MW (EL)	QRPP	1*28.9	100	100	2235840	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	140	3480611	Gas shortage
11	Madangan 102 PP(Summit)	QRPP	6*17	100	97	2073696	
12	Madangan-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	40	732595	Engine problem
13	Karaniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	100	539043	
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	395640	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	57	1702000	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	100	2186880	
18	Siddhirganj 335 MW CCPP	EGCB	1*217+118	335	0	560857	Tripped at 18.02
19	Saenigar 102 MW PP (Digital Power)	IPP	12*8.924	102	83	1273624	Engine problem
20	Kaptoti 52 MW PP (Sinha)	IPP	7*7.3	51	0	0	Fuel Shortage
21	Kamalaghat 54 MW PP(Banco Ener)	IPP	3*18	54	54	698520	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	1435680	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	906058	
24	Nabaganj 55 MW PP (Southern pow)	IPP	3*19.3	55	55	1160256	
25	Boalis 108MW PP(ELC)	IPP	12*9.75+1*3.5	108	0	0	Fuel Shortage
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*7.3	80	51	1218840	Engine problem
27	Mona 33 MW PP(Summit)	SIPP, REB	4*7.3	33	25	633700	
28	Ruganaj 33 MW PP(Summit)	SIPP, REB	4*7.3	33	33	834300	
29	Gasipur 52 MW PP	IPP	6*8.9	52	51	443364	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.075	300	285	4639307	
32	Karaniganj 300 MW PP (APR)	IPP	25*12.4	300	257	1234953	Low demand.
33	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	97	475796	
34	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	94	430232	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3322940	
36	Gasipur 100 MW PP	RPCL	100 MW	105	86	1320120	
	<b>Meghnaghat 104 MW PP (OPCL)</b>	IPP	18*5.6	104	104	2506400	
	<b>Disha area Total</b>			<b>5995</b>	<b>3346</b>	<b>65679388</b>	
37	Chattogram TPP-1	PDB	1*210	180	120	2900000	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage.
38	Raozan 25 MW PP	IPP	3*8.9	25	25	245908	
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Ener	20	20	0	136800	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	624960	
41	Kaptoti Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	42	985980	Low water level
42	Sikalbaha 225MW PP	PDB	1*150+1*175	225	204	4830367	
43	Sikalbaha Peaking GT	PDB	1*150	150	139	3213538	
44	Sikalbaha 105 MW PP (Baraka Sikat)	IPP	105 MW	105	0	0	Reserve.
45	Haihzari 100 MW peaking PP	PDB	11*8.9	98	9	43520	Under maint.
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	102	644498	
47	Judha 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	20	94440	Low demand.
48	Judha 100 MW Unit-2 (Acorn)	IPP	100	100	100	171380	
49	Barsabanda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	483168	
*	Malancha, Ctg. EPZ (United)		5*7.3+3*9.34	0	25	504960	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	90	1170240	Engine problem
51	Kapti 7 MW Solar PP	PDB	7.4 MW	7	0	35040	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	179	2805164	Low demand.
53	Jodac Power	IPP	3*18.55+1*3.6	54	54	1144709	
54	Kamajhuri Power Ltd.	IPP	1*10	110	0	0	Reserve.
	Judha Unit-2 (Acorn)	IPP	8*13.6	100	100	2156160	
	<b>Chattogram area Total</b>			<b>2266</b>	<b>1280</b>	<b>23740313</b>	
55	Ashuganj TPP Unit- 3	APSCCL	1*150	135	0	0	Gas shortage.
	Ashuganj TPP Unit- 4	APSCCL	1*150	129	0	0	Gas shortage.
	Ashuganj TPP Unit- 5	APSCCL	1*150	134	80	2173906	
56	Ashuganj 225 MW CCPP	APSCCL	1*142+1*75	221	197	4547000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCCL	1*360	360	275	7302100	FGMO
58	Ashuganj 450 MW CCPP(South)	APSCCL	1*360	360	0	0	Under maint.
59	Ashuganj 90 MW PP	APSCCL	14*3.968	45	29	654408	Gas shortage
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	54	1236960	
62	Ashuganj 195MW PP (APSCCL-United)	IPP	20*9.73+1*16	195	8	936727	Gas shortage.
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	34	816579	
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	80	884872	Low demand.
65	Titas 50 MW Peaking PP	PDB	8*5.92	52	50	317468	
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	90	2201970	
68	Chandpur 200MW (Desh energy)	IPP	0	200	200	1087200	
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	18	408528	Engine problem
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	172440	Engine problem
**	Impogor (Tripura)	Imported power		160	158	3346590	
71	Jangalia 30MW PP (Summit)	SIPP, PDB	4*7.3	33	33	805520	
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	43	497928	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	18	458180	Engine problem
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	100	211008	Reserve.
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	101	706800	Engine problem
	Chowmuhani 113 MW	IPP	12*9.78+2*31.1	113	113	2478000	
	<b>Chumilla Area Total</b>			<b>2980</b>	<b>1687</b>	<b>31245162</b>	
75	RPCL 210MW CCPP	IPP	4*26+1*70	202	154	3651080	Machine problem & Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	380376	Engine problem
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	0	0	Engine problem
78	Sarisbari 3 MW Solar Plant	IPP	1*3	3	0	11500	
79	Mymensingh 200 MW PP (United)	IPP	200	200	200	4500000	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	105	1282800	#REF!
	<b>Mymensingh Area Total</b>			<b>637</b>	<b>478</b>	<b>9835756</b>	
81	Fenchugaj CCPP Phase-1	PDB	2*32+1*33	70	60	1645000	
82	Fenchugaj CCPP Phase-2	PDB	2*35+1*35	90	90	718320	#4 under maint.
83	Kushihara 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3605563	Frequency control
84	Shahbazar 330 MW CCPP	PDB	3*110	330	183	4450000	Gas shortage.
85	Fenchugaj 51 MW PP (Barakattalia)	RPP	19*2.90	51	53	1123200	
86	Fenchugaj 44MW (Energyprima)	RPP	12*3.3+5*2	44	43	976392	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	685000	
88	Shahbazar GTTP Unit- 8 & 9	PDB	2*35	66	63	1487520	
89	Shahbazar 86MW PP (Shahbazar)	RPP	32*2.90	86	85	1958400	
91	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	97	2364410	
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	427000	
93	Sylhet 50MW PP (EPL)	RPP	2*2	50	0	0	Contract Expired
94	Shahshahulia 25 MW PP	SIPP, REB	3*3.34	25	24	562024	
95	Bishnoidi 341 MW CCPP (Summit)	IPP	1*222+1*119	341	310	7210000	FGMO
96	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	241740	
	Bibiyana South 400 MW	PDB	400 MW	0	0	5900	On test
	<b>Sylhet Area Total</b>			<b>1988</b>	<b>1117</b>	<b>26990469</b>	
98	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (WDC)	Imported power	2*500	1000	923	22167273	
99	Khulna 115 PP MW (RPCL-2)	QRPP	7*17	115	108	1248650	
100	Fatipour 50 MW Peaking PP	PDB	8*6.89	54	4	10730	Reserve.
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	215	3587520	
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	1536	Reserve.
103	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	325	7985376	Gas shortage
104	Noppara 40 MW PP (Kharajahan Ali)	QRPP	5*8.5	40	40	301500	
105	Noppara 100 MW PP (Barga Trac)	IPP	70*1.4	100	100	657550	
106	Ruzsha 105 MW PP (Oton ruzsha)	IPP	8*18.445	105	90	1585920	Engine problem
107	Madhumati 100 MW PP	IPP	100 MW	105	0	0	Reserve.
	<b>Khulna Area Total</b>			<b>2284</b>	<b>1803</b>	<b>37494575</b>	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	556992	
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	36	575262	
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	0	1267000	GT-2 Under maint.
112	Bhola 85 MW PP (Aggreko)	QRPP	86*1.0	85	86	1828282	Engine problem
	Rays 1320 MW	BCPCL	1*822	822	622	13307000	Under maint unit 1
	<b>Barisal Area Total</b>			<b>1054</b>	<b>846</b>	<b>17534336</b>	
113	Baghani 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage.
	Baghani 100 MW GTTP	PDB	1*100	100	0	0	
114	Baghani 50 MW Peaking PP	PDB	6*8.9	52	50	284274	
115	Bera 71 MW Peaking PP	PDB	9*8.29	71	40	233157	
116	Anwara 50 MW PP (Sinha)	QRPP	7*7.9	50	0	0	Fuel Shortage
117	Kaikhali 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Fuel Shortage
118	Kaikhali 50 MW Peaking PP	PDB	6*8.7	50	36	212400	
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	STC U/M & Gas Shortage
120	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	161	4229373	FGMO
121	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	165	4507364	FGMO
122	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	387	9210500	FGMO
123	Santabar 50 MW Peaking PP	PDB	6*8.7	50	0	0	Reserve.
124	Bogra 22 MW PP (GBB)	RPP	6*4	22	0	423840	
125	Bogra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	10	10	131652	
126	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	249498	
127	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	474720	
128	Chapanawabganj 100 MW Peaking	PDB	12*8.924	104	97	685528	
129	Baghani 200 MW PP (Paramount)	IPP	200 MW	200	175	643988	
130	Bagua 113 MW PP (Confidence)-2	IPP	113 MW	113	113	1244828	Low demand.
	Confidence Power Bogura Unit-1 113	IPP	6*18.55	113	109	2340000	
	<b>Rajshahi Area Total</b>			<b>2183</b>	<b>1406</b>	<b>24870926</b>	
131	Barapukuria TPP Unit-1	PDB	1*125	85	0	0	Under maint.
	Barapukuria TPP Unit-2	PDB	1*125	85	0	0	Coal shortage.
132	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	150	3661500	Coal shortage.
133	Rangpur 20 MW GTTP	PDB	1*20	20	0	0	Under maint.
134	Saipur 20 MW GTTP	PDB	1*20	20	0	0	Reserve.
135	Rangpur 113 MW PP (Confidence)	IPP	113 MW	113	0	1814400	
136	Sympa Solar Power 8MW	IPP	8 MW	8	0	39516	
	<b>Rangpur Area Total</b>			<b>605</b>	<b>150</b>	<b>5515416&lt;/</b>	