

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month December, 2020		Day : Friday		Date : 04.12.20							
Probable Maximum Demand :		7800 MW		Probable Maximum Generation : 13397 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 100.08 ft		Today = 99.98 ft							
				Rule Curve = 105.73 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.12.20 (Yesterday)		04.12.20 (Today)		03.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0	85	Under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	93	94	115	115	76	Gas Shortage
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	STG Commissioning
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	115	115	115	115	75	Gas Shortage
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200		
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	51	52	100	100		
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	312	325	325	325		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	340	400	400		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	370	342	412	412		
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	10	100	100	100		
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	145	126	155	155		
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	100	100	100	100		
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	1	48	100	100		
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	28	15	55	55		
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	46	86	100	100		
19	Gagnagar 102 MW PP (Digital Powe)	HFO (IPP)	12x8.924	102	102	3	0	100	100		
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
21	Summit Power (Madhatdi-Ashulia)	Gas (SIPP, REB)	8x3.67+1x7.3	80	80	34	58	58	58		
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25		
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25		
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52		
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105		
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	98	150	150		
27	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	10	50	50		
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	300	300	300		
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	149	149	149		
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300		
32	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	100		
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	0	55	55		
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	90	90	90		
	Manikgonj 162MW PP	HFO (IPP)				0	0	0	0		
<b>Dhaka Zone Total</b>				<b>6119</b>	<b>5895</b>	<b>2188</b>	<b>2826</b>	<b>3774</b>	<b>4064</b>	<b>564</b>	<b>715</b>
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	89	86	92	92	144	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	50	50		
44	Sikalbaha 105 MW PP (Baraka Siki)	HFO (IPP)	6x18.415	105	105	0	0	100	100		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Gas Shortage
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	215	204	215	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	198	179	300	300		
48	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	102	102		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	9	10	20		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	100	100		
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	45	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	80	50	100	100		
	Antima Energy Ltd.	HFO (IPP)				2	0	0	0		
<b>Chattogram Zone Total</b>				<b>2326</b>	<b>2266</b>	<b>765</b>	<b>778</b>	<b>1503</b>	<b>1498</b>	<b>474</b>	<b>180</b>
57	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	140	80	100	100	49	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	80	80	134	Gas Shortage
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	30	30		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	198	160	225	225		
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Under maint.
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Under maint.
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	35	5	8	8	50	Gas shortage
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	128	68	68	68	127	Gas shortage
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	142	150	150	150		
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	50	
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	50	50		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	118	100	200	200		
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	22	22		
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11		
71	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
72	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	21	21		
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	11	20	21		
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+4x15.15+15x1.02	200	200	0	0	0	200		
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114		
76	Chowmuhani 113 MW Impoort (Tripura)	HFO (IPP)	12*9.78+2*3.1	113	113	26	26	113	113		
	**			160	160	68	120	141	150		
<b>Cumilla Zone Total</b>				<b>3040</b>	<b>2980</b>	<b>1011</b>	<b>877</b>	<b>1468</b>	<b>1728</b>	<b>495</b>	<b>720</b>
77	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	105	110	164	150	92	Gas Shortage
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20		
79	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	60	83	95		
80	Jamalpur 115 MW PP (Unitec)	HFO (IPP)	12x9.87	115	115	106	115	115	115		
81	Mymensingh 200 MW PP (Unitec)	HFO (IPP)	21x9.780	200	200	0	60	200	200		
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	2	0	1.6	0		
	Mymensingh PV 50 MW Solar PP	Solar (IPP)				35	0	50	0		
<b>Mymensingh Zone Total</b>				<b>645</b>	<b>637</b>	<b>265</b>	<b>365</b>	<b>633.6</b>	<b>580</b>	<b>92</b>	<b>0</b>

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.12.20 (Yesterday)		04.12.20 (Today)		03.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
83	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	40	40	60	60					
84	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	22	22	22	22					
85	Fenchugonj 51 MW PP (Barakattuli)	Gas (RPP)	19x2.90	51	51	53	53	51	51					
86	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3-5x2.0	44	44	43	47	44	44					
87	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	5	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	32	36	36	36					
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	152	157	155	155					
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	76	78	86	86					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	19	19	20	20					
94	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0					
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0					
96	Shahjahanulla 25 MW PP	Gas (GIPP, REB)	3x9.34	25	25	14	16	16	16					
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	285	325	325					
98	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	238	238	235	235					
	Bibiyana South 400 MW	Gas (PDB)				0	0	0	0					
	<b>Sylhet Zone Total</b>			<b>2033</b>	<b>1988</b>	<b>1114</b>	<b>1112</b>	<b>1224</b>	<b>1224</b>	<b>0</b>	<b>0</b>			
99	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
100	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	0	0	0	0					
101	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25					
102	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	65	65					
103	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	0	0	100	220					
104	Khulna 115 PP MW (KPC-2)	HFO (QRPP)	7x17	115	115	0	66	115	115					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	100					
106	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40					
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	90	90	90					
108	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	448	760	580	768					
	<b>Khulna Zone Total</b>			<b>2288</b>	<b>2284</b>	<b>538</b>	<b>956</b>	<b>1115</b>	<b>1539</b>	<b>0</b>	<b>0</b>			
109	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
110	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	26	27	27					
111	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.		
112	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	43	86	95	95					
113	Payra 1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	500	660	600	660					
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				10	8	35	35					
	United Payra Power Ltd.	HFO (IPP)				0	0	0	0					
	<b>Barishal Zone Total</b>			<b>1054</b>	<b>1054</b>	<b>568</b>	<b>780</b>	<b>867</b>	<b>927</b>	<b>0</b>	<b>194</b>			
114	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
115	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50					
116	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40					
118	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0					
119	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	104	100	100					
120	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50					
121	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
122	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	33					
123	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
124	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150 + 1x75	220	220	109	175	220	220					
125	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	179	188	225	225					
126	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	426	301	400	400					
127	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	22	22					
128	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3-5x2.0	20	10	0	0	0	0					
129	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	9	11	11	11					
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52					
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	20	113	113	113					
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113					
	<b>Rajshahi Zone Total</b>			<b>2193</b>	<b>2183</b>	<b>831</b>	<b>1026</b>	<b>1506</b>	<b>1629</b>	<b>381</b>	<b>0</b>			
133	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	92	95	95	95	-10		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
134	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0					
135	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
136	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	114	113	113	113					
137	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
138	Majpara Tatalia 8 MW Solar PP (Sympha P)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
	<b>Rangpur Zone Total</b>			<b>685</b>	<b>605</b>	<b>211</b>	<b>208</b>	<b>216</b>	<b>208</b>	<b>75</b>	<b>0</b>			
	<b>Sub-total: Plants in operation</b>			<b>20383</b>	<b>19892</b>	<b>7491.0</b>	<b>8928</b>	<b>12307</b>	<b>13397</b>	<b>2081</b>	<b>1809</b>			
	Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss													
	(B) Contract expired power plants													
	Sub-Total: Plants under long term maintenance													
	<b>Gross Total</b>													
				<b>20383</b>	<b>19892</b>	<b>7491</b>	<b>8928</b>	<b>12307</b>	<b>13397</b>	<b>2081</b>	<b>1809</b>			
	<b>(C) Actual data of 03.12.20 (Yesterday) Thursday :</b>													
01.	Max. Demand (Generation end)	:	8928.00	MW,	at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand (Sub-station end)	:	8496.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	8928.00	MW,	at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	5721.00	MW,	at =	5:00 hrs	Dhaka	3200	3200	0	Mymensingh	651	651	0
05.	Day-peak Generation (Generation end)	:	7491.00	MW,	at =	12:00 hrs	Chattogram	943	943	0	Sylhet	316	316	0
06.	Evening-peak Generation (Generation end)	:	8928.00	MW,	at =	19:00 hrs	Khulna	1018	1018	0	Barishal	236	236	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	839	839	0	Rangpur	577	577	0
08.	Actual Minimum Generation up to 8:00 hrs.	:	5707.00	MW,	at =	7:00 hrs and	Cumilla	716	716	0				
09.	Generation shortfall at evening peak due to :	:					13. Fuel cost :		(a) Gas = 120437749 Taka		(c) Coal = 59790101 Taka		0	
	a) Gas limitation	:	1862	MW			(b) Oil = 288444947 Taka		Total = 468672796 Taka					
	d) Coal supply Limitation	:	75	MW			14. Maximum Temperature in Dhaka was : 29.2° C							
	b) Low water level in Kaptai lake	:	144	MW			15. Export through East-West interconnections :							
	c) Plants under shut down/ maintenance	:	1809	MW			At evening peak-hour : -17 MW, at 19:00 hrs							
10.	Total Energy (Generation + India Import)	:	171.93	MKWh			Maximum : -316 MW, at 8:00 hrs							
	By Gas =	104.762	MKWh				Energy : 1.417 MKWh							
	By Coal =	12.810	MKWh											
	By Solar =	0.402	MKWh											
11.	Total Gas Supplied	:	874.33	MKWh										
	<b>(D) Forecast of 04.12.20 (Today) Friday :</b>													
01.	Maximum Demand	:	7800	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13397	MW	(Generation end)		05.	Total Generation	:	150.21	MKWh			
03.	Maximum Shortage	:	-5597	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :		27.6° C				

\* Captive Power \*\* Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazool Islam Shaker)  
Deputy Secretary, Generation