

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month December, 2020			Day : Wednesday				Date : 16.12.20				
Probable Maximum Demand : 8000 MW			Probable Maximum Generation : 13495 MW				Rule Curve = 104.60 ft.				
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 99.21 ft.		Today = 99.15 ft.		15.12.20 (Yesterday)				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.12.20 (Yesterday)		16.12.20 (Today)		15.12.20 (Yesterday)	Machines shut-down (MW)	Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
<b>(A) Plants in operation:</b>											
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0	85	Under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	STG Commissioning
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	115	115	115	115	75	Gas Shortage
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300		
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	101	101	100	100		
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	144	301	360	360		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	300	450	450		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	366	363	412	412		
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	60	100	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305	Gas Shortage
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	100	100	100	100		
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	15	48	100	100		
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	48	55	55	55		
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	72	0	100	100		
19	Gagnagar 102 MW PP (Digital Powe)	HFO (IPP)	12x8.924	102	102	7	7	100	100		
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	16	16	16		
21	Summit Power.(Machabdi-Ashulia)	Gas (SIPP, REB)	6x8.67+7x8.73	80	80	49	57	58	58		
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	25	25	25		
23	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	15	40	52	52		
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	47	105	105		
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	64	150	150		
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	6	50	50		
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	180	300	300	300		
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	83	140	149	149		
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
32	Bramhanggan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	0	50	100		
33	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	0	60	100		
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	28	17	55	55		
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	90	90	90		
38	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	0	0	0	0		
<b>Dhaka Zone Total</b>				<b>6281</b>	<b>6057</b>	<b>2268</b>	<b>2734</b>	<b>3694</b>	<b>3984</b>	<b>793</b>	<b>885</b>
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x30	230	230	48	44	44	44	186	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0		
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25		
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50		
45	Sikalbaha 105 MW PP (Baraka Sikt)	HFO (IPP)	6x18.415	105	105	0	0	100	100		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Gas Shortage
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	230	204	215	225		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	161	161	300	300		
49	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	85	85		
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	10	20	30		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	7	102	102		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	39	54	54	54		
56	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	100	100	100		
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0		
<b>Chattogram Zone Total</b>				<b>2326</b>	<b>2266</b>	<b>720</b>	<b>815</b>	<b>1447</b>	<b>1442</b>	<b>516</b>	<b>180</b>
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	120	80	130	130	49	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	184	181	225	225		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	220	0	0	140	Was Under maint.
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Under maint.
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	16	16	45	45	179	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	15	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	150	143	150	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	48	60	60	115	Under Maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	85	68	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	20	21		
75	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	9x14.40+1.515+15x1.05	200	200	0	0	0	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	26	113	113		
**	Impoort (Tripura)	India		160	160	88	108	139	148		
<b>Cumilla Zone Total</b>				<b>3040</b>	<b>2980</b>	<b>763</b>	<b>1055</b>	<b>1388</b>	<b>1648</b>	<b>637</b>	<b>475</b>
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	107	90	110	110	112	Gas Shortage
79	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	12	95	95	95		
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	8	200	200		
83	Sarisabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	1	0	1.6	0		
84	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	11	0	50	0		
	Tangal 22 MW PP(Pali) Power Gen	HFO (SIPP)				26	26	26	26		
<b>Mymensingh Zone Total</b>				<b>695</b>	<b>687</b>	<b>292</b>	<b>354</b>	<b>618</b>	<b>566</b>	<b>112</b>	<b>0</b>

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.12.20 (Yesterday)		16.12.20 (Today)		15.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	20	20	30	30					
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43					
87	Fenchugonj 51 MW PP (Barakatula)	Gas (RPP)	19x2.90	51	51	50	52	51	51					
88	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	50	43	44	44					
89	Kushlaria 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163					
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11					
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	21	36	36	36					
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	118	121	150	150	209		Gas Shortage		
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	76	74	86	86					
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	120	96	150	150					
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	20	20					
96	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	239	120	400	400					
	Bibiyana South 400 MW	Gas (PDB)				125	130	65	65					
	Shahjibazar 100 MW GTPP	Gas (PDB)				0	0	0	0					
<b>Sylhet Zone Total</b>				<b>2033</b>	<b>1988</b>	<b>1003</b>	<b>940</b>	<b>1265</b>	<b>1265</b>	<b>209</b>	<b>0</b>			
101	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	220	210	410	410					
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25					
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	65	65					
105	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
106	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	66	115	115					
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	100					
108	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	90	90	90					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC )	India		1000	1000	546	783	551	792					
<b>Khulna Zone Total</b>				<b>2288</b>	<b>2284</b>	<b>856</b>	<b>1149</b>	<b>1396</b>	<b>1973</b>	<b>0</b>	<b>0</b>			
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	64	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	20	26	26					
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.		
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	13	21	95	95					
115	Payra 1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	320	520	600	660					
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				17	25	35	35					
	United Payra Power Ltd.	HFO (IPP)				0	0	0	0					
<b>Barishal Zone Total</b>				<b>1054</b>	<b>1054</b>	<b>367</b>	<b>650</b>	<b>866</b>	<b>926</b>	<b>0</b>	<b>194</b>			
116	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40					
120	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	18	18	34	34					
121	Chapanawabaganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	43	95	100	100					
122	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50					
123	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50					
124	Santalar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	33					
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Under maint.		
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	165	174	225	225					
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	377	390	400	400					
129	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
130	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0					
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
132	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	20	100	113	113					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	92	111	113	113					
<b>Rajshahi Zone Total</b>				<b>2193</b>	<b>2183</b>	<b>748</b>	<b>921</b>	<b>1370</b>	<b>1493</b>	<b>381</b>	<b>220</b>			
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	86	85	80	85					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
136	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274		Under maint.		
137	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
138	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	54	113	113	113					
139	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
140	Majpara, Tatalia 8 MW Solar PP (Sympha P)	Solar (IPP)	1 x 8	8	8	3	0	8	0					
<b>Rangpur Zone Total</b>				<b>685</b>	<b>605</b>	<b>143</b>	<b>198</b>	<b>201</b>	<b>198</b>	<b>85</b>	<b>274</b>			
<b>Sub-total: Plants in operation</b>				<b>20595</b>	<b>20104</b>	<b>7160.0</b>	<b>8816</b>	<b>12245</b>	<b>13495</b>	<b>2733</b>	<b>2228</b>			
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>						<b>6833</b>	<b>8413</b>	<b>11685</b>	<b>12878</b>					
<b>(B) Contract expired power plants</b>														
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0					
<b>Gross Total</b>				<b>20595</b>	<b>20104</b>	<b>7160</b>	<b>8816</b>	<b>12245</b>	<b>13495</b>	<b>2733</b>	<b>2228</b>			
<b>(C) Actual data of 15.12.20 (Yesterday) Tuesday :</b>														
01.	Max. Demand (Generation end)	:	8816.00	MW,	at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand (Sub-station end)	:	8413.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	8816.00	MW,	at =	19:00 hrs	Dhaka	3014	3014	0	Mymensingh	674	674	0
04.	Minimum Generation (Generation end)	:	5649.00	MW,	at =	5:00 hrs	Chattogram	953	953	0	Sylhet	318	318	0
05.	Day-peak Generation (Generation end)	:	7160.00	MW,	at =	12:00 hrs	Khulna	1065	1065	0	Barishal	227	227	0
06.	Evening-peak Generation (Generation end)	:	8816.00	MW,	at =	19:00 hrs	Rajshahi	873	873	0	Rangpur	556	556	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Cumilla	733	733	0				
08.	Actual Minimum Generation up to 8:00 hrs.	:	5537.00	MW,	at =	7:00 hrs					<b>Total</b>	<b>8413</b>	<b>8413</b>	<b>0</b>
09.	Generation shortfall at evening peak due to :	:					Fuel cost :		(a) Gas = 114588532	Taka	(c) Coal = 57966059	Taka		
	a) Gas limitation	:	2462	MW				(b) Oil = 290853283	Taka	Total = 463407875		Taka		
	d) Coal supply Limitation	:	85	MW										
	b) Low water level in Kaptai lake	:	186	MW										
	c) Plants under shut down/ maintenance	:	2228	MW										
10.	Total Energy (Generation + India Import)	:	171.17	MKWh			Maximum Temperature in Dhaka was :		24.5° C					
	By Gas = 104.479	MKWh					Export through East-West interconnections :							
	By Coal = 12.657	MKWh	By Hydro =	37.759	MKWh		At evening peak-hour	:	42	MW,	at	19:00 hrs		
	By Solar = 0.255	MKWh		1.108	MKWh		Maximum	:	-85	MW,	at	13:00 hrs		
							Energy	:	0.3255	MKWh				
11.	Total Gas Supplied	:	831.97	MMCFD										
<b>(D) Forecast of 16.12.20 (Today) Wednesday :</b>														
01.	Maximum Demand	:	8000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	13495	MW	(Generation end)	05.	Total Generation	:	155.33	MKWh				
03.	Maximum Shortage	:	-5495	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	27.4° C					

\* Captive Power \*\* Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)  
Deputy Secretary, Generation