

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CAPP Unit-1	PDB	1*210	170	63	1817500	Gas shortage
	Ghorasal Repowered CAPP Unit-2	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	280	7203091	Gas shortage
	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	12	745409	Gas shortage
4	Harpur GTPP	SBU, IPP	2*32	20	0	0	Under maint.
	Harpur 412 MW CAPP	EGCB	1*273+1*139	412	386	8973980	FGMO
	Harpur 360MW CAPP(HPL)	IPP	1*235+1*125	360	242	6238000	Gas shortage
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	225	4724500	Gas shortage
	Meghnaghat 100 MW(LEL)	QRPP	12*8.9	100	75	513600	High Voltage.
10	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage
11	Madangan 102 PP(Summit)	QRPP	6*17	100	64	345240	High Voltage.
12	Madangan 35 MW PP(Summit)	IPP	3*11.68+1*11.3	55	46	409943	High Voltage.
13	Keraniganj 100 MW PP (Powerpa)	QRPP	8*13.45	100	86	1779051	High Voltage.
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	0	257832	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PPI(Dutch Bangla)	QRPP	12*8.9	100	100	872640	
18	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	0	0	Under maint.
19	Gagragar 102 MW PP (Digital Po)	IPP	12*8.924	102	7	37440	High Voltage.
20	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Reserve.
21	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	1050120	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	1289280	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1014917	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	289121	High Voltage.
25	Bostia 108MW PP(CLOP)	IPP	12*8.775+1*9.5	108	0	0	Fuel shortage
26	Summit Power (Madhabadi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	51	1271220	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	17	411800	Engine problem
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	805900	
29	Gazipur 52 MW PP	IPP	6*8.9	52	24	123684	High Voltage.
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	3389780	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.
33	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	100	1186560	High Voltage.
36	Gazipur 100 MW PP	RPCL	100	105	0	0	Reserve.
	Meghnaghat 124 MW PP (OPCL)	IPP	18*5.8	104	104	1857800	
	Manikganj 162MW PP(MPGL)	IPP	9*18	162	17	182380	High Voltage.
	<b>Dhaka area Total</b>			<b>8057</b>	<b>2556</b>	<b>46890988</b>	
37	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	0	0	Reserve.
39	Teknaf 20MW PP (SolarTech)	Teknaf SolarTech Energy	20	20	0	109215	
40	Paterga 50MW PP (Baraka)	IPP	8*6.88	50	50	921600	
41	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	49	1161949	Unit-2 under maint
42	Sikalbaha 225MW	PDB	1*150+1*175	225	162	3820977	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
44	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	0	0	Reserve.
45	Hatthazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
46	Dahazari-Kalash 100 MW Peaking	IPP	6*17	102	102	369157	
47	Judidah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	22080	High Voltage.
48	Judidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	193200	
49	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	445536	
*	Malancha, Ctg, EPZ (United)		5*8.73+3*9.34	0	25	594240	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	51	191040	High Voltage.
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	23160	
52	Anwara 300 MW Solar PP (United)	IPP	300 MW	300	253	4458836	Transformer OIL
53	Jodiad Power	IPP	3*18.55+1*3.6	54	54	1301725	
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
	Judidah unit-2 (Acorn)	IPP	8*13.6	100	60	1190400	High Voltage.
	Anlima Energy Ltd.	IPP	6*21.2	0	0	124200	
	<b>Chattogram area Total</b>			<b>2266</b>	<b>935</b>	<b>16895715</b>	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	80	860082	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	150	2849760	
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
56	Ashuganj 225 MW CAPP	APSCL	1*142+1*75	221	0	1186000	Under maint.
57	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	0	0	Under maint.
58	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	290	7597000	Gas shortage
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	566776	Gas shortage
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	53	1010880	
62	Ashuganj 195MW APSCL-Unit	IPP	20*9.73+1*116	195	16	36127	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1224706	
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	142	2117672	
66	Tilas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
67	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	50	1157600	ST under maint.
68	Chandpur 200MW (Desh energy)	IPP	0	200	68	1025280	High Voltage.
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	16	367936	Engine problem
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	167380	
**	Impoport (Tripura)	Imported power	0	160	104	1925760	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	617000	
72	Jangalia 52 MW PP (Lakdanav)	IPP	6*8.92	52	24	168250	High Voltage.
73	Kumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	22	524810	
74	Daudkarna 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	34	1252860	High Voltage.
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	35	268800	High Voltage.
	<b>Cumilla Area Total</b>			<b>2980</b>	<b>1207</b>	<b>25222279</b>	
75	RPCL 210MW CAPP	IPP	4*35+1*70	202	106	2487080	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	432540	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	83	663360	High Voltage.
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10350	
79	Mymensingh 200 MW PP (United)	IPP	200	200	24	1512000	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2371200	#REF!
	Sulakhal 50 MW Solar PP	IPP	50	50	0	235610	
	Tangail Pali Power Gen 22 MW	SIPP	4*6.7	0	0	0	
	<b>Mymensingh Area Total</b>			<b>687</b>	<b>348</b>	<b>6351340</b>	
81	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	20	175000	Gas shortage & GT-2 under r
82	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	32	654960	GT-4 under maint.
83	Kushihara 163 MW CAPP (KP)	IPP	1*109+1*54	140	140	3419263	Frequency control
84	Shajbazar 330 MW CAPP	PDB	3*110	330	155	3589000	Gas shortage & GT-2 under r
85	Fenchugonj 51 MW PP (Barakata)	RPP	19*2.90	51	14	550800	High Voltage.
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	47	933984	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	8	136000	Engine problem
88	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	32	781920	Unit-9 under maint.
89	Shahjibazar 60MW PP (Shahjibaz)	RPP	32*2.90	86	74	1600320	Engine problem
90	Shahjibazar 100 MW GTPP	PDB	1*100	0	0	0	On test.
91	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	176	4328920	
92	Sylhet 20 MW GTPP	PDB	1*20	20	18	441000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	346008	Engine problem
95	Bibiana-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	0	0	Under maint.
96	Biyaniara 400 MW CAPP	PDB	400 MW	400	270	5221000	Gas shortage
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	0	0	Engine problem
	Biyaniara South 400 MW	PDB	400 MW	0	25	505200	
	<b>Sylhet Area Total</b>			<b>1988</b>	<b>1027</b>	<b>22692375</b>	
98	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	801	13281456	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	49	224640	High Voltage.
100	Fairpur 50 MW Peaking PP	PDB	8*6.89	50	0	0	Reserve.
101	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
102	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	0	Reserve.
103	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	120	4769280	Gas shortage
104	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	0	329625	Reserve.
105	Noapara 100 MW PP (Bangla Tra)	IPP	70*1.4	100	0	0	Reserve.
106	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	80	1351680	Engine problem
107	Mochmuri 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
	<b>Khulna Area Total</b>			<b>2284</b>	<b>1060</b>	<b>19956681</b>	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	64	547584	High Voltage.
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	26	483700	Engine problem
111	Bhola 225 MW CAPP	PDB	2*63+1*68	194	0	0	Under maint.
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	10	251427	Gas shortage
	Payra 1320 MW	BCPCL	1*622	622	540	11851300	Line OIL
	Bhola Nutan Badui BD LTD	IPP	220	0	36	821440	On test
	United Payra Power Ltd.	IPP	8*18.5+1*9.5	0	0	0	On test.
	<b>Barisal Area Total</b>			<b>1054</b>	<b>676</b>	<b>13944451</b>	
113	Baghabari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage.
	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	8	19226	Low demand
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
116	Amnura 50 MW PP(Sinha)</						