

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month December, 2020				Day : Saturday				Date : 26.12.20			
Probable Maximum Demand :		8800 MW		Probable Maximum Generation : 13673 MW				Rule Curve = 103.70 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 98.62 ft				Today = 98.54 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.12.20 (Yesterday)		26.12.20 (Today)		25.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Power Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		Under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	94	94	94	94	76	Gas Shortage
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	STG Commissioning
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	330	330	330		
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	100	100		
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	294	357	360	360		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	370	375	412	412		
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	50	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305	Gas Shortage
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	2	65	100	100		
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	15	100	100		
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	55	55		
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	36	60	85	85		
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	0	100	100		
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	16	16	16		
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	37	57	58	58		
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	14	17	17		
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52		
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105		
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	48	150	150		
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50		
28	Kamalaghat 54 MW PP (Banos Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	34	145	300	300		
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	24	149	149		
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300		
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1.959	100	100	0	0	50	100		
33	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1.959	100	100	0	0	60	100		
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	0	55	55		
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	85	104	104	104		
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	100	160		
<b>Dhaka Zone Total</b>				<b>6281</b>	<b>6057</b>	<b>1705</b>	<b>2148</b>	<b>3569</b>	<b>3919</b>	<b>1019</b>	<b>905</b>
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	44	47	49	49	183	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
42	Raazan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25		
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	25	50	50		
45	Sikalbaha 105 MW PP (Baraka Sik)	HFO (IPP)	6x18.415	105	105	0	0	100	100		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Gas Shortage
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	163	100	160	160	125	Gas Shortage
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	159	106	300	300		
49	Julda 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
50	Julda 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	60	100	100		
51	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	100	100		
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			23	42	25	35		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	102	102		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	52	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	12	110	110		
57	Julda unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	60	30	100	100		
	Anilma Energy Ltd.	HFO (IPP)				0	0	0	0		
<b>Chattogram Zone Total</b>				<b>2326</b>	<b>2266</b>	<b>680</b>	<b>512</b>	<b>1419</b>	<b>1404</b>	<b>638</b>	<b>180</b>
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	80	120	120	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	100	100	100	100		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	0	0	0	0		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	260	320	360	360		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Under maint.
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	54	55	55		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	16	8	12	12	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	57	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	77	138	150	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	45	51	50	50		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	50	85	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	25	33		
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	22	20	22		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x1.4+4x1.515+15x1.05	200	200	0	0	0	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	113	113		
**	Import (Tijpara)	India		160	160	52	96	140	149		
<b>Cumilla Zone Total</b>				<b>3040</b>	<b>2980</b>	<b>888</b>	<b>1093</b>	<b>1608</b>	<b>1877</b>	<b>376</b>	<b>360</b>
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	109	130	130	130	72	Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	91	95	95		
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	65	115	115	115		
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	0	200	200		
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	2	0	1.6	0		
84	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0		
	Tangail 22 MW PP(Pali Power Gen	HFO (SIPP)				0	0	0	0		
<b>Mymensing Zone Total</b>				<b>695</b>	<b>687</b>	<b>243</b>	<b>356</b>	<b>612</b>	<b>560</b>	<b>72</b>	<b>0</b>

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.12.20 (Yesterday)		26.12.20 (Today)		25.12.20 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening					
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30					
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	32	32	30	30					
87	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	8	8	51	51					
88	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	5	5	44	44					
89	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	130	163	163					
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11					
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	33	33	33					
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+2x110	330	330	161	155	158	158	175		Gas Shortage		
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	75	86	86					
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	182	150	215	215					
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	0	20	20					
96	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	16	16					
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	15	120	320	320					
100	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	250	80	0	0	320		Gas Shortage		
	Bibiyana South 400 MW	Gas (PDB)				50	300	300	300					
	Shahjibazar 100 MW GTPP	Gas (PDB)				0	0	100	100					
<b>Sylhet Zone Total</b>						<b>2033</b>	<b>1988</b>	<b>956</b>	<b>1129</b>	<b>1577</b>	<b>495</b>	<b>0</b>		
101	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
102	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	200	235	300	300	175		Gas Shortage		
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	50	50	0	0	35	35					
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70					
105	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
106	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	16	115	115					
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0					
108	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	90	90	90					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	416	559	579	819					
<b>Khulna Zone Total</b>						<b>2288</b>	<b>2284</b>	<b>669</b>	<b>900</b>	<b>1329</b>	<b>1805</b>	<b>175</b>	<b>0</b>	
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	26	25	25					
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.		
114	Bhola 95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	11	10	10	10					
115	Payra 1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	400	530	600	660					
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				14	36	35	35					
	United Payra Power Ltd.	HFO (IPP)				0	0	0	0					
<b>Barishal Zone Total</b>						<b>1054</b>	<b>1054</b>	<b>440</b>	<b>650</b>	<b>780</b>	<b>840</b>	<b>0</b>	<b>194</b>	
116	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40					
120	Amnura 50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	0	35	35					
121	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	61	100	100					
122	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50					
123	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50					
124	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34					
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	180	180	220	220					
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	295	431	400	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
130	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0					
131	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	9	11	11	11					
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	0	35	113	113					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	90	109	113	113					
<b>Rajshahi Zone Total</b>						<b>2193</b>	<b>2183</b>	<b>596</b>	<b>849</b>	<b>1366</b>	<b>1490</b>	<b>601</b>	<b>0</b>	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	67	65	88	88					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
136	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274		Under maint.		
137	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
138	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	113	113	113					
139	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
140	Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
<b>Rangpur Zone Total</b>						<b>685</b>	<b>605</b>	<b>71</b>	<b>178</b>	<b>209</b>	<b>201</b>	<b>85</b>	<b>274</b>	
<b>Sub-total: Plants in operation</b>						<b>20595</b>	<b>20104</b>	<b>6248.0</b>	<b>7815</b>	<b>12469</b>	<b>13673</b>	<b>3461</b>	<b>1913</b>	
<b>Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss</b>						<b>5890</b>	<b>7367</b>	<b>11754</b>	<b>12889</b>					
<b>(B) Contract expired power plants</b>														
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0			
<b>Gross Total</b>						<b>20595</b>	<b>20104</b>	<b>6248</b>	<b>7815</b>	<b>12469</b>	<b>13673</b>	<b>3461</b>	<b>1913</b>	
<b>(C) Actual data of 25.12.20 (Yesterday) Friday :</b>														
01.	Max. Demand (Generation end)	: 7815.00 MW, at = 20:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand (Sub-station end)	: 7367.00 MW, at = 20:00 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	: 7815.00 MW, at = 20:00 hrs		Dhaka	2396	2396	0	Mymensingh	660	660	0			
04.	Minimum Generation (Generation end)	: 5614.00 MW, at = 5:00 hrs		Chattogram	815	815	0	Sylhet	292	292	0			
05.	Day-peak Generation (Generation end)	: 6248.00 MW, at = 12:00 hrs		Khulna	977	977	0	Barishal	227	227	0			
06.	Evening-peak Generation (Generation end)	: 7815.00 MW, at = 20:00 hrs		Rajshahi	793	793	0	Rangpur	525	525	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 20:00 hrs		Cumilla	682	682	0							
08.	Actual Minimum Generation up to 8:00 hrs.	: 5081.00 MW, at = 7:00 hrs an		<b>Total 7367</b>									<b>7367</b>	<b>0</b>
09.	Generation shortfall at evening peak due to :													
	a) Gas limitation	: 3193 MW		13. Fuel cost : (a) Gas = 116386220 Taka (c) Coal = 57394162 Taka										
	d) Coal supply Limitation	: 85 MW		(b) Oil = 251624499 Taka Total = 425404861 Taka										
	b) Low water level in Kaptai lake	: 183 MW		14. Maximum Temperature in Dhaka was : 26.7° C										
	c) Plants under shut down/ maintenance	: 1913 MW		15. Export through East-West interconnections :										
10.	Total Energy (Generation + India Import)	: 162.32 MKWh		At evening peak-hour : -75 MW, at 20:00 hrs										
	By Gas = 104.325 MKWh	By Hydro = 32.602 MKWh		Maximum : -212 MW, at 18:00 hrs										
	By Coal = 12.455 MKWh	By Solar = 0.457 MKWh		Energy : 1.0835 MKWh										
11.	Total Gas Supplied	: 840.91 MWh												
<b>(D) Forecast of 26.12.20 (Today) Saturday :</b>														
01.	Maximum Demand	: 8800 MW (Generation end)		04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 13673 MW (Generation end)		05. Total Generation : 182.78 MKWh										
03.	Maximum Shortage	: -4873 MW (Generation end)		06. Probable Max. Temperature in Dhaka : 25.3° C										

\* Captive Power \*\* Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazoul Islam Shaker)  
Deputy Secretary, Generation