

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
 Tel: 9564667, 9551095

Month December, 2020				Day: Thursday				Date: 31.12.20				
Probable Maximum Demand: 9000 MW				Probable Maximum Generation: 12866 MW				Rule Curve = 103.20 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 98.27 ft.				Today = 98.21 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.12.20 (Yesterday)		31.12.20 (Today)		30.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Power Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0	85	Under maint.	
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Gas Shortage	
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	STG Commissioning	
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.	
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	330	300	300			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	11	12	12	12			
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	255	274	360	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	327	396	412	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.	
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305	Gas Shortage	
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	68	93	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	70	78	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	2	15	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	80	100	100	100			
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	32	16	100	100			
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	16	19	19			
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	48	57	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	17	17			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	52	52	52			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	105	105			
26	Kodda 150MW PP	HFO (BPD-B RPCL)	9x17.06	149	149	0	150	150	150			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50			
28	Kamalaghat 54 MW PP (Banos Energy)	HFO (IPP)	3x18.69	54	54	17	35	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	270	300	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	79	125	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1.959	100	100	0	0	50	100			
33	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1.959	100	100	0	0	60	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	25	35	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	55	55			
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	90	104	104			
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
Dhaka Zone Total				6281	6057	2130	2851	3437	3697	1113	905	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	47	45	45	45	185	Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	45	50	50	50			
45	Sikalbaha 105 MW PP (Baraka Sik)	HFO (IPP)	6x18.415	105	105	0	0	100	100			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Gas Shortage	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	164	163	0	0	62	Gas Shortage	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	216	215	300	300			
49	Julda 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	10	100	100			
50	Julda 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	70	100	100	100			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	100	100			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	12	10	20			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	30	102	102			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Julda unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
	Anlima Energy Ltd.	HFO (IPP)				38	0	0	0			
Chattogram Zone Total				2326	2266	780	891	1240	1225	577	180	
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	140	70	135	135	65	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	5	26	26			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	201	184	221	221			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	95	273	260	260	87	Under maint.	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	56	5	5	5	50	Gas Shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	8	8	8	187	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	148	150	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	51	45	50	50			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	100	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	20	22			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.05	200	200	0	0	0	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	18	18	113	113			
**	Impoort (Tijpara)	India		160	160	74	100	110	148			
Cumilla Zone Total				3040	2980	1027	1093	1568	1858	565	87	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	86	106	110	149	96	Gas Shortage	
79	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	24	56	95	95			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	8	115	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	165	200	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	2	0	1.6	0			
84	Sutiali 60 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0			
	Tangal 22 MW PP(Pali Power Gen	HFO (SIPP)				26	26	22	22			
Mymensingh Zone Total				695	687	363	416	614	601	96	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.12.20 (Yesterday)		31.12.20 (Today)		30.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
85	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	20	20	30	30			
86	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	22	22	30	30			
87	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	5	8	51	51			
88	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	5	20	44	44			
89	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			
90	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
91	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	33	33	33			
92	Shajibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	145	143	155	155	187		Gas Shortage
93	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	67	69	86	86			
94	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	137	176	200	200			
95	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	20	20			
96	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			
97	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0			
98	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	16	16			
99	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	220	260	320	320			
100	Bibiyana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Gas Shortage
		Bibiyana South	400 MW	Gas (PDB)			417	435	420	435			
		Shahjibazar	100 MW GTTP	Gas (PDB)			0	0	100	100			
		Sylhet Zone Total			2033	1988	1069	1197	1516	1531	587	0	
101	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16			
102	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	200	175	270	270	235		Gas Shortage
103	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	35	35			
104	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70			
105	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220			
106	Khulna	115 PP MW (KPC-2)	HFO (QRPP)	7x17	115	115	0	115	115	115			
107	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100			
108	Noapara	40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	24	40	40			
109	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	60	90	90			
110	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	52	100	100			
**	Bheramara (HVDC)	India		1000	1000		572	813	589	830			
		Khulna Zone Total			2288	2284	862	1239	1359	1886	235	0	
111	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110			
112	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	25	25	25			
113	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.
114	Bhola	95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	72	90	90	90			
115	Payra	1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	0	0	0	0			
		Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				17	34	35	35			
		United Payra Power Ltd.	HFO (IPP)				19	55	55	55			
		Barishal Zone Total			1054	1054	126	220	315	315	0	194	
116	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
117		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50			
118		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
119		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40			
120		Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	35	35			
121		Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	52	94	100	100			
122		Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	50			
123		Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	50			
124		Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34			
125		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			Gas Shortage
126		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage
127		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	150	130	220	220			
128		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	383	313	400	400			
129		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
130		Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			
131		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
132		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	25	52	52			
133		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113			
134		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	92	111	113	113			
		Rajshahi Zone Total			2193	2183	817	819	1366	1490	601	0	
135	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
136		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	150	150	150	124		Under maint.
137		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
138		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	40	35	113	113			
139		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
140		Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	4	0	8	0			
		Rangpur Zone Total			685	605	193	185	271	263	85	124	
		Sub-total: Plants in operation			20595	20104	7367.0	8911	11686	12866	3859	1490	
		Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss					6886	8329	10922	12026			
(B) Contract expired power plants													
		Sub-Total: Plants under long term maintenance			0	0	0	0	0	0			
		Gross Total			20595	20104	7367	8911	11686	12866	3859	1490	
(C) Actual data of 30.12.20 (Yesterday) Wednesday :													
01.	Max. Demand (Generation end) :			8911.00 MW, at = 19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand (Sub-station end) :			8329.00 MW, at = 19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end) :			8911.00 MW, at = 19:00 hrs	Dhaka	2960	2960	0	Mymensingh	699	699	0	
04.	Minimum Generation (Generation end) :			5616.00 MW, at = 5:00 hrs	Chattogram	876	876	0	Sylhet	311	311	0	
05.	Day-peak Generation (Generation end) :			7367.00 MW, at = 12:00 hrs	Khulna	1078	1078	0	Barishal	236	236	0	
06.	Evening-peak Generation (Generation end) :			8911.00 MW, at = 19:00 hrs	Rajshahi	873	873	0	Rangpur	575	575	0	
07.	Evening Peak Load-shed (Sub-station end) :			0.00 MW, at = 19:00 hrs	Cumilla	721	721	0					
08.	Actual Minimum Generation up to 8:00 hrs. :			5571.00 MW, at = 7:00 hrs					Total	8329	8329	0	
09.	Generation shortfall at evening peak due to :				13.	Fuel cost :	(a) Gas = 104921644 Taka	(c) Coal = 19907118 Taka					
	a) Gas limitation :			3589 MW		(b) Oil = 328350054 Taka	Total = 453178817 Taka						
	d) Coal supply Limitation :			85 MW									
	b) Low water level in Kaptai lake :			185 MW									
	c) Plants under shut down/ maintenance :			1490 MW	14.	Maximum Temperature in Dhaka was :	26.6° C						
10.	Total Energy (Generation + India Import) :			171.94 MKWh	15.	Export through East-West interconnections :							
	By Gas = 103.183 MKWh			47.940 MKWh		At evening peak-hour :	-512 MW, at 19:00 hrs						
	By Coal = 3.673 MKWh			1.092 MKWh		Maximum :	-512 MW, at 19:00 hrs						
	By Solar = 0.454 MKWh					Energy :	4.33 MKWh						
11.	Total Gas Supplied :			792.18 MMCFD									
(D) Forecast of 31.12.20 (Today) Thursday :													
01.	Maximum Demand :			9000 MW (Generation end)	04.	Maximum Load-shed :			0 MW At evening peak (Sub-station end)				
02.	Maximum Generation :			12866 MW (Generation end)	05.	Total Generation :			173.66 MKWh				
03.	Maximum Shortage :			-3866 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :			26.0° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation