

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 4-Jan-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2'95	185	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CCPP Unit-1	PDB	1'210	170	0	0	Gas shortage
	Ghorasal Repowered CCPP Unit-2	PDB	1'210	180	0	3936000	Gas shortage
	Ghorasal TPP Unit-5	PDB	1'210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	330	6932845	
3	Ghorasal 78.5 MW PP (MAX)	QRPP	2'40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	0	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	373	8759392	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	354	7416000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	0	0	Under maint.
9	Meghnaghat 100 MW(EL)	QRPP	12'8.9	100	75	381680	High Voltage.
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	305	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6'17	100	70	833520	High Voltage.
12	Madanganj 55 MW PP(Summit)	IPP	3'117.08+1'11.3	55	15	225129	Low demand
13	Karaniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	85	1014385	High Voltage.
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	447480	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	100	361920	
18	Siddhirgonj 305 MW CCPP	EGCB	1'211+118	335	0	0	Under maint.
19	Gagnagar 102 MW PP (Digital Po)	IPP	12'8.924	102	50	588384	High Voltage.
20	Kapoti 52 MW PP (Sinha)	IPP	7'7.9	51	0	0	Reserve.
21	Kamalaghat 54 MW PP(Banco En)	IPP	3'18	54	17	371520	Low demand
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	115	306720	High Voltage.
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	106892	Low demand
24	Nabaganj 55 MW PP (Southern)	IPP	3'19.3	55	35	525374	Low demand
25	Bosila 108MW PP(PLC)	IPP	12'8.775+1'3.5	108	0	0	Fuel shortage
26	Summit Power (Madhabadi-Ashuli)	SIPP, REB	3'3.67+4'8.73	80	57	1305600	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	504700	Engine problem
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	16	581700	Engine problem
29	Gazipur 52 MW PP	IPP	6'8.9	52	24	59424	Low demand
30	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	291	3301962	
32	Karaniganj 300 MW PP (APR)	IPP	256'1.4	300	0	100193	Reserve.
33	Bramhangaoan 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve.
34	Aurahi 100MW PP (Aggreko)	IPP	0.85'23+0.85'91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	123	1415950	High Voltage.
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	930168	
37	Meghnaghat 149 MW PP (QPCL)	IPP	18'3.5	149	90	892320	Engine problem
38	Manikganj 182MW PP(MPGL)	IPP	9'18	182	55	1324800	Low demand
<b>Dhaka area Total</b>				<b>6057</b>	<b>2459</b>	<b>42694058</b>	
39	Chattogram TPP-1	PDB	1'210	180	0	0	Gas shortage.
40	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage.
41	Raozan 25 MW PP	IPP	3'8.9	25	25	85937	
42	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energ	20	20	0	110025	
43	Patena 50MW PP (Baraka Si)	IPP	8'8.98	50	50	613650	
44	Kapali Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	35	848000	Unit-2 under maint
45	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Gas shortage
47	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	0	0	Reserve.
48	Hafazari 100 MW peaking PP	PDB	11'8.9	98	0	0	Under maint.
49	Dohazari-Kaleshi 100 MW Peaki	IPP	6'117	102	85	218182	Low demand
50	Juidah 100 MW Unit-1 (Acom)	QRPP	8'13.45	100	10	15720	Low demand
51	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	1159680	
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	19	436848	Machine problem
53	Malancha, Ctg. EPZ (United)	IPP	5'8.73+3'9.34	0	25	591360	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	51	83520	High Voltage.
55	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	14726	
56	Anwara 300 MW PP (United)	IPP	300 MW	300	198	3088891	Low demand
57	Jodac Power	IPP	3'18.55+1'3.6	54	54	1227660	
58	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
59	Juidah unit-2 (Acom)	IPP	8'13.6	100	100	2215680	
60	Anilima Energy Ltd.	IPP	6'21.2	0	0	0	RRT
<b>Chattogram area Total</b>				<b>2266</b>	<b>752</b>	<b>10709929</b>	
61	Ashuganj TPP Unit- 3	APSCL	1'150	135	0	49430	Gas shortage
62	Ashuganj TPP Unit-4	APSCL	1'150	129	0	0	Gas shortage
63	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	Gas shortage
64	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	183	4479000	FGMO
65	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	0	3946700	Gas shortage
66	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	310	7538000	
67	Ashuganj 50 MW PP	APSCL	14'3.968	45	26	298944	Gas shortage
68	Ashuganj 55 MW PP (Precision)	RPP	15.4	55	49	452160	Gas shortage
69	Ashuganj 185MW PP (APSCL-Unit-8 & 9)	IPP	20'8.73+1'116	195	36	434981	Gas shortage
70	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1211642	
71	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	102	2085890	
72	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	0	Reserve.
73	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	80	882700	Under maint.
74	Chandpur 200MW (Desh energy)	IPP	0	200	50	1155220	High Voltage.
75	Feni 22MW (Doreen)	SIPP, PDB	8'2.90	22	18	428832	Engine problem
76	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	257580	
77	Imporrt (Tripura)	Imported power	0	160	106	2031360	
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	808600	
79	Jangalia 52 MW PP (Lakdanav)	IPP	6'8.92	52	0	0	Low demand
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	21	488530	
81	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Reserve.
82	Feni Lanka Power Ltd	IPP	7'18.415+1'9.78	114	0	0	Reserve.
83	Chowmahani 113 MW	IPP	12'9.78+2'3.1	113	18	525840	Low demand
<b>Cumilla Area Total</b>				<b>2980</b>	<b>1094</b>	<b>27045637</b>	
84	RPCL 210MW CCPP	IPP	4'35+1'70	202	107	2502440	Gas shortage
85	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	495468	
86	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	40	248640	High Voltage.
87	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	11150	
88	Mymensingh 200 MW PP (United)	IPP	200	200	200	2988000	High Voltage.
89	Jamalpur 115 MW PP (United)	IPP	115 MW	115	8	40800	#REF!
90	Sutakhal 50 MW Solar PP	IPP	50	50	0	240890	
91	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	24	209760	
<b>Mymensingh Area Total</b>				<b>709</b>	<b>399</b>	<b>6737148</b>	
92	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	30	716000	Gas shortage & GT-2 under r
93	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	80	20	475440	GT-4 under maint.
94	Koshiara 163 MW PP (IFP)	IPP	1'108+1'54	163	0	0	Line OIL
95	Shahjibazar 330 MW CCPP	PDB	3'110	330	143	3281000	Gas shortage & GT-2 under
96	Fenchugonj 51 MW PP (Barakati)	RPP	19'2.90	51	5	217200	
97	Fenchugonj 44MW (Energyprima)	RPP	12'3.3+5'2	44	5	230184	
98	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	174500	
99	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	33	664896	Unit-9 under maint.
100	Shahjibazar 50MW PP (Shahjibaz)	RPP	32'2.90	86	71	1431360	Engine problem
101	Shahjibazar 100 MW GTPP	PDB	1'100	0	0	0	On test.
102	Sylhet 225 MW CCPP	PDB	1'142+1'189	231	163	3278160	
103	Sylhet 20 MW GTPP	PDB	1'20	20	0	0	Gas shortage
104	Sylhet 50MW PP (EPL)	RPP	27'2	50	0	0	Contract Expired
105	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	0	0	Engine problem
106	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	280	6839000	Gas shortage
107	Bibiana-III 400 MW CCPP	PDB	400 MW	400	0	0	Gas shortage & Bibiyana sou
108	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	0	55800	Engine problem
109	Bibiyana South 400 MW	PDB	400 MW	0	425	9151100	On test
<b>Sylhet Area Total</b>				<b>1988</b>	<b>1186</b>	<b>26514640</b>	
110	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Reserve.
111	Bheramara (HVDC)	Imported power	2'500	1000	817	14273131	
112	Khulna 115 PP MW (KPCL-2)	QRPP	7'17	115	99	1547520	Low demand
113	Fairpur 50 MW Peaking PP	PDB	8'8.89	54	0	0	Reserve.
114	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	0	Reserve.
115	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	6	24704	Low demand
116	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	220	5670720	Gas shortage
117	Noapara 40 MW PP (Khanjahan A)	QRPP	5'8.5	40	0	280875	Reserve.
118	Noapara 100 MW PP (Bangla Tr)	IPP	70'1.4	100	0	74880	Reserve.
119	Rupsha 105 MW PP (Orion rupsh)	IPP	8'18.445	105	84	983280	Engine problem
120	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
<b>Khulna Area Total</b>				<b>2284</b>	<b>1226</b>	<b>22861110</b>	
121	Barisal 110 MW PP (Summit I)	IPP	7'17.076	110	0	0	High Voltage.
122	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	21	401100	Engine problem
123	Bhola 225 MW CCPP	PDB	2'63+1'68	194	0	0	Under maint.
124	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	64	1054178	High Voltage.
125	Payra 1320 MW	BCRCL	2'622	1244	500	10230500	High Voltage.
126	Bhola Nutan Biktut BD LTD	IPP	2'20	0	0	444736	On test.
127	United Payra Power Ltd.	IPP	8'18.5+1'9.5	0	54	638400	On test.
<b>Barisal Area Total</b>				<b>1676</b>	<b>639</b>	<b>12829014</b>	
128	Baghabari 71 MW GTPP	PDB	1'71	71	0	0	Gas shortage.
129	Baghabari 100 MW GTPP	PDB	1'100	100	0	0	Gas shortage.
130	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	0	2016	Reserve.
131	Bara 70 MW Peaking PP	PDB	9'8.29	71	0	0	Reserve.
132	Amnara 50 MW PP (Sinha)	QRPP					