

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month January, 2021				Day : Wednesday				Date : 13.01.21				
Probable Maximum Demand :			9500 MW		Probable Maximum Generation :				12836 MW			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.47 ft		Today = 97.41 ft		Rule Curve = 100.72 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.01.21 (Yesterday)		13.01.21 (Today)		12.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Power Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
<b>(A) Plants in operation:</b>												
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under maint.
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110			
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	370	365	360	360			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	223	195	230	230			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Under maint.
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	365	355	412	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	15	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305		Gas Shortage
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	100	100	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	80	80	64	84			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	0	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	83	73	100	100			
19	Gagnagar 102 MW PP (Digital Powe)	HFO (IPP)	12x8.924	102	102	24	102	100	100			
20	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22			
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	52	57	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	52	52	52			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	78	105	105			
26	Kodda 150MW PP	HFO (BPD- RPCL)	9x17.06	149	149	64	150	149	149			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50			
28	Kamalaghat 54 MW PP (Banos Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	285	291	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	73	128	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	35	37			
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	81	90	90			
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	101	90	90			
<b>Dhaka Zone Total</b>				<b>6281</b>	<b>6057</b>	<b>2116</b>	<b>2639</b>	<b>3108</b>	<b>3420</b>	<b>1276</b>	<b>885</b>	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	48	46	46	46	184		Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	0	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	46	50	50	50			
45	Sikalbaha 105 MW PP (Baraka Sike)	HFO (IPP)	6x18.415	105	105	0	0	0	100			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Gas Shortage
48	Anwara 300 MW PP (Uniled)	HFO (IPP)	17x17.076+ 3x8.04	300	300	180	160	300	300			
49	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	30	20	100	100			
50	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17			
*	Malancha, Ctg EPZ (Uniled)	Gas	5x8.73+3x9.34			3	22	10	20			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	40	90	93			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0			
<b>Chattogram Zone Total</b>				<b>2326</b>	<b>2266</b>	<b>598</b>	<b>736</b>	<b>1104</b>	<b>1217</b>	<b>739</b>	<b>180</b>	
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	5	5			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	150	177	225	225			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	250	230	360	360			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	250	250	360	360			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50		Gas shortage
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	120	118	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	33	31	0	0			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	100	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	32	33	33			
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	32	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	22	22	20	22			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+4x0.15+15x1.05	200	200	0	0	0	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	113	113	113			
**	Impoort (Tripura)	India		160	160	86	108	134	146			
<b>Cumilla Zone Total</b>				<b>3040</b>	<b>2980</b>	<b>1108</b>	<b>1326</b>	<b>1851</b>	<b>2115</b>	<b>635</b>	<b>0</b>	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	106	105	120	120	97		Gas Shortage
79	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	91	95	95			
81	Jamalpur 115 MW PP (Uniled)	HFO (IPP)	12x9.87	115	115	55	75	115	115			
82	Mymensingh 200 MW PP (Uniled)	HFO (IPP)	21x9.780	200	200	200	200	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
84	Sutiahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	7	0	50	0			
85	Tangal 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	24</						

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.01.21 (Yesterday)		13.01.21 (Today)		12.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30				
87	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	32	22	22				
88	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	14	50	51	51				
89	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	10	50	44	44				
90	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	140	163	163				
91	Hobiganj	11MW PP Cofidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	40	40	40				
93	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	0	0	0	0	330		Under maint.	25/01/2021
94	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	68	73	70	70				
95	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
96	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	19	19	20	20				
97	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0				
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	9	9				
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8				
100	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	285	330	330				
101	Bibiyana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Gas Shortage	
	Bibiyana South	400 MW	Gas (PDB)				280	120	270	270				
	Shahjibazar	100 MW GTTP	Gas (PDB)				100	100	0	0			On Test	
<b>Sylhet Zone Total</b>					<b>2033</b>	<b>1988</b>	<b>1067</b>	<b>967</b>	<b>1068</b>	<b>1068</b>	<b>400</b>	<b>330</b>		
102	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
103	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	150	140	140	260		Gas Shortage	
104	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	5	5	35	35				
105	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70				
106	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
107	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	115	115	115	115				
108	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	50	100				
109	Noapara	40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40				
110	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	90	90				
111	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India			1000	1000	681	821	695	840				
<b>Khulna Zone Total</b>					<b>2288</b>	<b>2284</b>	<b>978</b>	<b>1198</b>	<b>1335</b>	<b>1766</b>	<b>260</b>	<b>0</b>		
112	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110				
113	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	27	24	27				
114	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.	
115	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	32	82	80	80				
116	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	360	460	600	600				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)					19	56	50	56				
	United Payra Power Ltd.	HFO (IPP)					45	45	54	54				
<b>Barishal Zone Total</b>					<b>1676</b>	<b>1676</b>	<b>471</b>	<b>702</b>	<b>918</b>	<b>927</b>	<b>0</b>	<b>194</b>		
117	a) Baghabari	71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari	100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
118	Baghabari	50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	0	50				
119	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
121	Ammura	50 MW PP (Siraha)	HFO (QRPP)	7x7.79	50	50	0	25	25	25				
122	Chapainawabganj	100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	102	104	104				
123	Katakhali	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
124	Katakhali	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
125	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34				
126	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	151	133	220	220				
129	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	380	330	400	400				
130	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
131	Bogra	20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0				
132	Ullapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
133	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	16	52	52				
134	Bagura	113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	70	113	113	113				
135	Bagura	113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113				
<b>Rajshahi Zone Total</b>					<b>2193</b>	<b>2183</b>	<b>694</b>	<b>905</b>	<b>1360</b>	<b>1484</b>	<b>601</b>	<b>0</b>		
136	a) Barapukuria	TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria	TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
137	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150				
138	Rangpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	70	107	113	113				
140	Saidpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Tatulia	8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	1	0	8	0				
<b>Rangpur Zone Total</b>					<b>685</b>	<b>605</b>	<b>221</b>	<b>257</b>	<b>271</b>	<b>263</b>	<b>170</b>	<b>0</b>		
<b>Sub-total: Plants in operation</b>					<b>21239</b>	<b>20748</b>	<b>7666.0</b>	<b>9245</b>	<b>11643</b>	<b>12836</b>	<b>4178</b>	<b>1589</b>		
<b>Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss</b>							<b>7346</b>	<b>8859</b>	<b>11156</b>	<b>12300</b>				
<b>(B) Contract expired power plants</b>														
Sub-Total: Plants under long term maintenance					0	0	0	0	0	0				
<b>Gross Total</b>					<b>21239</b>	<b>20748</b>	<b>7666</b>	<b>9245</b>	<b>11643</b>	<b>12836</b>	<b>4178</b>	<b>1589</b>		
<b>(C) Actual data of 12.01.21 (Yesterday) Tuesday :</b>														
01.	Max. Demand (Generation end) :			9245.00 MW, at = 19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand (Sub-station end) :			8859.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end) :			9245.00 MW, at = 19:00 hrs	Dhaka	3125	3125	0	Mymensingh	765	765	0		
04.	Minimum Generation (Generation end) :			5981.00 MW, at = 5:00 hrs	Chattogram	997	997	0	Sylhet	335	335	0		
05.	Day-peak Generation (Generation end) :			7666.00 MW, at = 12:00 hrs	Khulna	1099	1099	0	Barishal	232	232	0		
06.	Evening-peak Generation (Generation end) :			9245.00 MW, at = 19:00 hrs	Rajshahi	939	939	0	Rangpur	604	604	0		
07.	Evening Peak Load-shed (Sub-station end) :			0.00 MW, at = 19:00 hrs	Cumilla	763	763	0						
08.	Actual Minimum Generation up to 8:00 hrs. :			5886.00 MW, at = 7:00 hrs										
09.	Generation shortfall at evening peak due to :													
	a) Gas limitation	: 3824 MW												
	d) Coal supply Limitation	: 170 MW												
	b) Low water level in Kaptai lake	: 184 MW												
	c) Plants under shut down/ maintenance	: 1589 MW												
10.	Total Energy (Generation + India Import) :			182.85 MKWh										
	By Gas =	94.487 MKWh	55.094 MKWh											
	By Coal =	14.308 MKWh	1.088 MKWh											
	By Solar =	0.209 MKWh												
11.	Total Gas Supplied :			743.64 MMCFD										
<b>(D) Forecast of 13.01.21 (Today) Wednesday :</b>														
01.	Maximum Demand :			9500 MW (Generation end)	04.	Maximum Load-shed :			0 MW At evening peak (Sub-station end)					
02.	Maximum Generation :			12836 MW (Generation end)	05.	Total Generation :			187.89 MKWh					
03.	Maximum Shortage :			-3336 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :			25.9° C					

\* Captive Power \*\* Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)  
Deputy Secretary, Generation