

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2021				Day : Friday				Date : 15.01.21						
Probable Maximum Demand : 8600 MW				Probable Maximum Generation : 13161 MW				Rule Curve = 100.34 ft.						
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.35 ft.				Today = 97.29 ft.						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.01.21 (Yesterday)		15.01.21 (Today)		14.01.21 (Yesterday)		15.01.21 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks		Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
(A) Plants in operation:														
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0			85	Under maint.	
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0			170	Under maint.	
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	147	82	240	240					
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0			190	Under maint.	
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	320	360	360					
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20			Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	210	196	275	275					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450			Under maint.	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	351	371	412	412					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	67	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0			335	Under maint.	
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	60	90	100	100					
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305			Gas Shortage	
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	36	100	100	100					
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	61	64	80	80					
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55					
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	74	85	100	100					
19	Gagnagar 102 MW PP (Digital Powe)	HFO (IPP)	12x8.924	102	102	16	50	100	100					
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22					
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	57	55	58	58					
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	52	52	52					
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	80	105	105					
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	64	149	149	149					
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50					
28	Kamalaghat 54 MW PP (Banos Energy)	HFO (IPP)	3x18.69	54	54	0	54	54	54					
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	300	300	300	300					
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	125	128	149	149					
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300					
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
33	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	100					
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	35	0	55	55					
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	37					
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	90	90	90					
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	144	144	144					
Dhaka Zone Total				6281	6057	2174	2540	3353	3645	1276	895			
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	44	46	46	186			Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
42	Raazan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	0	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	47	50	50	50					
45	Sikalbaha 105 MW PP (Baraka Sike)	HFO (IPP)	6x18.415	105	105	0	0	0	100					
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Gas Shortage	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225			Gas Shortage	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	178	141	300	300					
49	Julda 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	20	40	100	100					
50	Julda 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	100	100	100					
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	102	102					
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	15	17	17					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	25	36	40					
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	43	31	90	93					
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54					
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110					
57	Julda unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100					
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0					
Chattogram Zone Total				2326	2266	619	710	1130	1237	741	180			
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135			Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	0	0	0					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	142	112	225	225					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	230	220	360	360					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	260	360	360					
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	2	0	0	53			Gas shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187			Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	73	68	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	51	39	0	0					
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	50	50	200	200					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	26	30	33	33					
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	1	34	43	43					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	22	20	22					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.05	200	200	0	0	0	200					
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	65	80	113	113					
**	Impoort (Tripura)	India		160	160	82	104	134	146					
Cumilla Zone Total				3040	2980	1106	1109	1843	2107	638	0			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	81	107	120	120	95			Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	20	22	22					
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	56	91	95	95					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	36	115	115					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	118	200	200	200					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
84	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0					
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	25	18	22	22					
Mymensingh Zone Total				717	709	282	472	626	574	95	0			

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.01.21 (Yesterday)		15.01.21 (Today)		14.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0				
87	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43				
88	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	50	50	51	51				
89	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	50	50	44	44				
90	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163				
91	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	40	40	40				
93	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	0	0	0	0	330		Under maint.	25/01/2021
94	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	69	70	70	70				
95	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	120	120				
96	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	19	20	20				
97	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0				
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	9	9				
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x3.34	25	25	8	8	8	8				
100	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	341	330	330				
101	Bibiana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Gas Shortage	
	Bibiana South	400 MW	Gas (PDB)				270	270	270	270				
	Shahjibazar	100 MW GTTP	Gas (PDB)				100	100	100	100			On Test	
	Sylhet Zone Total				2033	1988	1060	1174	1279	1279	400	330		
102	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
103	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	210	340	340	200		Gas Shortage	
104	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	4	35	35				
105	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70				
106	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
107	Khulna	115 PP MW (KPOL-2)	HFO (QRPP)	7x17	115	115	99	115	115	115				
108	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
109	Noapara	40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40				
110	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	90	90	90				
111	Madhurati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara	(HVDC)	India		1000	1000	681	822	499	739				
	Khulna Zone Total				2288	2284	1054	1281	1339	1865	200	0		
112	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
113	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	28	24	27				
114	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.	
115	Bhola	95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	31	31	80	80				
116	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	400	530	600	600				
	Bhola Nutan	Biddut BD LTD	Gas/HSD (IPP)				46	18	50	56				
	United Payra	Power Ltd.	HFO (IPP)				45	45	54	54				
	Barishal Zone Total				1676	1676	541	652	918	927	0	194		
117	a) Baghabari	71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari	100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
118	Baghabari	50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50				
119	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
121	Ammura	50 MW PP (Siraha)	HFO (QRPP)	7x7.79	50	50	0	25	25	25				
122	Chapainawabganj	100 MW Peaking	HFO (PDB)	12x8.924	104	104	52	102	104	104				
123	Katakahi	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
124	Katakahi	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50				
125	Santhar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34				
126	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	131	0	0	0	220		Gas Shortage	
129	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	320	400	400	400				
130	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
131	Bogra	20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0				
132	Ullapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
133	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	52	52				
134	Bagura	113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
135	Bagura	113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	95	113	113	113				
	Rajshahi Zone Total				2193	2183	752	938	1140	1264	821	0		
136	a) Barapukuria	TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria	TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
137	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	149	150	150				
138	Rangpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	105	100	113	113				
140	Saidpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Talulia	8 MW Solar PP (Sympla Pt)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
	Rangpur Zone Total				685	605	259	249	271	263	170	0		
	Sub-total: Plants in operation				21239	20748	7847.0	9125	11899	13161	4341	1599		
	Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						7560	8791	11463	12679				
(B) Contract expired power plants														
	Sub-Total: Plants under long term maintenance				0	0	0	0	0	0				
	Gross Total				21239	20748	7847	9125	11899	13161	4341	1599		

(C) Actual data of 14.01.21 (Yesterday) Thursday :				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :			
01.	Max. Demand (Generation end)	: 9125.00	MW, at = 19:00 hrs	Zone	Demand	Supply	Load Shed
02.	Max. Demand (Sub-station end)	: 8791.00	MW, at = 19:00 hrs		MW	MW	MW
03.	Highest Generation (Generation end)	: 9125.00	MW, at = 19:00 hrs	Dhaka	3031	3031	0
04.	Minimum Generation (Generation end)	: 5855.00	MW, at = 5:00 hrs				
05.	Day-peak Generation (Generation end)	: 7847.00	MW, at = 12:00 hrs	Chattoagram	1025	1025	0
06.	Evening-peak Generation (Generation end)	: 9125.00	MW, at = 19:00 hrs				
07.	Evening Peak Load-shed (Sub-station end)	: 0.00	MW, at = 19:00 hrs	Khulna	1093	1093	0
08.	Actual Minimum Generation up to 8:00 hrs.	: 5857.00	MW, at = 7:00 hrs	Rajshahi	926	926	0
09.	Generation shortfall at evening peak due to :			Cumilla	737	737	0
	a) Gas limitation	: 3985	MW				
	d) Coal supply Limitation	: 170	MW	13. Fuel cost :	(a) Gas = 94179257 Taka	(c) Coal = 68674243 Taka	
	b) Low water level in Kaptai lake	: 186	MW		(b) Oil = 394384105 Taka	Total = 557237605 Taka	
	c) Plants under shut down/ maintenance	: 1599	MW	14. Maximum Temperature in Dhaka was :	24.1° C		
10.	Total Energy (Generation + India Import)	: 182.90	MWKWh	15. Export through East-West interconnections :			
	By Gas = 94.934	MKWWh	54.225	At evening peak-hour	: 89	MW, at	19:00 hrs
	By Coal = 14.784	MKWWh	1.106	Maximum	: 8	MW, at	20:00 hrs
	By Solar = 0.202	MKWWh		Energy	: 0.012	MKWWh	
11.	Total Gas Supplied	: 738.90	MMCFD				

(D) Forecast of 15.01.21 (Today) Friday :				04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)			
01.	Maximum Demand	: 8600	MW (Generation end)	05. Total Generation	: 172.38	MKWWh	
02.	Maximum Generation	: 13161	MW (Generation end)	06. Probable Max. Temperature in Dhaka :	24.8° C		
03.	Maximum Shortage	: -4561	MW (Generation end)				

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation