

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2021				Day: Monday				Date: 18.01.21				
Probable Maximum Demand : 9500 MW				Probable Maximum Generation : 12797 MW				Rule Curve = 99.77 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.11 ft.				Today = 97.03 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.01.21 (Yesterday)		18.01.21 (Today)		17.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Power Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under maint.
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	211	200	180	180			
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	250	300	300	300			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	50	50		96	Gas Shortage
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		78	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	242	250	300	300			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0		450	Under maint.
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	333	341	412	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	40	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0		305	Gas Shortage
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	24	89	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	48	100	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	15	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	75	85	100	100			
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	50	72	100	100			
20	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	25	35	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	16	52	52			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	99	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	48	149	149	149			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50			
28	Kamalaghat 54 MW PP (Banos Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	300	300	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	64	130	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	49	55	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	37			
36	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	71	90	90	90			
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	144	144	144			
Dhaka Zone Total				6281	6057	2050	2763	3368	3620	1264	895	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	48	44	43	43		186	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	0	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50			
45	Sikalbaha 105 MW PP (Baraka Sike)	HFO (IPP)	6x18.415	105	105	0	0	0	100			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Gas Shortage
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	Gas Shortage
48	Anwara 300 MW PP (Uniled)	HFO (IPP)	17x17.076+ 3x8.04	300	300	252	250	300	300			
49	Julda 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	100	100			
50	Julda 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	102	102			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	15	15	15			
*	Malancha, Ctg EPZ (Uniled)	Gas	5x8.73+3x9.34			2	15	10	25			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	24	90	90			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Julda unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0			
Chattogram Zone Total				2326	2266	639	762	1099	1214	741	180	
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0		135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0		129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0		134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	3	3	5	5			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	164	174	225	225			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	260	260	360	360			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	260	260	360	360			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	0	0	0		55	Gas shortage
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8		187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	73	75	75	75			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	48	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	21	21			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	16	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	18	20	22			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.05	200	200	0	0	0	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	46	113	113			
**	Impoort (Tijpara)	India		160	160	76	102	134	146			
Cumilla Zone Total				3040	2980	999	1138	1782	2046	640	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	86	87	105	105		115	Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	32	91	95	95			
81	Jamalpur 115 MW PP (Uniled)	HFO (IPP)	12x9.87	115	115	16	65	115	115			
82	Mymensingh 200 MW PP (Uniled)	HFO (IPP)	21x9.780	200	200	190	200	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
84	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0			
85	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	19	22	22			

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.01.21 (Yesterday)		18.01.21 (Today)		17.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance					
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)						
86	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	20	20								
87	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43								
88	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	45	8	8	8								
89	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	50	20	5	5								
90	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	140	130	163	163								
91	Hobiganj	11MW PP Cofidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11								
92	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	20	40	40								
93	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	0	0	0	0	330		Under maint.	25/01/2021				
94	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	70	70	70	70								
95	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	20	150	160	160								
96	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	20	20								
97	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0								
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	9	9								
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x3.34	25	25	8	8	8	8								
100	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	341	341								
101	Bibiana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Gas Shortage					
		Bibiyana South 400 MW	Gas (PDB)				270	266	270	270								
		Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	100	100			On Test					
Sylhet Zone Total							2033	1988	985	1025	1268	400	330					
102	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16								
103	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	360	370	0	0	40		Gas Shortage					
104	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	35	35								
105	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	7	70	70							
106	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220								
107	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	99	99	115	115								
108	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100								
109	Noapara	40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	40	40	40	40								
110	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	90	90	90								
111	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100								
**	Bheramara (HVDC)	India		1000	1000		726	868	741	885								
Khulna Zone Total							2288	2284	1278	1474	1241	1671	40	0				
112	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110								
113	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	26	24	28								
114	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.					
115	Bhola	95 MW PP (Aggreko)	Gas (QRPP)	1,1x96	95	95	61	80	95	95								
116	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	450	440	600	600								
		Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				32	45	50	56								
		United Payra Power Ltd.	HFO (IPP)				0	0	0	0								
Barishal Zone Total							1676	1676	564	607	879	889	0	194				
117	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage					
118		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50								
119		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200								
120		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40								
121		Ammura 50 MW PP (Siraha)	HFO (QRPP)	7x7.79	50	50	0	25	28	28								
122		Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	105	104	104								
123		Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50								
124		Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50								
125		Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34								
126		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage					
127		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage					
128		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage					
129		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	369	285	400	400								
130		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22								
131		Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0								
132		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11								
133		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52								
134		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113	113								
135		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113								
Rajshahi Zone Total							2193	2183	622	724	1143	1267	821	0				
136	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage					
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage					
137		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150								
138		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
139		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2'3	113	113	113	107	113	113								
140		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
141		Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	3	0	8	0								
Rangpur Zone Total							685	605	266	257	271	263	170	0				
Sub-total: Plants in operation							21239	20748	7797.0	9232	11662	12797	4191	1599				
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							7447	8817	11137	12222								
(B) Contract expired power plants																		
Sub-Total: Plants under long term maintenance							0	0	0	0	0	0	0	0	0			
Gross Total							21239	20748	7797	9232	11662	12797	4191	1599				
(C) Actual data of 17.01.21 (Yesterday) Sunday :																		
01.	Max. Demand (Generation end) :				9232.00	MW,	at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand (Sub-station end) :				8817.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end) :				9232.00	MW,	at =	19:00 hrs	Dhaka	3102	3102	0	Mymensingh	780	780	0		
04.	Minimum Generation (Generation end) :				5531.00	MW,	at =	5:00 hrs	Chattogram	1002	1002	0	Sylhet	334	334	0		
05.	Day-peak Generation (Generation end) :				7797.00	MW,	at =	12:00 hrs	Khulna	986	986	0	Barishal	237	237	0		
06.	Evening-peak Generation (Generation end) :				9232.00	MW,	at =	19:00 hrs	Rajshahi	968	968	0	Rangpur	657	657	0		
07.	Evening Peak Load-shed (Sub-station end) :				0.00	MW,	at =	19:00 hrs	Cumilla	751	751	0						
08.	Actual Minimum Generation up to 8:00 hrs. :				5746.00	MW,	at =	7:00 hrs	Total 8817 8817 0									
09.	Generation shortfall at evening peak due to :								13. Fuel cost : (a) Gas = 100418074 Taka (c) Coal = 67591488 Taka (b) Oil = 350228316 Taka Total = 518237878 Taka									
	a) Gas limitation :				3835	MW												
	d) Coal supply Limitation :				170	MW												
	b) Low water level in Kaptai lake :				186	MW												
	c) Plants under shut down/ maintenance :				1599	MW												
10.	Total Energy (Generation + India Import) :				180.26	MKWh	14. Maximum Temperature in Dhaka was : 23.2° C											
	By Gas = 98.201 MKWh				47.500	MKWh	15. Export through East-West interconnections :											
	By Coal = 14.540 MKWh				1.093	MKWh	At evening peak-hour : 76 MW, at 19:00 hrs											
	By Solar= 0.312 MKWh						Maximum : 9 MW, at 20:00 hrs											
11.	Total Gas Supplied :				747.20	MMCFD	Energy : 0.055 MKWh											
(D) Forecast of 18.01.21 (Today) Monday :																		
01.	Maximum Demand :				9500	MW	(Generation end)				04.	Maximum Load-shed :				0	MW	At evening peak (Sub-station end)
02.	Maximum Generation :				12797	MW	(Generation end)				05.	Total Generation :				185.50	MKWh	
03.	Maximum Shortage :				-3297	MW	(Generation end)				06.	Probable Max. Temperature in Dhaka :				26.2° C		

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation