

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021		Day : Tuesday				Date : 02.03.21						
Probable Maximum Demand :		11200 MW		Yesterday = 9143 ft		Probable Maximum Generation :		13896 MW				
Water Level of Kaptai Lake at 06:00 AM				Today = 91.19 ft		Rule Curve =		92.84 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.03.21 (Yesterday)		02.03.21 (Today)		01.03.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	a) Ghorasal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.	
	b) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
2	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	300	300	300	300			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	13	12	12	12			
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Under maint.	7/3/2021
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	420	450	450	30		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	320	381	0	0			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	225	225	335	Under maint.	
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	93	100	100			
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	220	230	300	300			
15	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	100	100	100	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	81	97	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	71	96	100	100			
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	50	102	100	102			
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	0	22	22			
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	56	55	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
24	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	16	52	52			
25	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	90	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	98	149	149			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50			
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	249	300	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
31	Keraniganj 300 MW PP (APRI)	HSD (IPP)	25x6.14	300	300	0	58	100	300			
32	Bramhargan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	36	100	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	55	55			
36	Boslia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	113	144	144	144			
	Spectra Solar Plant Ltd.	Solar				31	0	30	0			
Dhaka Zone Total				6171	5972	2752	3318	3657	3879	365	1160	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160		Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raazari 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	46	46			
45	Sikalbaha 105 MW PP (Baraka Siks)	HFO (IPP)	6x18.415	105	105	0	0	50	100			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100	50		Gas Shortage
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Gas Shortage
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	306	304	300	300			
49	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	21	10	100	100			
50	Juldah 100 MW Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
51	Dohazari Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85			
52	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	15	22	22			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	20	10	25			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	32	64	102	102			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	90	90	100	100			
58	Chattogram 116 MW PP (Anima Er)	HFO (IPP)	6x21.06	116	116	0	0	116	116			
Chattogram Zone Total				2442	2382	864	987	1415	1455	615	180	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	10	10	10	35		Gas Shortage
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	187	195	225	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	260	300	300			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	285	285	300	300			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50		Gas shortage
65	Ashuganj 185MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51		Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150		Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	50		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	117	125	138	125			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	136	150	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
73	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	20	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14.4+1x15+1x15+1x15	200	200	0	0	0	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	35	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	36	111	113	113			
**	Impoport (Tripura)	India		160	160	118	152	135	147			
	Bhairon 54.5 MW	HFO (IPP)				0	0	0	0			
Cumilla Zone Total				3040	2980	1218	1463	1678	1927	879	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	85	98	110	110			
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	22	22			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	24	33	82	82			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	8	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	170	190	200	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50									

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.03.21 (Yesterday)		02.03.21 (Today)		01.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	20	20				
88	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	0	0				
89	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021	
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163				
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	36	35	35		30	Under maint.	
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	163	162	162	162	168		Gas Shortage	
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	80	74	80				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0			Under maint.	
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20				
98	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020	
99	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	5	5	10	10				
100	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16				
101	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	275	341	341				
102	Bibiyana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	421	406	350	350				
	Bibiyana South	400 MW	Gas (PDB)				271	270	300	300				
	Shahjibazar	100 MW GTTP	Gas (PDB)				0	0	0	0			On Test	
Sylhet Zone Total						2033	1988	1513	1538	1553	1559	168	261	
103	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	200	163	190	190	247		Gas Shortage	
105	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	0	25	25				
106	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	12	60	60				
107	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	66	99	115	115				
109	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	20	50	100				
110	Noapara	40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	16	40	40	40				
111	Rupsha	105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	92	105	105	105				
112	Machumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000		665	699	723	723				
Khulna Zone Total						2288	2284	1043	1138	1408	1694	247	0	
113	Barsal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	80	110	110				
114	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	25	26	26				
115	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.	
116	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	70	54	95	95				
117	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	450	550	620	620				
118	Potukhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
	Bhola Nutan	Biddut BD LTD	Gas/HSD				74	53	51	51				
Barishal Zone Total						1826	1826	609	762	1052	1052	0	194	
119	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50				
121	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
123	Ammura	50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	12	12	12	12				
124	Chapainawabganj	100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	104	104				
125	Katakhal	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	50	50				
126	Katakhal	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	50	50				
127	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	20	0	34				
128	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			Gas Shortage	
129	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	174	132	180	180				
131	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	416	380	400	400				
132	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22				
133	Bogra	20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020	
134	Ullapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
135	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52				
136	Bagura	113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
137	Bagura	113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	113	113				
Rajshahi Zone Total						2193	2183	883	1066	1307	1431	601	0	
138	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	84	85	85	1		Coal Shortage	
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
139	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150				
140	Rangpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		20	Under Overhauling	
141	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	107	113	113	113				
142	Saidpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara	Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total						685	605	263	347	356	348	86	20	
Sub-total: Plants in operation						21395	20929	9520.0	10988	13029	13896	2961	1815	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						9061	10458	12400	13226					
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0			
Gross Total						21395	20929	9520	10988	13029	13896	2961	1815	
(C) Actual data of 01.03.21 (Yesterday) Monday :														
01.	Max. Demand (Generation end)	: 10988.00 MW, at = 19:30 hrs				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand (Sub-station end)	: 10458.00 MW, at = 19:30 hrs				Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 10988.00 MW, at = 19:30 hrs				Dhaka	3884	3884	0	Mymensingh	807	807	0	
04.	Minimum Generation (Generation end)	: 7475.00 MW, at = 5:00 hrs				Chattogram	1082	1082	0	Sylhet	379	379	0	
05.	Day-peak Generation (Generation end)	: 9520.00 MW, at = 12:00 hrs				Khulna	1278	1278	0	Barishal	295	295	0	
06.	Evening-peak Generation (Generation end)	: 10988.00 MW, at = 19:30 hrs				Rajshahi	1082	1082	0	Rangpur	669	669	0	
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:30 hrs				Cumilla	982	982	0					
08.	Actual Minimum Generation up to 8:00 hrs.	: 7631.00 MW, at = 7:00 hrs				Total : 10458 Demand, 10458 Supply, 0 Load Shed								
09.	Generation shortfall at evening peak due to :					13. Fuel cost : (a) Gas = 132168862 Taka, (c) Coal = 75649138 Taka, (b) Oil = 458610388 Taka, Total = 666428388 Taka								
	a) Gas limitation	: 2715 MW				14. Maximum Temperature in Dhaka was : 33.5° C								
	d) Coal supply Limitation	: 86 MW				15. Export through East-West interconnections : At evening peak-hour : -222 MW, at 19:30 hrs, Maximum : -434 MW, at 7:00 hrs, Energy : 2.303 MKWh								
	b) Low water level in Kaptai lake	: 160 MW												
	c) Plants under shut down/ maintenance	: 1815 MW												
10.	Total Energy (Generation + India Import)	: 225.67 MKWh												
	By Gas = 124.151 MKWh	64.264 MKWh												
	By Coal = 16.162 MKWh	By Hydro = 1.696 MKWh												
	By Solar = 0.669 MKWh													
11.	Total Gas Supplied	: 906.08 MMCFD												
(D) Forecast of 02.03.21 (Today) Tuesday :														
01.	Maximum Demand	: 11200 MW (Generation end)				04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 13896 MW (Generation end)				05. Total Generation : 230.03 MKWh								
03.	Maximum Shortage	: -2696 MW (Generation end)				06. Probable Max. Temperature in Dhaka : 33.5° C								

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation