

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021		Day : Saturday				Date : 06.03.21						
Probable Maximum Demand :		11000 MW		Yesterday = 90.73 ft		Today = 90.49 ft		Probable Maximum Generation : 15350 MW				
Water Level of Kaptai Lake at 06:00 AM								Rule Curve = 92.20 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.03.21 (Yesterday)		06.03.21 (Today)		05.03.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening	Description/ Remarks			
(A) Plants in operation:												
1	a) Ghorasal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.	
	b) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190			
2	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	300	300	300	300			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	12	12	108	108			
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	94	204	0	0	156	Under maint.	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	420	450	450	30		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	355	338	412	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	180	200	200	155	Under maint.	
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	20	100	100			
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	270	270	300	300			
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	0	0	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	15	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	10	50	100	100			
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	0	100	100			
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22			
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	55	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
24	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52			
25	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	16	149	149			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50			
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	195	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	50	130	149	149			
31	Keraniganj 300 MW PP (APRI)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
32	Bramhargan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	0	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	10	35	35			
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	36	104	104			
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	144	144			
	Spectra Solar Plant Ltd.	Solar (IPP)				31	0	30	0			
Dhaka Zone Total			6171	5972	1834	2553	4130	4350	365	776		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raazari 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	12	45	50	50			
45	Sikalbaha 105 MW PP (Baraka Siks)	HFO (IPP)	6x18.415	105	105	0	0	50	100			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130			
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Gas Shortage	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	121	287	300	300			
49	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	0	100	100			
50	Juldah 100 MW Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	0	20	100	100			
51	Dohazari Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	85	85			
52	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			29	35	12	20			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	102	102			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
58	Chattogram 116 MW PP (Anima Er)	HFO (IPP)	6x21.06	116	116	0	0	116	116			
Chattogram Zone Total			2442	2382	487	773	1447	1480	565	180		
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	3	23	20	23	22	Gas Shortage	
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	191	184	225	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	260	270	300	300			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	300	300	300			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas shortage	
65	Ashuganj 185MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	50		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	96	96	96	96			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	32	147	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	21	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	8	11	11			
73	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	21	20	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14.4+1x15+1x10.04	200	200	0	0	0	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	8	113	113			
**	Impoort (Tripura)	India		160	160	96	126	135	147			
	Bhairab 54.5 MW	HFO (IPP)				56	56	55	55			
Cumilla Zone Total			3040	2980	1079	1298	1701	1967	866	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	103	143	150	160			
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	17	17			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	32	82	82	82			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	0	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	200	200	200			
84	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.03.21 (Yesterday)		06.03.21 (Today)		05.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	44	44				
88	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0				
89	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	48	53	51	51				
90	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021	
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	130	163	163				
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	34	20	36	36		46	Under maint.	
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	162	154	160	160	176		Gas Shortage	
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	83	83	83				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	136	136	137	137		95	Under maint.	
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20				
98	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020	
99	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	5	7	10	10				
100	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
101	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	341	341				
102	Bibiyana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	353	367	350	350				
	Bibiyana South	400 MW	Gas (PDB)				379	320	370	400				
	Shahjibazar	100 MW GTTP	Gas (PDB)				0	0	0	0			On Test	
Sylhet Zone Total						2033	1988	1709	1649	1792	1822	176	141	
103	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+ 1 x 132	410	410	230	400	400	400	10		Gas Shortage	
105	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25				
106	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	0	100	115	115				
109	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
110	Noapara	40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	24	40	40				
111	Rupsha	105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	0	90	105	105				
112	Machumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000		812	836	852	827				
Khulna Zone Total						2288	2284	1042	1450	1747	2008	10	0	
113	Barsal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	64	110	110				
114	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	27	26	27				
115	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.	
116	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	33	41	95	95				
117	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	480	620	620				
118	Potukhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
Bhola Nutan Biddut BD LTD														
Barishal Zone Total						1826	1826	490	681	1071	1072	0	194	
119	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50				
121	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
123	Ammura	50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	0	12	12				
124	Chapanawabganj	100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	0	104	104				
125	Katakali	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
126	Katakali	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
127	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34				
128	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
129	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	200	225	220		Gas Shortage	
130	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	170	154	200	225				
131	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	384	404	400	400				
132	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
133	Bogra	20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020	
134	Ullapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11				
135	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
136	Bagura	113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	0	70	113	113				
137	Bagura	113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	94	94	94				
Rajshahi Zone Total						2193	2183	617	753	1508	1682	601	0	
138	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	111	110	105	110			Coal Shortage	
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
139	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150				
140	Rangpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		20	Under Overhauling	
141	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	80	113	113				
142	Saidpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara	Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total						685	605	301	340	376	373	85	20	
Sub-total: Plants in operation						21395	20929	7951.0	9947	14410	15350	2668	1311	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss								7472	9348	13542	14426			
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0			
Gross Total						21395	20929	7951	9947	14410	15350	2668	1311	
(C) Actual data of 05.03.21 (Yesterday) Friday :														
01.	Max. Demand (Generation end) : 9947.00 MW, at = 20:00 hrs					12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand (Sub-station end) : 9348.00 MW, at = 20:00 hrs					Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end) : 9947.00 MW, at = 20:00 hrs					MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end) : 7363.00 MW, at = 5:00 hrs					Dhaka	3185	3185	0	Mymensingh	826	826	0	
05.	Day-peak Generation (Generation end) : 7951.00 MW, at = 12:00 hrs					Chattogram	1005	1005	0	Sylhet	350	350	0	
06.	Evening-peak Generation (Generation end) : 9947.00 MW, at = 20:00 hrs					Khulna	1219	1219	0	Barishal	262	262	0	
07.	Evening Peak Load-shed (Sub-station end) : 0.00 MW, at = 20:00 hrs					Rajshahi	991	991	0	Rangpur	614	614	0	
08.	Actual Minimum Generation up to 8:00 hrs. : 7300.00 MW, at = 7:00 hrs					Cumilla	896	896	0					
09.	Generation shortfall at evening peak due to :									Total	9348	9348	0	
	a)	Gas limitation : 2423 MW								(c) Coal =	84159108	Taka		
	d)	Coal supply Limitation : 85 MW								(b) Oil =	187769937	Taka		
	b)	Low water level in Kaptai lake : 160 MW								Total =	402371139	Taka		
	c)	Plants under shut down/ maintenance : 1311 MW												
10.	Total Energy (Generation + India Import) : 199.46 MCKWh					14.	Maximum Temperature in Dhaka was : 32.5° C							
	By Gas = 128.209 MCKWh		By Hydro = 29.571 MCKWh		15.	Export through East-West interconnections :								
	By Coal = 17.343 MCKWh		By Solar = 1.684 MCKWh			At evening peak-hour : -42 MW, at 20:00 hrs								
	By Solar = 0.679 MCKWh					Maximum : -228 MW, at 19:00 hrs								
11.	Total Gas Supplied : 1010.83 MCFD						Energy : 0.5075 MCKWh							
(D) Forecast of 06.03.21 (Today) Saturday :														
01.	Maximum Demand : 11000 MW (Generation end)					04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation : 15350 MW (Generation end)					05.	Total Generation : 220.57 MCKWh							
03.	Maximum Shortage : -4350 MW (Generation end)					06.	Probable Max. Temperature in Dhaka : 35° C							

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation