

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour		Energy Generated	Remarks	
					Generation	Hour			
				Unit No. X Capacity	MW	MM	MM		
	Ghorasal Repowered CCGP Unit-4	PDB	1'210	170	0	0	0	Under maint.	
	Ghorasal Repowered CCGP Unit-5	PDB	1'210	190	0	0	0	Under maint.	
	Ghorasal TFP Unit-5	PDB	1'210	190	190	3339000			
2	Ghorasal 365 MW CCGP Unit-7	PDB	1'243+1'122	365	300	7088491		Gas shortage	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2'40	78	0	0		Contract Expired	
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	0	11500		Gas shortage	
5	Haripur GTPP	SBU, PDB	2'32	20	0	0		Under Maint.	
6	Haripur 412 MW CCGP	EGCB	1'273+1'139	412	0	0		Dirty fuel(Gas)	
7	Haripur 360MW CCGP(LH)	IPP	1'235+1'125	360	0	2120000		Dirty fuel(Gas)	
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2'150+1'150	450	250	5381750		Dirty fuel(Gas)	
9	Meghnaghat 100 MW(EL)	QRPP	12'8.9	100	100	913920			
10	Meghnaghat CCGP(Summit)	IPP	2'110+1'110	305	240	5644451		Dirty fuel(Gas)	
11	Madanganj 102 PPI(Summit)	QRPP	6'17	100	100	775104			
12	Madanganj-25 MW PPI(Summit)	(IPP)	3'17.08+1'11.3	55	55	730816			
13	Karaniganj 120 MW PP (Doreen)	QRPP	8'13.45	100	85	1364182		Engine problem	
14	Narasinghat 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	422136			
15	210 MW Siddhirgonj TFP	PDB	1'210	115	0	0		Under maint.	
16	Siddhirgonj 2'120 MW GTFP	EGCB	2'105	210	0	0		Gas shortage	
17	Siddhirgonj 100 PPI(Dutch Bangla	QRPP	12'8.9	100	100	1638720			
18	Siddhirgonj 335 MW CCGP	EGCB	1'217+1'118	335	221	5455602		ST Under maint.	
19	Gagnagar 102 MW PP (Digital Po	IPP	12'8.924	102	102	672064			
20	Katpali 52 MW PP (Sinha)	IPP	7'7.9	51	49	299248			
21	Kamalaghat 54 MW PP(Banco En	IPP	3'18	54	54	1183680			
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	150	536160			
23	Manikganj 55 MW PP (Northern	IPP	3'19.3	55	55	822951			
24	Nababganj 55 MW PP (Southern	IPP	3'19.3	55	55	792406			
25	Bossia 108MW PPI(CLC)	IPP	12'8.75+1'3.5	108	0	0		Fuel shortage	
26	Summit Power (Madhabhat-Ashuli)	SIPP, REB	3'8.67+1'8.73	80	35	1059720		Engine problem	
27	Maona 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	33	819800			
28	Rugganj 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	33	774000			
29	Gazipur 52 MW PP	IPP	6'8.9	52	51	166260			
30	Tongi 80 MW GTFP	PDB	1' 105	105	0	0		Under maint.	
31	Kodda 300 MW PP Unit-2 (Summ	IPP	16'17.076	300	300	4870143			
32	Keraniganj 300 MW PP (APR)	IPP	26'1.4	300	0	0		Reserve.	
33	Bramhangsan 100 MW PP (Aggr	IPP	100	100	0	20170		Reserve.	
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	74773		Reserve.	
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	149	3251664			
36	Gazipur 100 MW PP	RPCL	100 MW	105	90	888024		Engine problem	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18'5.6	104	90	1520640		Engine problem	
38	Manikganj 162MW PPI(MPGL)	IPP	9'18	162	144	828000		Engine problem	
	Spectra Solar Plant Ltd.	IPP	35	0	0	0			
Dhaka area Total				5972	3053	53617375			
39	Chattoagram TFP-1	PDB	1'210	180	120	2900000		Gas shortage.	
	Chattoagram TFP-2	PDB	1'210	180	0	0		Gas shortage	
40	Raozan 25 MW PP	IPP	3'8.9	25	25	271605			
41	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	106110			
42	Falanga 50MW PP (Baraka)	IPP	8'8.98	50	50	872640			
43	Kaptai Hydro Unit-2,3,4, 5	PDB	2'40+1'50	230	70	1666000		Unit-2 under maint	
44	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0		Gas shortage	
45	Sikalbaha Peaking GT	PDB	1'150	150	120	2914045			
46	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	0	0		Reserve.	
47	Hathazari 100 MW peaking PP	PDB	118.9	98	0	0		Under maint.	
48	Hathazari-Kalin 100 MW Peakin	PDB	6'13.7	102	102	307415			
49	Judiah 100 MW Unit-1 (Acorn)	QRPP	8'13.45	100	40	226990		High Voltage.	
50	Judiah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1442880			
51	Baratkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	20	412080			
*	Malarcha, Ctg. EPZ (Unlited)		5'8.73+3'9.34	0	20	525600			
52	Chattoagram 108 MW PP (ECPV)	IPP	16'7	108	54	329280		Low demand	
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	19920			
54	Anwara 300 MW PP (Unlited)	IPP	300 MW	300	306	6440836			
55	Jodiach Power	IPP	3'18.5+1'3.6	54	54	684229			
56	Karnaphuli Power Ltd.	IPP	110	110	0	0		Reserve.	
57	Judiah unit-2 (Acorn)	IPP	6'13.6	100	100	2395200			
	Anilma Energy Ltd.	IPP	6'21.2	116	17	79036		Low demand	
Chattoagram area Total				2382	1198	21623676			
58	Ashuganj TFP Unit-3	APSCL	1'150	135	0	0		Gas shortage	
	Ashuganj TFP Unit-4	APSCL	1'150	129	0	0		Gas shortage	
	Ashuganj TFP Unit-5	APSCL	1'150	134	130	267166			
59	Ashuganj 225 MW CCGP	APSCL	1'142+1'75	221	183	4527000		FGMO	
60	Ashuganj 450 MW CCGP(North)	APSCL	1'360	360	30	4891000		Synchronized at 16.51.	
61	Ashuganj 450 MW CCGP(South)	APSCL	1'360	360	295	7324000		FGMO	
62	Ashuganj 50 MW PP	APSCL	14'3.968	45	23	513936		Gas shortage	
63	Ashuganj 55 MW PP (Precision	RPP	19'4	55	55	918720		Gas shortage	
64	Ashuganj 195MW PP (APSCL-UN	IPP	20'9.124+1'16	195	0	0		Gas shortage	
65	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	0	0		Line fault	
66	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	0	0		Line fault	
67	Titas 50 MW Peaking PP	PDB	6'8.92	52	6	54144		Low demand	
68	Chandpur 150 MW CCGP	PDB	1'106+1'57	163	77	1993250		Machine problem	
69	Chandpur 200MW (Desh energy)	IPP	0	200	161	2943840		Low demand	
70	Feni 22MW PP (Dreem)	SIPP, PDB	8'2.90	22	19	334008			
71	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	8	210600		Engine problem	
**	Import (Tribuna)		Imported power	0	160	140	2604480		
72	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	819600			
73	Jangalia 52 MW PP (Lakdanav)	IPP	6'8.92	52	52	217130			
74	Curulla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	21	367320			
75	Daudkandi 200 MW PP (B. Trac)	IPP	154'1.4	200	0	0		Reserve.	
76	Feni Lanka Power	IPP	7'18.415+1'9.78	114	100	225720		Low demand	
77	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	113	1415400			
	Bhairab 54.5 MW	IPP	3'18.2	0	37	82440		On Test	
Cumilla Area Total				2980	1483	32317754			
78	RPCL 210MW CCGP	IPP	4'35+1'70	202	123	3159440		Gas shortage	
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	12	249948		Engine problem	
80	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	81	833280		Engine problem	
81	Sarihashani 3 MW Solar Plant	IPP	3	3	0	7400			
82	Mymensingh 200 MW PP (Unlited)	IPP	200	200	200	3811200		Low demand	
83	Jamalpur 115 MW PP (Unlited)	IPP	115 MW	115	35	235200		#REF!	
84	Sultakhal 50 MW Solar PP	IPP	50	50	0	190710			
85	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	24	394080			
Mymensingh Area Total				709	475	8881258			
86	Fenchuganj CCGP Phase-1	PDB	2'32+1'33	70	43	1017000		Machine problem	
87	Fenchuganj CCGP Phase-2	PDB	2'35+1'35	90	31	609000		Machine problem	
88	Kushiana 163 MW CCGP (KP)	IPP	1'109+1'54	163	163	3776809			
89	Shajibazar 330 MW CCGP	PDB	3'110	330	307	6845000			
90	Fenchuganj 51 MW PP (Barakati)	RPP	19'2.90	51	53	1181400			
91	Fenchuganj 44MW (Energyprima	RPP	12'3.3+5'2	44	0	0		Contract Expired	
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	245000			
93	Shajibazar GTPP Unit- 8 & 9	PDB	2'35	66	35	814752		GT-9 Under maint.	
94	Shajibazar 66MW PP (Shajibaz	RPP	32'2.60	66	79	1763520			
	Shajibazar 100 MW GTFP	PDB	1'100	0	0	0		Under Shut down	
95	Sylhet 225 MW CCGP	PDB	1'142+1'89	231	0	0		Machine problem	
96	Sylhet 20 MW GTFP	PDB	1'20	20	18	358000			
97	Sylhet 50MW PP (EPL)	RPP	27'2	50	0	0		Contract Expired	
98	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	377760		Engine problem	
99	Bibiana-II 341 MW CCGP (Summ	IPP	1'222+1'119	341	290	7466500		FGMO	
100	Bibiyana-III 400 MW CCGP	IPP	400 MW	400	322	7077000			
101	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	7	160200		Engine problem	
	Bibiana South 400 MW	PDB	400 MW	383	250	5959400		On Test	
Sylhet Area Total				2371	1625	38303341			
102	Bheramara GTPP Unit-3	PDB	1'20	16	0	0		Reserve.	
**	Bheramara (HVDC)	Imported power	2'500	1000	725	17641091			
103	Khulna 115 MW PP (KPCL-2)	QRPP	7'17	115	66	702720		Engine problem	
104	Fardpur 50 MW Peaking PP	PDB	6'8.89	54	0	0		Reserve.	
105	Khulna 225 MW CCGP	NWPGCL	1'150+1'75	230	0	0		Reserve.	
106	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	12	24960		Low demand	
107	Bheramara 410 MW CCGP	NWPGCL	1'278+1'132	410	235	6278400		FGMO	
108	Noapara 40 MW PP (Khanjahan A	QRPP	5'8.5	40	40	101250			
109	Noapara 100 MW PP (Bangla Tra	IPP	70'1.4	100	50	117120		Low demand	
110	Rupsha 105 MW PP (Orion rupsh	IPP	6'18.445	105	85	1366800		Engine problem	
111	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0		Reserve.	
Khulna Area Total				2284	1223	26121541			
112	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	48	231744		High Voltage.	
113	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	34	491400			
114	Bhola 225 MW CCGP	PDB	2'63+1'68	194	0	0		Under maint.	