

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021			Day : Saturday				Date : 20.03.21							
Probable Maximum Demand : 11300 MW			Yesterday = 8799 ft				Today = 87.77 ft				Probable Maximum Generation : 15689 MW			
Water Level of Kaptai Lake at 06:00 AM							Rule Curve = 89.96 ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.03.21 (Yesterday)		20.03.21 (Today)		19.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
					Day	Evening	Day	Evening	Gas/water/Coal limitation	Machines shut down (MW)				
(A) Plants in operation:														
1	a) Ghorasal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.			
	b) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.			
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190					
2	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	300	260	300	300					
3	Ghorasahat 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	99	103	108	108					
4	Ghorasahat 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage			
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	227	279	280	280					
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Dirty in fuel gas			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling			
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	345	343	412	412					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	70	150	200	140	Gas Shortage			
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	160	154	150	150	181	ST Under maint.			
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	70	100	100					
14	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	305	305	240	250	250	250					
15	Meghnaghat 100 MW(HL)	HFO (QRPP)	12x8.9	100	100	0	12	100	100					
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	30	100	100					
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	55	55					
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	4	85	85	85					
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	0	100	100					
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.90	22	22	22	22	22	22					
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIIP, REB)	6x167+7x8.73	80	80	39	51	58	58					
22	Maona 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	25	25	17	17					
23	Rupganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	33	33	33	33					
24	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52					
25	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105					
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	64	149	149					
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50					
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54					
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	19	280	300	300					
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	100	149	149	149					
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300					
32	Bramhargan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100					
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	35	55	55					
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55					
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	104	104					
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	54	144	144					
	Spectra Solar Plant Ltd.	Solar (IPP)				22	0	30	0					
Dhaka Zone Total			6171	5972	1860	2802	4007	4277	715	646				
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level			
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	105	105	105					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.			
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0					
42	Raazan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	8	44	50	50					
45	Sikalbaha 105 MW PP (Baraka Sika)	HFO (IPP)	6x18.415	105	105	0	0	50	100					
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	80	0	0					
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	203	225	225					
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	49	138	300	300					
49	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100					
50	Juldah 100 MW Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	0	60	100	100					
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	102	102					
52	Hathazari 22 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					
53	Barakunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	19	19	20	20					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			22	42	10	10					
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	102	102					
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54					
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110					
57	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	75	100	100	100					
58	Chattogram 116 MW PP (Anima Er)	HFO (IPP)	6x21.06	116	116	0	0	116	116					
Chattogram Zone Total			2442	2382	693	1000	1664	1689	160	180				
59	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	100	135	135					
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	80	100	130	130					
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage			
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	19		Gas Shortage			
61	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	215	182	225	225					
62	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	265	270	350	350					
63	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	260	275	350	350					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	25	25	25	25					
65	Ashuganj 185MW PP (APSCCL United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50					
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	82	200	200	200					
71	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	21	21	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	8	11	11	11					
73	Jangala 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52					
75	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	12	12	12	12					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14.4+1x15+1x16.026	200	200	0	0	0	200					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	36	113	113					
**	Impoport (Tripura)	India		160	160	124	152	150	167					
	Bhairab 54.5 MW	HFO (IPP)				0	0	0	0					
Cumilla Zone Total			3040	2980	1239	1451	1956	2223	541	163				
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	123	136	144	144	66	Gas Shortage			
80	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	17	20	22	22					
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	24	24	81	81					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	109	115	115					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	187	105	200					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0					
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	24	24	22	22					
Mymensingh Zone Total			717	709	349	504	541	584	66	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.03.21 (Yesterday)		20.03.21 (Today)		19.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	44	44				
88	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42				
89	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	50	50	51	51				
90	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021	
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	33	34	35	35	32		GT-9 Under maint.	
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	284	258	300	300				
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	78	78				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	146	149	150	160				
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	20	20				
98	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020	
99	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	10	10				
100	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
101	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	315	341	341				
102	Bibiyana-II	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	316	400	400				
103	Bibiyana South	383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	330	317	330	330				
	Shahjibazar	100 MW GTTP	Gas (PDB)				0	0	0	0			On Test	
Sylhet Zone Total						2416	2371	1883	1804	1991	2001	0	32	
104	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
105	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+ 1 x 132	410	410	285	305	385	385				
106	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25				
107	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	0	90	99	99				
110	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	30	50	100				
111	Noapara	40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40				
112	Rupsha	105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	53	70	90	95				
113	Madhupati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000		717	716	735	735				
Khulna Zone Total						2288	2284	1055	1251	1584	1875	0	0	
114	Barsal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	80	110	110				
115	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	28	25	25				
116	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.	
117	Bhola	95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	93	95	95	95				
118	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	460	550	620	620				
119	Potukhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
	Bhola Nutan	Biddut BD LTD	Gas/HSD				0	0	90	90				
Barishal Zone Total						1826	1826	570	753	1090	1090	0	194	
120	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
121		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50				
122		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
124		Ammura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	42	42	42				
125		Chapanawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	0	100	100				
126		Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
127		Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
128		Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	34				
129		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
130		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	165	164	200	200				
131		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	201	140	200	200				
132		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	390	376	400	400				
133		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22				
134		Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020	
135		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
136		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	25	52	52				
137		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	25	113	113	113				
138		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	50	100	95	113				
Rajshahi Zone Total						2193	2183	861	1019	1535	1677	381	0	
139	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	149	150	150				
141		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	2	10	10	10				
142		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	70	107	113	113				
143		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144		Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total						685	605	227	266	281	273	170	0	
Sub-total: Plants in operation						21778	21312	8737.0	10846	14649	15689	2033	1215	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						8346	10360	13992	14986					
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0			
Gross Total						21778	21312	8737	10846	14649	15689	2033	1215	
(C) Actual data of 19.03.21 (Yesterday) Friday :														
01.	Max. Demand (Generation end)			: 10846.00 MW, at = 19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):									
02.	Max. Demand (Sub-station end)			: 10360.00 MW, at = 19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)			: 10846.00 MW, at = 19:30 hrs	Dhaka	3458	3458	0	Mymensingh	925	925	0		
04.	Minimum Generation (Generation end)			: 8189.00 MW, at = 6:00 hrs	Chattogram	1119	1119	0	Sylhet	396	396	0		
05.	Day-peak Generation (Generation end)			: 8737.00 MW, at = 12:00 hrs	Khulna	1293	1293	0	Barishal	277	277	0		
06.	Evening-peak Generation (Generation end)			: 10846.00 MW, at = 19:30 hrs	Rajshahi	1164	1164	0	Rangpur	706	706	0		
07.	Evening Peak Load-shed (Sub-station end)			: 0.00 MW, at = 19:30 hrs	Cumilla	1022	1022	0						
08.	Actual Minimum Generation Forecast up to 8:00			: 8133.00 MW, at = 5:00 hrs	Total 10360 10360 0									
09.	Generation shortfall at evening peak due to :				13. Fuel cost : (a) Gas = 162927297 Taka (c) Coal = 76792846 Taka									
	a) Gas limitation			: 1703 MW	(b) Oil = 236173184 Taka Total = 475893327 Taka									
	d) Coal supply Limitation			: 170 MW										
	b) Low water level in Kaptai lake			: 160 MW										
	c) Plants under shut down/ maintenance			: 1215 MW										
10.	Total Energy (Generation + India Import)			: 220.38 MCKWh	14. Maximum Temperature in Dhaka was : 35.0° C									
	By Gas = 147.802 MCKWh			By Oil = 33.177 MCKWh	15. Export through East-West interconnections :									
	By Coal = 16.631 MCKWh			By Hydro = 1.680 MCKWh	At evening peak-hour : -294 MW, at 19:30 hrs									
	By Solar = 0.666 MCKWh				Maximum : -294 MW, at 19:30 hrs									
11.	Total Gas Supplied			: 1170.49 MCMCFD	Energy : 0.757 MCKWh									
(D) Forecast of 20.03.21 (Today) Saturday :														
01.	Maximum Demand			: 11300 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation			: 15689 MW (Generation end)	05. Total Generation : 229.60 MCKWh									
03.	Maximum Shortage			: -4389 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 37.3° C									

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation