

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month March, 2021		Day : Thursday				Date : 25.03.21					
Probable Maximum Demand :		12800 MW				Probable Maximum Generation : 15061 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 87.26 ft				Today = 87.02 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.03.21 (Yesterday)		25.03.21 (Today)		24.03.21 Gen. shortfall for : (Yesterday) (MW)	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
<b>(A) Plants in operation:</b>											
1	a) Ghorasal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering
1	b) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
1	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	170	170	170	0	Under maint.
2	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	190	190	365	Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	90	92	99	99	0	Contract Expired on 08/01/2021
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	0	Contract Expired on 08/01/2021
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	400	350	350	0	Under Overhauling
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	303	343	412	412	69	Gas Shortage
11	Siddhirganj 2'120 MW GTTP	Gas (EGCB)	2 x 105	210	210	178	183	100	180	0	Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	s/d for filter changing due to Dirt in gas
13	Siddhirganj 100 PPI(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100	0	0
14	Meghnadhat CAPP(Summit)	Gas (IPP)	2x110+1x110	305	305	260	270	270	270	35	dirt in gas
15	Meghnadhat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	100	100	100	100	0	0
16	Madanganj 102 PPI(Summit)	HFO (QRPP)	6x17	102	100	48	87	100	100	0	0
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	50	55	55	0	0
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	52	73	85	85	0	0
19	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	102	102	100	100	0	0
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22	0	0
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x8.67+7x8.73	80	80	53	53	58	58	0	0
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33	0	0
23	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	33	33	33	0	0
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	51	52	52	0	0
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	105	105	0	0
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	115	148	149	149	0	0
27	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	50	50	50	50	0	0
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54	0	0
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	263	280	300	300	0	0
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	131	130	149	149	0	0
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	104	304	100	300	0	0
32	Bramangan 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	50	99	50	100	0	0
33	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	45	100	100	100	0	0
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	55	55	55	55	0	0
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55	0	0
36	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0	0	0
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104	0	0
38	Manikganj 162MW PP(MPLG)	HFO (IPP)	9x18	162	162	144	144	144	144	0	0
	Spectra Solar Plant Ltd.	Solar (IPP)				17	0	30	0	0	0
<b>Dhaka Zone Total</b>				<b>6171</b>	<b>5972</b>	<b>3248</b>	<b>3775</b>	<b>3774</b>	<b>4074</b>	<b>819</b>	<b>935</b>
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x60	230	230	70	70	70	70	160	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0	0	0
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25	0	0
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0	0	0
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	45	50	50	0	0
45	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	0	0	50	100	0	0
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	110	120	120	40	Gas Shortage
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	203	225	225	0	0
48	Anwara 300 MW PP (Unite)	HFO (IPP)	17x17.076+3x8.04	300	300	197	197	300	300	0	0
49	Julidah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	90	100	100	100	0	0
50	Julidah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100	0	0
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	102	102	0	0
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	0	0
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	16	20	20	0	0
*	Malancha, Ctg,EPZ (Unite)	Gas	5x8.73+3x9.34			2	29	10	15		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	6	6	6	0	0
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54	0	0
56	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110	0	0
57	Julidah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100	0	0
58	Chattogram 116 MW PP (Anlima En	HFO (IPP)	6x21.06	116	116	0	0	116	116	0	0
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>973</b>	<b>1086</b>	<b>1583</b>	<b>1613</b>	<b>200</b>	<b>360</b>
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	70	80	135	65	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	80	80	0	49	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	50	120	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	20	26	26	25	Gas Shortage
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+175	221	221	207	200	225	225	0	0
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	305	280	350	350	0	0
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	300	280	350	350	0	0
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	35	30	30	0	0
65	Ashuganj 195MW PP (APSCL-Unite)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	0	50	0	0
69	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	81	100	200	200	0	0
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22	0	0
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11	0	0
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33	0	0
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	52	52	0	0
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	20	20	20	0	0
76	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	86x1.4+84x1.51+16x1.06	200	200	50	204	100	200	0	0
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	100	114	114	114	0	0
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	113	113	113	113	0	0
**	Impport (Tripura)	India		160	160	146	162	151	168	0	0
	Bhairab 54.5 MW	HFO (IPP)				0	0	0	0	0	0
<b>Cumilla Zone Total</b>				<b>3040</b>	<b>2980</b>	<b>1596</b>	<b>1837</b>	<b>1935</b>	<b>2227</b>	<b>661</b>	<b>163</b>
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	103	106	120	120	96	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22	0	0
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	73	77	77	0	0
82	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	16	115	115	115	0	0
83	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	180	191	200	200	0	0
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0	0	0
85	Sulakhai 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0	0	0
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	24	25	22	22	0	0
<b>Mymensingh Zone Total</b>				<b></b>							

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.03.21 (Yesterday)		25.03.21 (Today)		24.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	44	44			GT-1 Load gear problem	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	30	30	30			GT-4 Shaft Problem	
89	Fenchugonj 51 MW PP (Barakatulle)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021	
91	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	130	130				
92	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0			Under maint.	
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	165	163	170	170				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	73	80	81	81				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	30	104	105	150			Water Problem	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	0	20	20				
98	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020	
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	341	341				
102	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	241	241	250	250	159		Gas Shortage	
103	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	393	310	400	400	73		Gas Shortage	
	Shahjibazar 100 MW GTPP	Gas (PDB)				0	0	0	0			On Test	
	<b>Sylhet Zone Total</b>			<b>2416</b>	<b>2371</b>	<b>1551</b>	<b>1500</b>	<b>1659</b>	<b>1704</b>	<b>159</b>	<b>280</b>		
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	345	225	280	280	185		Gas Shortage	
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	9	25	25				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	83	99	99				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
111	Noapara 40 MW PP (Kharjahan AII)	HFO (QRPP)	5x8.5	40	40	33	33	40	40				
112	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	90	95	90	95				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC) India			1000	1000	711	711	727	727				
	<b>Khulna Zone Total</b>			<b>2288</b>	<b>2284</b>	<b>1262</b>	<b>1256</b>	<b>1471</b>	<b>1762</b>	<b>185</b>	<b>0</b>		
114	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	80	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	34	25	25				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	68	69	70	70			GT-2 & STG Under maint.	
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	93	96	95	95				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	420	610	620	620				
119	Potashali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	150	150				
	Bhola Nutan Bidout BD LTD	Gas/HSD (IPP)				24	60	105	105				
	<b>Banshal Zone Total</b>			<b>1826</b>	<b>1826</b>	<b>626</b>	<b>966</b>	<b>1175</b>	<b>1175</b>	<b>0</b>	<b>125</b>		
120	a) Baghabani 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71			Gas Shortage	
	b) Baghabani 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	100			Gas Shortage	
121	Baghabani 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	47	43	50	50				
122	Baghabani 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	200	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	12	28	40	40				
124	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42				
125	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	8	98	100	100				
126	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	50	50				
127	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	43	50	50				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	34				
129	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
130	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	190	183	200	200				
131	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	200	187	200	200				
132	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	415	401	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	21	22	22				
134	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020	
135	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
136	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113				
	<b>Rajshahi Zone Total</b>			<b>2193</b>	<b>2183</b>	<b>1225</b>	<b>1557</b>	<b>1643</b>	<b>1677</b>	<b>381</b>	<b>0</b>		
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	149	150	150	125		Coal Shortage	
141	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	12	10	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	93	113	113	113				
143	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	9	0	0				
144	Majpara, Tatala 8 MW Solar PP (Sympha Po)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
	<b>Rangpur Zone Total</b>			<b>685</b>	<b>605</b>	<b>243</b>	<b>283</b>	<b>281</b>	<b>273</b>	<b>295</b>	<b>0</b>		
	<b>Sub-total: Plants in operation</b>			<b>21778</b>	<b>21312</b>	<b>11126.0</b>	<b>12790</b>	<b>14129</b>	<b>15061</b>	<b>2796</b>	<b>1863</b>		
	<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>					<b>10548</b>	<b>12125</b>	<b>13394</b>	<b>14278</b>				
<b>(B) Contract expired power plants</b>													
	Sub-Total: Plants under long term maintenance			0	0	0	0	0	0	0	0		
	<b>Gross Total</b>			<b>21778</b>	<b>21312</b>	<b>11126</b>	<b>12790</b>	<b>14129</b>	<b>15061</b>	<b>2796</b>	<b>1863</b>		
<b>(C) Actual data of 24.03.21 (Yesterday) Wednesday :</b>													
01.	Max. Demand (Generation end)			12790.00	MW, at = 21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand (Sub-station end)			12125.00	MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)			12790.00	MW, at = 21:00 hrs	Dhaka	4324	4324	0	Mymensingh	1016	1016	0
04.	Minimum Generation (Generation end)			9488.00	MW, at = 6:00 hrs	Chattoogram	1247	1247	0	Sylhet	469	469	0
05.	Day-peak Generation (Generation end)			11126.00	MW, at = 12:00 hrs	Khulna	1483	1483	0	Barishal	333	333	0
06.	Evening-peak Generation (Generation end)			12790.00	MW, at = 21:00 hrs	Rajshahi	1319	1319	0	Rangpur	744	744	0
07.	Evening Peak Load-shed (Sub-station end)			0.00	MW, at = 21:00 hrs	Cumilla	1190	1190	0				
08.	Minimum Generation Forecast up to 8:00 hrs.			9560.00	MW, at = 5:00 hrs					Total	12125	12125	0
09.	Generation shortfall at evening peak due to :					13.	Fuel cost :	(a) Gas = 145281700 Taka	(c) Coal = 76072076 Taka				
	a) Gas limitation			2341	MW		(b) Oil = 742308766 Taka	Total = 963662543 Taka					
	d) Coal supply Limitation			295	MW								
	b) Low water level in Kaptai lake			160	MW								
	c) Plants under shut down/ maintenance			1863	MW								
10.	Total Energy (Generation + India Import)			266.76	MKWh	14.	Maximum Temperature in Dhaka was :	37.6° C					
	By Gas = 136.086 MKWh					15.	Export through East-West interconnections :						
	By Coal = 16.464 MKWh						At evening peak-hour	-25	MW, at 21:00 hrs				
	By Solar = 0.556 MKWh						Maximum	-40	MW, at 22:00 hrs				
11.	Total Gas Supplied			1106.60	MMCFD		Energy	0.035	MKWh				
<b>(D) Forecast of 25.03.21 (Today) Thursday :</b>													
01.	Maximum Demand			12800	MW (Generation end)	04.	Maximum Load-shed	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation			15061	MW (Generation end)	05.	Total Generation	266.97	MKWh				
03.	Maximum Shortage			-2261	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	39.8° C					

\* Captive Power \*\* Imported Power  
#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Faozul Islam Shaker)  
Deputy Secretary, Generation