

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : **8-Apr-21**

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Enerov	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
	Ghorasal Repowered CCPP Unit-3	PDB	1'210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1'210	190	170	4000500	Gas shortage
2	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	300	7224300	Machine problem
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	103	2351227	
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	272	969730	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	118	3910000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	320	7067550	Gas shortage
9	Meghnaghat 100 MW (IEL)	IPP	12'8.9	100	100	1053120	
10	Meghnaghat CCPP(Summit)	QRPP	2'110+1'110	305	270	4945251	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6'17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	55	1324584	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	60	377134	Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	391464	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	175	3833000	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	92	1197120	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+1'118	335	223	5154511	Gas shortage
19	Gagajpur 102 MW PP (Digital Power)	IPP	12'8.924	102	102	1200660	
20	Katpothi 52 MW PP (Sinha)	IPP	7'7.9	51	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	1311840	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	150	1204320	
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	1090557	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	1256035	
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	108	0	0	Engine problem
26	Summit Power (Madhabad+Ashulla)	SIPP, REB	3'3.67+4'8.73	80	53	1181940	Engine problem
27	Siliana 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	664600	
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	593700	Engine problem
29	Gazipur 52 MW PP	IPP	6'8.9	52	51	683552	
30	Tongi 80 MW GTPP	PDB	1'105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	283	2431308	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	53	44782	Low demand
33	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve.
34	Aurahat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3097440	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	2209200	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	104	2527680	
38	Manikgonj 162MW PP(MPL)	IPP	9'18	162	162	2125440	
	Spectra Solar Plant Ltd.	IPP	35	35	0	152145	
	Dhaka area Total			5829	3714	65584990	
39	Chattogram TPP-1	PDB	1'210	180	0	0	Gas shortage.
	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
	Raozan 25 MW PP	IPP	3'8.9	25	25	589138	
41	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy Ltd	20	20	0	111375	
42	Patanga 50MW PP (Baraka)	IPP	8'6.98	50	49	596160	
43	Kapali Hydro Unit-1,2,3,4,5	PDB	2'40+3'50	230	100	2474429	Unit-2 under maint
44	Sikalbaha 225MW	PDB	1'150+1'175	225	203	4793577	FGMO
45	Sikalbaha Peaking GT	PDB	1'150	150	130	3030676	Machine problem
46	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	0	Reserve.
47	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	0	
48	Dohazari-Kalish 100 MW Peaking	PDB	6'17	102	83	373962	Engine problem
49	Jullah 100 MW Unit-1 (Acom)	QRPP	8'13.45	100	100	1292400	
50	Jullah 100 MW Unit-3 (Acom)	IPP	0	100	100	2278980	
51	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	20	466416	
*	Malancha, Ctg. EPZ (United)		5'8.73+3'9.34	0	20	507360	
52	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	87	558720	Engine problem
53	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	30121	
54	Anwara 300 MW PP (United)	IPP	300 MW	300	65	516873	Transformer O/L
55	Jodiak Power	IPP	3'18.55+1'3.6	54	54	1273169	
56	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
57	Jullah unit-2 (Acom)	IPP	8'13.6	100	100	2344320	
	Animia Energy Ltd.	IPP	6'21.2	116	99	1873036	Engine problem
	Chattogram area Total			2382	1235	23109512	
58	Ashuganj TPP Unit- 3	APSCL	1'150	135	80	2046402	Gas shortage
	Ashuganj TPP Unit- 4	APSCL	1'150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Gas shortage
59	Ashuganj 225 MW CCPP	APSCL	1'142+1'75	214	214	4840000	
60	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	290	7028000	FGMO
61	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	300	6974000	FGMO
62	Ashuganj 50 MW PP	APSCL	14'3.98	45	32	591480	Engine problem
63	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	52	1108800	
64	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	16	317818	Gas shortage
65	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	0	0	Line fault
66	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	0	0	Line fault
67	Tilas 50 MW Peaking PP	PDB	6'8.92	52	50	166792	
68	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	89	2058950	Gas shortage
69	Chandpur 200MW (Desh energy)	IPP	0	200	155	4018080	Engine problem
70	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	457848	
71	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	243000	
**	Impogrt (Tripura)	Imported power	0	160	164	3283200	
72	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	818300	
73	Jangalia 52 MW PP (Lakdanari)	IPP	6'8.92	52	52	515726	
74	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	17	436800	Engine problem
75	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	50	39168	Low demand
76	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	654360	
77	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	113	2035320	
	Bharob 54.5 MW	IPP	3'18.2	54	37	885240	Engine problem
	Cumilla Area Total			3034	1885	38519284	
78	RPCL 210MW CCPP	IPP	4'35+1'70	202	104	2715720	Gas shortage
79	Tangali 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	17	349704	Engine problem
80	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	32	681600	Engine problem
81	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	8600	
82	Mymensingh 200 MW PP (United)	IPP	200	200	180	4197600	Engine problem
83	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2206800	
84	Subakhali 50 MW Solar PP	IPP	50	50	0	232760	
85	Tangali Path Power Gen 22 MW	IPP	4'6.7	22	24	571680	
	Mymensingh Area Total			709	472	10964464	
86	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	43	108000	Machine problem
87	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	43	1023000	Machine problem
88	Kushira 163 MW CCPP (KP)	IPP	1'109+1'54	163	163	3547227	
89	Shajibazar 330 MW CCPP	PDB	3'110	330	334	7314000	
90	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1229400	
91	Fenchugonj 44MW (Energyprima)	RPP	12'3.3+5'2	0	0	0	Contract Expired
92	Hobgaj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	264000	
93	Shajibazar GTPP Unit 8 & 9	PDB	2'135	86	33	774816	GT-9 Under maint.
94	Shajibazar 88MW PP (Shajibazar)	RPP	32'2.90	86	78	1821120	Engine problem
	Shajibazar 100 MW GTPP	PDB	1'100	100	0	0	Under Shut down
95	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	176	4192350	Machine problem
96	Sylhet 20 MW GTPP	PDB	1'20	20	19	418000	
97	Sylhet 50MW PP (EPL)	RPP	27'2	0	0	0	Contract Expired
98	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	378912	Engine problem
99	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	280	7328500	FGMO
100	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	305	7895000	FGMO
101	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	9	194220	
	Bibiyana South 400 MW	PDB	400 MW	383	340	8658400	
	Sylhet Area Total			2377	1903	46046945	
102	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2'500	1000	779	18240727	
103	Khulina 115 PP MW (KPCL-2)	QRPP	7'17	115	99	2194560	Engine problem
104	Faridpur 50 MW Peaking PP	PDB	8'6.89	54	18	99360	Engine problem
105	Khulina 225 MW CCPP	NWPGCL	1'150+1'75	230	0	0	Reserve.
106	Gopalganj 100 MW Peaking PP	PDB	16'8.98	100	0	0	Reserve.
107	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	390	4916736	Gas shortage
108	Noapara 40 MW PP (Khanijahan Ali)	QRPP	5'8.5	40	22	284625	Engine problem
109	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	100	491520	
110	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	53	1256640	Low demand
111	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
	Khulina Area Total			2284	1271	27484168	
112	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	80	503904	High voltage.
113	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	29	535182	
114	Bhola 225 MW CCPP	PDB	2'630+1'168	194	84	1605000	Machine problem
115	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	95	1804262	
116	Payra 1320 MW	BCPCL	2'622	1244	580	13021700	
	Bhola Nutan Biddut BD LTD	IPP	220	0	0	452891	On Test
	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	0	Reserve.
	Barisal Area Total			1826	848	17922939	
117	Baghabari 71 MW GTPP	PDB	1'71	71	0	0	Gas shortage
	Baghabari 100 MW GTPP	PDB	1'100	100	0	0	Gas shortage.
118	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	43	243255	
119	Bera 70 MW Peaking PP	PDB	9'8.29	71	35	126642	Engine problem
120	Annura 50 MW PP(Sinha)	QRPP	0'77.79	50	0	0	Fuel shortage
121	Katakahali 50 MW PP (Northern)	QRPP	6'8.9	50	0	0	Fuel shortage
122	Katakahali 50 MW Peaking PP	PDB	6'8.7	50	31	92172	Engine problem
123	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'75	210	0	0	Gas shortage
124	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'75	220	147	3862182	Gas shortage
125	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	188	4459491	Gas shortage
126	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1'282+1'132	414	421	9194100	
127	Sariatani 50 MW Peaking PP	PDB	6'8.7	50	32	144411	Engine problem
128	Bogura 22 MW PP (GSB)	RPP	6'1.95	22	22	499440	
129	Bogura 20 MW PP (Energyprima)	RPP	5'3.3+5'2	0	0	0	Contract Expired
130	Ullapara 11 MW PP (Summit)	SIPP, REB	4'2.90	11	5	129888	Engine problem
131	Natore 52 MW PP (Rajlanka)	IPP	6'8.92	52	52	583200	
132	Chapainawabganj 100 MW Peaking PP	PDB	12'8.924	104	98	589852	
133	Baghabari 200 MW PP (Paramount)	IPP	200 MW	200	0	0	Reserve.
134	Bagura 113 MW PP (Confidence)-2	IPP	113 MW	113	94	2274912	Engine problem
135	Confidence Power Bogura Unit-1 113 MW	IPP	6'18.55	113	90	2143392	Engine problem