

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 10-Apr-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Enerov Generated	Remarks
	Ghorasal Repowered CAPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CAPP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	300	7086091	Machine problem
3	Ghorasal 78.5 MW PP(MAX)	ORPP	0	0	240	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	103	2369000	
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	0	0	Under S/D due to dust in the gas line.
7	Haripur 360MW CAPP(HPL)	IPP	1*235+1*125	360	234	6540000	Gas shortage
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	300	6914350	Gas shortage
9	Meghnaghat 100 MW(LEL)	QRPP	12*8.9	100	100	1295040	
10	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	990255	
11	Madaniganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
12	Madaniganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	55	1228556	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	60	362461	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	415764	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	87	1936000	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	100	1515840	
18	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	0	1004891	ST under maint.
19	Gaighataj 102 MW PP (Digital Power)	IPP	12*8.924	102	102	1406736	
20	Katpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
21	Karnalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	1227600	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	1272960	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1178138	
24	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	1181805	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Engine problem
26	Summit Power,(Madhabdi+Ashula)	SIPP, REB	3*3.67+4*8.73	80	51	1110540	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	779300	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	574000	Engine problem
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	465600	
30	Tongi 80 MW GTPP	PDB	1* 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	269	3091199	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	300	1194578	
33	Bramhanganj 100 MW PP (Aggreko)	IPP	100	100	100	429111	
34	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	100	503839	
35	Kodda 148 MW PP Unit-1 (Summit)	IPP	149	149	149	3151580	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	974400	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	104	2465280	
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	2204640	
	Spectra Solar Plant Ltd.	IPP	35	35	0	49663	
Dhaka area Total				5829	3228	54919217	
39	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.
40	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
41	Raczan 25 MW PP	IPP	3*8.9	25	25	330033	
42	Teknaf 20MW PP (Solartech)	Teknaf Solartech Ener	20	20	0	130140	
43	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	50	868800	
44	Kapta Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1642876	Unit-2 under maint
45	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4848403	FGMO
46	Sikalbaha Peaking GT	PDB	1*150	150	130	3138668	Machine problem
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	0	Reserve.
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	
49	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	83	667856	Engine problem
50	Julidah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	100	1306200	
51	Julidah 100 MW PP Unit-3 (Acom)	IPP	100	100	100	2413440	
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	456144	
53	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	21	443040	
54	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	91	1680960	Engine problem
55	Kapta 7 MW Solar PP	PDB	7.4 MW	7	0	31799	
56	Anwara 300 MW PP (United)	IPP	300 MW	300	105	715091	Transformer O/L
57	Jodioc Power	IPP	3*18.55+1*3.6	54	54	909658	
58	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
59	Julidah unit-2 (Acom)	IPP	8*13.6	100	100	2414400	
60	Anima Energy Ltd.	IPP	6*21.2	116	57	1188055	Engine problem
Chattogram area Total				2382	1209	23176363	
61	Ashuganj TPP Unit- 3	APSCCL	1*150	135	135	2619790	Gas shortage
62	Ashuganj TPP Unit- 4	APSCCL	1*150	129	0	0	Gas shortage
63	Ashuganj TPP Unit- 5	APSCCL	1*150	134	0	0	Gas shortage
64	Ashuganj 225 MW CAPP	APSCCL	1*142+1*75	221	205	4698000	
65	Ashuganj 450 MW CAPP(North)	APSCCL	1*360	360	305	7352000	FGMO
66	Ashuganj 450 MW CAPP(South)	APSCCL	1*360	360	295	7298000	FGMO
67	Ashuganj 50 MW PP	APSCCL	14*3.968	45	26	573696	Engine problem
68	Ashuganj 55 MW PP (Precision)	IPP	15*4	55	10	680720	
69	Ashuganj 195MW PP (APSCCL-United)	IPP	20*9.73+1*16	195	8	200727	Gas shortage
70	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0	Line fault
71	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	0	Line fault
72	Titas 50 MW Peaking PP	PDB	6*8.92	52	50	256704	
73	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	0	0	Under maint.
74	Chandpur 200MW (Desh energy)	IPP	0	200	172	4036320	
75	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	426024	
76	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	251620	
77	Impoted (Tripura)	Imported power	160	160	148	3355200	
78	Jangala 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	788500	
79	Jangala 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	956230	
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	478900	
81	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	200	906240	
82	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	632700	
83	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	113	2525880	
84	Bharob 54.5 MW	IPP	3*18.2	54	18	443880	Engine problem
Cumilla Area Total				3034	1934	3849331	
85	RPCL 210MW CAPP	IPP	4*36+1*70	202	155	3492580	Gas shortage
86	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	358524	Engine problem
87	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	24	409060	Engine problem
88	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11150	
89	Mymensingh 200 MW PP (United)	IPP	200	200	187	3760800	Engine problem
90	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1526400	
91	Sutakhal 50 MW Solar PP	IPP	50	50	0	258680	
92	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	563760	
Mymensingh Area Total				709	522	10452954	
93	Fenchuganj CAPP Phase-1	PDB	2*32+1*33	70	42	1011000	Machine problem
94	Fenchuganj CAPP Phase-2	PDB	2*35+1*35	90	43	1018080	Machine problem
95	Kushlari 163 MW CAPP (KP)	IPP	1*109+1*54	163	163	3470073	
96	Shajibazar 330 MW CAPP	PDB	3*110	330	327	7319000	
97	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	50	741600	
98	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
99	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	0	84000	
100	Shajibazar GTPP Unit- 8 & 9	PDB	2*35	66	32	705972	GT-8 Under maint.
101	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	78	1847040	Under Shut down
102	Shajibazar 100 MW GTPP	PDB	1*100	100	0	0	Machine problem
103	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	170	2778070	
104	Sylhet 20 MW GTPP	PDB	1*20	20	18	411000	
105	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
106	Shahjanulla 25 MW PP	SIPP, REB	3*9.34	25	16	370656	Engine problem
107	Bibiana-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	300	7240000	FGMO
108	Bibiana-III 400 MW CAPP	PDB	400 MW	400	368	8077000	FGMO
109	Sylhet (10MW PP (Desh)	RPP	6*1.95	10	7	168480	
110	Bibiana South 400 MW	PDB	400 MW	383	342	8485500	
Sylhet Area Total				2377	1956	43727471	
111	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
112	Bheramara (HVDC)	Imported power	2*500	1000	833	18376727	
113	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	99	2034240	Engine problem
114	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	14	63800	Engine problem
115	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
116	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
117	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	265	6206272	Gas shortage.
118	Nosapara 40 MW PP (Khanjahan Ali)	QRPP	8*5	40	33	228000	Engine problem
119	Nosapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100	579690	
120	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	93	1492800	Engine problem
121	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1437	30978799	
122	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	866784	
123	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	34	616194	
124	Bhola 225 MW CAPP	PDB	2*63+1*68	194	68	1557000	Machine problem
125	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	98	1980029	
126	Payra 1320 MW	BCPCL	2*622	1244	580	1225000	
127	Bhola Nutan Biddut BD LTD	IPP	220	0	0	0	On Test
128	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	64	212400	Low demand
Barisal Area Total				1826	954	18163407	
129	Baghabari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage
130	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage.
131	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	289856	
132	Bera 70 MW						