

Date : 11-Apr-21							Page -2
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
	Ghorasal Repowered CCPP Unit-3	PDB	1'210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1'210	160	0	0	Under maint.
	Ghorasal TTP Unit-5	PDB	1'210	190	0	0	Gas shortage
2	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	300	7128327	Machine problem
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	103	2385727	
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	25	0	Under SID due to dust in the gas line
7	Haripur 360MW CCPP(HRL)	IPP	1'235+1'125	360	234	6112000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	300	7006150	Gas shortage
9	Meghnaghat 100 MW(EL)	QRPP	12'8.9	100	100	1972800	
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	305	0	0	
11	Madanganj 102 PP(Summit)	QRPP	6'17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	1317234	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	73	827172	Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	479520	
15	210 MW Siddhirgonj TTP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	1119000	Gas shortage
17	Siddhirgonj 100 PP(Dutah Bangla)	QRPP	12'8.9	100	100	2411520	
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+1'118	335	0	0	Gas line fault.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	102	1846224	
20	Kalpotti 52 MW PP (Sinha)	IPP	7'7.9	51	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	1296360	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	150	2905440	
23	Maniganj 55 MW PP (Northern)	IPP	3'19.3	55	55	1323093	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	1326975	
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	108	0	0	Engine problem
26	Summit Power, (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	54	1238640	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	793400	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	614700	Engine problem
29	Gazipur 52 MW PP	IPP	8'8.9	52	51	704540	
30	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	282	5324289	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	71	303309	Low demand
33	Bramhanganj 100 MW PP (Aggreko)	IPP	100	100	100	390535	
34	Aurahat 100 MW PP (Aggreko)	IPP	0.85'23+0.85'91	100	100	492773	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3603600	
36	Gazipur 100 MW PP	RPCL	100 MW PP	105	105	1729200	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	104	2620800	
38	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	162	3667680	
	Spectra Solar Plant Ltd.	IPP	35	35	0	22615	
<b>Dhaka Area Total</b>				<b>6829</b>	<b>2833</b>	<b>6115857</b>	
39	Chattogram TTP-1	PDB	1'210	180	0	0	Gas shortage
40	Chattogram TTP-2	PDB	1'210	180	0	0	Gas shortage
41	Raozan 25 MW PP	IPP	3'8.9	25	25	623311	
42	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energ	20	20	0	115020	
43	Patenga 50MW PP (Baraka)	IPP	6'6.98	50	50	1108800	
44	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2'135+3'50	230	71	1679535	Unit-2 under maint
45	Sikalbaha 225MW	PDB	1'150+1'175	225	151	3557339	FGMO
46	Sikalbaha Peaking GT	PDB	1'150	150	130	3096192	
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	0	Reserve.
48	Halhazan 100 MW peaking PP	PDB	11'8.9	98	0	0	
49	Dahazari-Kalaha 100 MW Peaking	PDB	8'17	100	100	91828	Engine problem
50	Juldah 100 MW Unit-1 (Acom)	QRPP	8'13.45	100	100	2059080	
51	Juldah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	2383680	
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	20	432144	
	Malancha_Clg_EP2 (United)		5'8.73+3'9.34	0	21	443040	
53	Chattogram 108 MW PP (ECPV)	IPP	167	108	97	1235520	
54	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	2958	
55	Anwara 300 MW PP (Unitec)	IPP	300 MW	300	144	2589418	Transformer OIL
56	Jodiac Power	IPP	3'18.55+1'3.6	54	54	1273675	
57	Kamaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
58	Juldah unit-2 (Acom)	IPP	8'13.6	100	100	2385600	
	Amrta Energy Ltd.	IPP	6'21.2	116	57	1368709	Engine problem
<b>Chattogram Area Total</b>				<b>2382</b>	<b>1263</b>	<b>25310659</b>	
59	Ashuganj TTP Unit-3	APSCL	1'150	135	135	3252038	
60	Ashuganj TTP Unit-4	APSCL	1'150	129	0	0	Gas shortage
61	Ashuganj TTP Unit-5	APSCL	1'150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	211	5134000	
63	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	320	7828500	FGMO
64	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	305	7223000	FGMO
65	Ashuganj 50 MW PP	APSCL	14'3.968	45	26	573768	Engine problem
66	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	47	916800	
67	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	8	117090	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	0	0	Line fault
69	Ashuganj 150 MW PP (Midland)	IPP	23'7.015	150	0	0	Line fault
70	Titas 50 MW Peaking PP	PDB	8'8.92	52	50	530288	
71	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	50	749910	
72	Chandpur 200MW (Desh energy)	IPP	0	200	160	2843040	Engine problem
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	442836	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	245340	
75	Imphooli (Tribal Power)	Imported power	0	162	162	3567360	
76	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	808100	
77	Jangalia 52 MW PP (Lakdanavi)	IPP	6'8.92	52	52	893830	
78	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	20	465910	
79	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	150	629184	Low demand
80	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	1345760	
81	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	113	2713200	
82	Bhairab 54.5 MW	IPP	3'18.2	54	0	208080	Engine problem
<b>Cumilla Area Total</b>				<b>3034</b>	<b>1987</b>	<b>40530834</b>	
83	RPCL 210MW CCPP	IPP	4'35+1'70	202	141	3312880	Gas shortage
84	Tangal 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	17	264132	Engine problem
85	Jamalpur 95 MW PP(powerpac)	IPP	12'8.924	95	24	450000	Engine problem
86	Sariakhat 3 MW Solar Plant	IPP	1'3	0	0	13200	
87	Mymensingh 200 MW PP (Unitec)	IPP	200	200	190	4351200	Engine problem
88	Jamalpur 115 MW PP (Unitec)	IPP	115 MW	115	115	2464800	
89	Sutiakhal 50 MW Solar PP	IPP	50	50	0	291640	
90	Tangal Palli Power Gen 22 MW	IPP	4'8.7	22	24	559440	
<b>Mymensingh Area Total</b>				<b>799</b>	<b>511</b>	<b>11713292</b>	
91	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	42	1007600	Machine problem
92	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	43	1027920	Machine problem
93	Kushihara 163 MW CCPP (KP)	IPP	1'109+1'54	163	163	3588627	
94	Shajibazar 330 MW CCPP	PDB	3'110	330	334	7514000	
95	Fenchugonj 51 MW PP (Barakattallah)	RPP	19'2.90	51	50	1165200	
96	Fenchugonj 440 MW (Energyprima)	RPP	12'3.3+9'2	0	0	0	Contract Expired
97	Hobiganj 11MW PP Confidence-E	SIPP, REB	11	11	11	166500	
98	Shajibazar GTPP Unit- 8 & 9	PDB	2'35	66	32	735888	GT-8 Under maint.
99	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	78	1758720	Engine problem
100	Shajibazar 100 MW GTPP	PDB	1'100	100	100	0	Under Shut down
101	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	217	4463180	
102	Sylhet 20 MW GTPP	PDB	1'20	18	18	409000	
103	Sylhet 50MW PP (EPL)	RPP	2'72	0	0	0	Contract Expired
104	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	355368	Engine problem
105	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	315	7431550	FGMO
106	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	372	9305000	FGMO
107	Sylhet 10MW PP (Desh)	RPP	8'1.95	8	10	152540	
108	Bibiyana South 400 MW	PDB	400 MW	383	370	8663000	
<b>Sylhet Area Total</b>				<b>2377</b>	<b>2069</b>	<b>47761593</b>	
109	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Reserve.
110	Bheramara (HVDC )	Imported power	2'500	1000	839	20240000	
111	Khulna 115 PP MW (KPCL-2)	QRPP	7'17	115	83	2142720	Engine problem
112	Fairpur 50 MW Peaking PP	PDB	8'6.89	50	20	144480	Engine problem
113	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	0	Reserve.
114	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve.
115	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	285	6624000	Gas shortage
116	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5'8.5	40	33	429000	Engine problem
117	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	100	789160	
118	Rupsha 105 MW PP (Oron/rupsha)	IPP	6'18.445	105	92	1927680	Engine problem
119	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
<b>Khulna Area Total</b>				<b>2284</b>	<b>1452</b>	<b>32296040</b>	
120	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	110	765792	
121	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	34	632110	
122	Bhola 225 MW CCPP	PDB	2'63+1'88	194	67	1595000	Machine problem
123	Bhola 95 MW PP (Aggreko)-2	QRPP	96'1.10	97	95	4399000	
124	Payra 1320 MW	BCPCL	2'622	1244	580	13727000	
125	Bhola Nutan Biddut BD LTD	IPP	220	0	0	0	On Test
126	Unitec Payra Power Ltd.	IPP	8'18.5+1'9.5	150	35	274800	Low demand
<b>Barisal Area Total</b>				<b>1826</b>	<b>923</b>	<b>19303702</b>	
127	Baghabari 71 MW GTPP	PDB	1'71	71	0	0	Gas shortage
128	Baghabari 100 MW GTPP	PDB	1'100	100	0	0	Gas shortage.
129	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	50	600752	
130	Bera 70 MW Peaking PP	PDB	9'8.29	71	35	341583	Engine problem