

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2021		Day : Wednesday				Date : 14.04.21					
Probable Maximum Demand :		13200 MW		Yesterday = 80.92 ft		Today = 80.64 ft		Probable Maximum Generation : 15498 MW		Rule Curve = 85.80 ft.	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	13.04.21 (Yesterday)		14.04.21 (Today)		13.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	a) Ghorasal Repowered CCGP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering
	b) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.
2	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300		
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	97	103	103	103		
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
5	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
6	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	180	160	280	280	200	Gas Shortage
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	260	260	260	260	190	Gas Shortage
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Dirty in gas
10	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	180	180	180	180	30	Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	211	221	220	220	114	ST under maint.
12	Siddhirgonj 100 PP/Dutch Bangla	HFO (QRPP)	12x8.9	100	100	100	96	100	100		
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	295	240	235	235	65	dirty in gas
14	Meghnaghat 100 MW(LEL)	HFO (QRPP)	12x8.9	100	100	93	100	100	100		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	50	55	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	46	82	100	100		
17	Gagragar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	102	102	100	100		
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.50	22	22	22	22	22	22		
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	53	52	58	58		
20	Masna 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.71	33	33	28	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.71	33	33	25	33	25	25		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	38	50	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	132	133	149	149		
25	Kalipoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	232	268	300	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	131	149	149	149		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	256	100	300		
30	Bramhangan 100 MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	50	100		
31	Aurahi 100MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	101	100	100		
32	Nabaganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	55	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	162	162	162		
37	Manikganj 35MW Solar PP (Inspect	Solar (IPP)	1x35	35	35	31	0	30	0		
Dhaka Zone Total				6026	5829	3088	3581	3636	3856	917	874
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	45	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	0	0	50	100		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130		
46	Shikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	40	230	230	230		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	249	125	300	300		
48	Judah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	90	98	100	100		
49	Judah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
50	Dohazari - Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	83	82	85		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.50	22	22	17	20	22	22		
*	Malancha Ctg.EPZ (Unite)	Gas	5x8.73+3x9.34			2	31	25	35		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	57	84	100	100		
54	Sikalbaha 54 MW Power Plant(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
56	Judah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
57	Chattogram 116 MW PP (Anilima En	HFO (IPP)	6x21.06	116	116	57	57	60	60		
Chattogram Zone Total				2442	2382	1025	1257	1633	1671	160	360
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	100	135	135	35	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+17x5	221	221	188	208	225	225		
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	320	300	300	300		
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	305	300	360	360		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	47	50	50	50		
64	Ashuganj 199MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	0	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	0	0	0	0	51	Gas Shortage
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	51	50	50	112	Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	154	154	170	170		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.50	22	22	21	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x4.46+115x1.54+106	200	200	0	150	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	114	114	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	110	113	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	37	37	36	36		
**	Impoport (Tripura)	India		160	160	146	170	157	188		
Cumilla Zone Total				3094	3034	1646	1969	1982	2163	536	112
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	99	100	150	150	102	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.50	22	22	17	17	17	17		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	41	57	56	56		
82	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
83	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	160	180	200	200		
84	Saishaban 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	49	0	50	0	0		
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	21	24	22	22		
Mymensingh Zone Total				717	709	504	493	612	560	102	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.04.21 (Yesterday)		14.04.21 (Today)		13.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42	28	GT-1 Load gear problem		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43	47	Under maint.		
89	Fenchugonj 51 MW PP (Barakatulle)	Gas (RPP)	19x2.90	51	51	27	50	51	51				
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	32	33	33	34	Under maint.		
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	310	326	330	330				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	69	78	75	78				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x69	231	231	164	163	200	220				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	300	341	341				
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	345	368	400	400	32	Gas Shortage		
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	331	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1850	1896	2133	2156	32	109	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	315	250	400	400	160	Gas Shortage		
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	19	20	20				
106	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	99	99	99				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	32	33	32	33				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	91	92	92	92				
112	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	769	843	858	858				
Khulna Zone Total					2288	2284	1294	1436	1711	1998	160	0	
113	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110				
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	34	33	33				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	64	67	70	70	127	GT-2 & STG Under maint.		
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x196	95	95	58	96	95	95				
117	Payra 1320 MW TPP	Coal (BCFCL)	2x622	1244	1244	500	610	622	622				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	150	150				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				4	4	0	0				
Barishal Zone Total					1826	1826	644	975	1080	1080	0	127	
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	10	43	50	50				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	42	35	35				
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	96	100	100				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	30	31				
126	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
127	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	33				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	80	120	120	130	Gas Shortage		
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150+1x75	220	220	212	174	180	200				
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	140	176	200	200				
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	372	394	400	400				
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22				
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	43	43	43				
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
Rajshahi Zone Total					2173	2173	1035	1363	1617	1671	301	0	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	71	75	70	70	10	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage		
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124	Coal Shortage		
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	10	10				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	34	113	113	113				
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara, Tatala 8 MW Solar PP (Synspa Po)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	261	338	351	343	219	0	
Sub-total: Plants in operation					21673	21219	11347.0	13308	14755	15498	2427	1582	
Available Power at Sub-station end excluding PS auxiliary use and Transmission loss							10843	12717	14099	14810			
(B) Plants under long term maintenance/ contract expired													
143	Ghorashal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
144	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0	0	0	0	
Gross Total					21967	21219	11347	13308	14755	15498	2427	1582	
(C) Actual data of 13.04.21 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	: 13308.00 MW, at = 21:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 12717.00 MW, at = 21:00 hrs											
03.	Highest Generation (Generation end)	: 13308.00 MW, at = 21:00 hrs											
04.	Minimum Generation (Generation end)	: 10030.00 MW, at = 7:00 hrs											
05.	Day-peak Generation (Generation end)	: 11347.00 MW, at = 12:00 hrs											
06.	Evening-peak Generation (Generation end)	: 13308.00 MW, at = 21:00 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9531.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation	: 2048 MW											
	d) Coal supply Limitation	: 219 MW											
	b) Low water level in Kaplai lake	: 160 MW											
	c) Plants under shut down/ maintenance	: 1582 MW											
10.	Total Energy (Generation + India Import)	: 272.13 MKWh											
	By Gas =	141.417 MKWh	By Oil =	85.575 MKWh									
	By Coal =	19.806 MKWh	By Hydro =	1.676 MKWh									
	By Solar =	0.763 MKWh											
11.	Total Gas Supplied	: 1165.48 MMCFD											
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
	Dhaka	4246	4246	0	Mymensingh	1056	1056	0					
	Chattogram	1338	1338	0	Sylhet	493	493	0					
	Khulna	1639	1639	0	Barishal	383	383	0					
	Rajshahi	1428	1428	0	Rangpur	833	833	0					
	Cumilla	1301	1301	0									
	Total	12717	12717	0									
13.	Fuel cost :	(a) Gas = 152731068 Taka	(c) Coal = 93652596 Taka										
		(b) Oil = 651703522 Taka	Total = 890067187 Taka										
14.	Maximum Temperature in Dhaka was :	36.9° C											
15.	Export through East-West interconnections :												
	At evening peak-hour	: -390 MW, at 21:00 hrs											
	Maximum	: -440 MW, at 22:00 hrs											
	Energy	: 1.22 MKWh											
(D) Forecast of 14.04.21 (Today) Wednesday :													
01.	Maximum Demand	: 13200 MW (Generation end)											
02.	Maximum Generation	: 15498 MW (Generation end)											
03.	Maximum Shortage	: -2298 MW (Generation end)											
04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)											
05.	Total Generation	: 269.92 MKWh											
06.	Probable Max. Temperature in Dhaka	: 40.4° C											

* Captive Power ** Imported Power

#Remarks: Highest Generation 13377 MW on 12-04-2021 at 21:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation