

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2021		Day : Wednesday		Date : 21.04.21							
Probable Maximum Demand : 13500 MW		Yesterday = 78.92 ft		Today = 78.75 ft		Probable Maximum Generation : 15595 MW		Rule Curve = 84.20 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.04.21 (Yesterday)		21.04.21 (Today)		20.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	a) Ghorasal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering
	b) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190		
2	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	104	104	104		
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
5	Hanpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
6	Hanpur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	262	278	360	360	82	Gas Shortage
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	300	300	170	Gas Shortage
8	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Hanpur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Dirty in gas
10	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	95	180	120	150	30	Gas Shortage
11	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	207	204	220	220	131	ST Under maint.
12	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	90	100	100		
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	305	305	275	285	285	285	20	dirty in gas
14	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	35	100	100	100		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	100	80	100		
17	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	50	102	100	100		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.50	22	22	22	22	22	22		
19	Summit Power, (Madhabdi+Ashula)	Gas (SIIP, REB)	6x3.57+3x7.3	80	80	43	53	58	58		
20	Masna 33 MW PP(Summit)	Gas (SIIP, REB)	4x7.5	33	33	33	33	33	33		
21	Rupganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x7.5	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	50	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	75	101	105	105		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	149	149	149		
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalaghat 54 MW PP (Banco Energy)	Gas (IPP)	3x18.89	54	54	38	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	30	282	300	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
29	Keraniganj 300 MW PP (AR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
30	Branhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
31	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	52	100	100		
32	Nabaganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	35	54	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	55	55		
34	Bosila 108MW PP(EL)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	60	162	162	162		
37	Manikganj 35MW Solar PP (Inspect	Solar (IPP)	1x35	35	35	34	0	30	0		
Dhaka Zone Total				6026	5829	2356	3301	3625	3895	714	1086
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	35	35	35	195	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	0	30	50	100		
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130		
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	203	230	230		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	16	300	300		
48	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	92	100	100	100		
49	Juldah 100 MW Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	90	100	100		
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	83	83	83		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	21	21	22	22		
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			2	35	10	20		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	90	90	90		
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	51	110	110		
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
57	Chattogram 116 MW PP (Anlima En	HFO (IPP)	6x21.06	116	116	116	109	116	116		
Chattogram Zone Total				2442	2382	884	1214	1622	1657	195	360
58	a) Ashuganj TPP Unit-3	Gas (APSCCL)	1 x 150	150	135	80	135	100	135	0	Gas Shortage
	b) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	26	26	26		
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	205	209	225	225		
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	295	310	310	310		
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	340	325	340	340		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	154	55	55	20	52	50	55		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+116	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Line fault
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	89	89	90	90	74	ST Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	178	180	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	20	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
75	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	99x1.4+6x1.51+15x1.05	200	200	0	20	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	113	113	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	37	36	37	37		
**	Impoort (Tripura)	India		160	160	120	144	156	184		
Cumilla Zone Total				3094	3034	1600	1949	1987	2225	450	125
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	148	162	160	165		
80	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	19	19	20	20		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	50	74	74	74		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	13	115	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	189	182	200	200		
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	26	0	50	0		
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	18	18	22	22		
Mymensingh Zone Total				717	709	465	570	643	596	0	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.04.21 (Yesterday)		21.04.21 (Today)		20.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	39	40	43	43	30		GT-1 Load gear problem	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43	47		Under maint.	
89	Fenchugonj 51 MW PP (Barakatulle)	Gas (RPP)	19x2.90	51	51	48	50	51	51				
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	20	33	33	46		Under maint.	
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	328	334	330	330				
94	Shahjibazar 96MW PP (Shahjibazar)	Gas (RPP)	32x3.00	96	86	78	78	78	78				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x69	231	231	148	162	135	150				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	16	16				
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	341	341				
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	386	375	400	400				
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	400	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1934	2001	2072	2087	0	123	
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	385	380	400	400				
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	20	20	20				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	4	0	60	60				
107	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	99	99	99				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	33	32	33				
111	Rupsha 105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	53	92	93	93				
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	717	717	851	851				
Khulna Zone Total					2288	2284	1242	1441	1705	1992	0	0	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110				
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	34	33	33				
115	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	65	65	70	70	129		GT-2 & STG Under maint.	
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	82	82	95	95				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	420	540	622	622				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				107	110	109	110				
Barishal Zone Total					1826	1826	695	941	1189	1190	0	129	
119	a) Baghabani 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabani 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
120	Baghabani 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
121	Baghabani 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	40	35	40				
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	97	100	100				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31				
126	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	24	50	50				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	32				
128	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	100	128	0	0	82		Gas Shortage	
129	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	180	182	180	200				
130	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	196	190	200	200				
131	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	404	413	400	400				
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	22	22				
133	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	43	43				
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	95	113	113				
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113				
Rajshahi Zone Total					2173	2173	1150	1479	1547	1605	253	0	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	71	75	75	14		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	225	150	150	150	124		Coal Shortage	
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	10	10				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	112	111	113	113				
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara, Tatula 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	421	332	356	348	223	0	
Sub-total: Plants in operation					21673	21219	10747.0	13228	14746	15595	1835	1823	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							10306	12685	14140	14955			
(B) Plants under long term maintenance/ contract expired													
143	Ghorashal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
144	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0	0	0	0	
Gross Total					21967	21219	10747	13228	14746	15595	1835	1823	
(C) Actual data of 20.04.21 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	: 13228.00 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 12685.00 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 13296.00 MW, at = 22:00 hrs	Dhaka	4292	4292	0	Mymensingh	1101	1101	0			
04.	Minimum Generation (Generation end)	: 9565.00 MW, at = 7:00 hrs	Chattogram	1308	1308	0	Sylhet	501	501	0			
05.	Day-peak Generation (Generation end)	: 10747.00 MW, at = 12:00 hrs	Khulna	1608	1608	0	Barishal	378	378	0			
06.	Evening-peak Generation (Generation end)	: 13228.00 MW, at = 21:00 hrs	Rajshahi	1488	1488	0	Rangpur	726	726	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs	Cumilla	1283	1283	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10015.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :	:					Total	12685	12685	0			
a)	Gas limitation	: 1417 MW	13. Fuel cost :		(a) Gas = 161984376 Taka	(c) Coal = 89265298 Taka							
d)	Coal supply Limitation	: 223 MW			(b) Oil = 570824079 Taka	Total = 822073753 Taka							
b)	Low water level in Kaptai lake	: 195 MW											
c)	Plants under shut down/ maintenance	: 1823 MW	14. Maximum Temperature in Dhaka was : 36.9° C										
10.	Total Energy (Generation + India Import)	: 273.26 MKWh	15. Export through East-West interconnections :										
	By Gas = 152.793 MKWh	By Oil = 79.645 MKWh	At evening peak-hour : -60 MW, at 21:00 hrs										
	By Coal = 18.648 MKWh	By Hydro = 0.848 MKWh	Maximum : -136 MW, at 18:30 hrs										
	By Solar = 0.812 MKWh		Energy : 1.051 MKWh										
11.	Total Gas Supplied	: 1279.90 MMCFD											
(D) Forecast of 21.04.21 (Today) Wednesday :													
01.	Maximum Demand	: 13500 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 15595 MW (Generation end)	05.	Total Generation	: 277.46 MKWh								
03.	Maximum Shortage	: -2095 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	38.9° C								

* Captive Power ** Imported Power

#Remarks: Highest Generation 13380 MW on 15-04-2021 at 21:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation