

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month April, 2021			Day : Friday				Date : 23.04.21					
Probable Maximum Demand : 12900 MW			Yesterday = 76.60 ft				Today = 78.48 ft				Rule Curve = 83.60 ft.	
Water Level of Kaptai Lake at 06:00 AM			22.04.21 (Yesterday)				23.04.21 (Today)				22.04.21 (Yesterday)	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	a) Ghorasal Repowered CCGP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering	
	b) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering	
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	190	190			
2	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	97	103	104	104			
4	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
5	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.	
6	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	281	302	360	360	58	Gas Shortage	
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage	
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Dirty in gas	
10	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	75	148	94	180	62	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	220	220	220	115	ST under maint.	
12	Siddhirgonj 100 PP/Dutch Bangla	HFO (QRPP)	12x8.9	100	100	70	100	100	100			
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	270	270	285	285	35	dirty in gas	
14	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	100	50	100	100	100			
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100			
17	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	64	72	100	100			
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.50	22	22	19	19	22	22			
19	Summit Power (Madhabal+Ashulia)	Gas (SIPP, REB)	6x17+1x17.3	80	80	51	53	50	50			
20	Masna 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.17	33	33	33	33	33	33			
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.17	33	33	33	33	33	33			
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	25	52	52			
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	105	105			
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	100	149	149			
25	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	185	300	300			
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	143	149	149	149			
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
30	Bramhangon 100 MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
31	Aurahi 100MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
32	Nabaganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	35	55	55	55			
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	35			
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	72	104	104			
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	157	162	162	162			
37	Manikganj 35MW Solar PP (Inspect	Solar (IPP)	1x35	35	35	0	0	30	0			
Dhaka Zone Total			6026	5829	2117	2893	3571	3877	737	1070		
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	55	35	35	175	Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	45	50	50			
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	105	105	100	100			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130			
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	204	203	220	220			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300			
48	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	80	100	100	100			
49	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	100	90	90			
50	Dohazari - Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	66	66	66			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.50	22	22	18	21	22	22			
*	Malancha Ctg.EPZ (Unite)	Gas	5x8.73+3x9.34			5	35	11	21			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	51	84	84			
54	Sikalbaha 54 MW Power Plant (Jodiak Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	0	110	110			
56	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
57	Chattogram 116 MW PP (Anilima En	HFO (IPP)	6x21.06	116	116	72	35	116	116			
Chattogram Zone Total			2442	2382	964	1117	1630	1615	175	360		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	135	80	100	100	55	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+17x5	221	221	108	211	225	225			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	280	285	310	310			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	310	275	340	340			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	49	48	55	55			
64	Ashuganj 198MW PP (APSO-United)	Gas (IPP)	20'9.73+1'16	195	195	0	8	8	8	187	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	0	0	0	0	51	Line fault	
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	89	95	90	90	68	ST Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	178	175	180	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.50	22	22	16	22	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.50	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	47	52	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+4x1.55+15x1.058	200	200	0	0	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	75	113	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	18	37	37	37			
**	Import (Tripura)	India		160	160	90	152	157	179			
Cumilla Zone Total			3094	3034	1485	1643	1993	2185	505	119		
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	179	172	210	210			
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.50	22	22	0	19	20	20			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	73	66	74	74			
82	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	75	115	115	115			
83	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	0	140	200	200			
84	Saishaban 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0			
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22			
Mymensingh Zone Total			717	709	3							

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.04.21 (Yesterday)		23.04.21 (Today)		22.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)				
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	40	40	40		30	GT-1 Load gear problem		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	43	42	43		47	Under maint.		
89	Fenchugonj 51 MW PP (Barakatulle)	Gas (RPP)	19x2.90	51	51	47	53	51	51					
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	2	11	11	11					
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	32	52	52		34	Under maint.		
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	332	331	330	330					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	73	75	75	75					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x69	231	231	211	216	0	0					
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	18	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	15	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	300	341	341					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	375	368	400	400					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	395	388	400	400					
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total					2422	2377	1977	2062	1949	1950	0	111		
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	370	355	400	400					
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20					
106	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	5	0	60	60					
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	66	99	99	99					
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100					
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32	33					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	92	90	92					
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	588	845	858	858					
Khulna Zone Total					2288	2284	1082	1523	1709	1998	0	0		
113	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	80	110	110					
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	22	34	33	33					
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	60	65	65		134	GT-2 & STG Under maint.		
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x196	95	95	15	82	95	95					
117	Payra 1320 MW TPP	Coal (BCFCL)	2x622	1244	1244	380	550	622	622					
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	50					
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				107	107	109	110					
Barishal Zone Total					1826	1826	589	930	1034	1085	0	134		
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	50	50	50	21		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	50	50	50	50		Gas Shortage		
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	35	40					
123	Ammura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0					
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	99	100	100					
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31					
126	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43					
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	30					
128	Siraggonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	100	119	144	144	91		Gas Shortage		
129	Siraggonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	154	162	180	200					
130	Siraggonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	157	171	200	200					
131	Siraggonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	372	426	400	400					
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22					
133	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	0	5	11	11					
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	50	50					
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	0	113	113					
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	98	113	113					
Rajshahi Zone Total					2173	2173	924	1366	1791	1847	162	0		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	74	76	75	75	9		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage		
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage		
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	10	10					
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	113	113	113	113					
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
142	Majpara, Tatala 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	0	0	8	0					
Rangpur Zone Total					685	605	337	339	356	348	218	0		
Sub-total: Plants in operation					21673	21219	9864.0	12409	14726	15546	1797	1794		
Available Power at Sub-station end excluding PS auxiliary use and Transmission loss							9372	11790	13991	14771				
(B) Plants under long term maintenance/ contract expired														
143	Ghorashal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021		
144	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
145	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021		
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020		
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0	0	0	0		
Gross Total					21967	21219	9864	12409	14726	15546	1797	1794		
(C) Actual data of 22.04.21 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	: 12409.00 MW, at = 21:00 hrs					12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 11790.00 MW, at = 21:00 hrs					Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	: 12409.00 MW, at = 21:00 hrs					Dhaka	4049	4049	0	Mymensingh	994	994	0
04.	Minimum Generation (Generation end)	: 8089.00 MW, at = 6:00 hrs					Chattogram	1297	1297	0	Sylhet	512	512	0
05.	Day-peak Generation (Generation end)	: 9864.00 MW, at = 12:00 hrs					Khulna	1539	1539	0	Barishal	358	358	0
06.	Evening-peak Generation (Generation end)	: 12409.00 MW, at = 21:00 hrs					Rajshahi	1162	1162	0	Rangpur	685	685	0
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs					Cumilla	1194	1194	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8277.00 MW, at = 5:00 hrs					Total				11790	11790	0	
09.	Generation shortfall at evening peak due to :						13. Fuel cost :		(a) Gas = 158946447 Taka	(c) Coal = 82862270 Taka				
	a) Gas limitation	: 1404 MW					(b) Oil = 416442922 Taka		Total = 658251639 Taka					
	d) Coal supply Limitation	: 218 MW												
	b) Low water level in Kaplai lake	: 175 MW												
	c) Plants under shut down/ maintenance	: 1794 MW												
10.	Total Energy (Generation + India Import)	: 244.77 MKWh					14. Maximum Temperature in Dhaka was : 33.0° C							
	By Gas = 150.348 MKWh	By Oil = 57.014 MKWh					15. Export through East-West interconnections :							
	By Coal = 17.329 MKWh	By Hydro = 0.994 MKWh					At evening peak-hour : 190 MW, at 21:00 hrs							
	By Solar = 0.571 MKWh						Maximum : -180 MW, at 1:00 hrs							
11.	Total Gas Supplied	: 1210.50 MMCFD					Energy : 0.5405 MKWh							
(D) Forecast of 23.04.21 (Today) Friday :														
01.	Maximum Demand	: 12900 MW (Generation end)					04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 15546 MW (Generation end)					05. Total Generation : 254.46 MKWh							
03.	Maximum Shortage	: -2646 MW (Generation end)					06. Probable Max. Temperature in Dhaka : 39.0° C							

* Captive Power ** Imported Power

#Remarks: Highest Generation 13380 MW on 15-04-2021 at 21:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation