

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 24-Apr-21

Page 2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour Generation | Energy Generated | Remarks |
|------------------------------|----------------------------------|------------------|--------------------|------------------|----------------------|------------------|--------------------|
| | | | | | | | |
| | Ghorasal Repowered CAPP Unit | PDB | 1*210 | 170 | 0 | 0 | Under maint. |
| | Ghorasal Repowered CAPP Unit | PDB | 1*210 | 180 | 0 | 0 | Under maint. |
| | Ghorasal TPP Unit-5 | PDB | 1*210 | 190 | 180 | 4378500 | |
| 2 | Ghorasal 365 MW CAPP Unit-7 | PDB | 1*243+1*122 | 365 | 0 | 0 | Under maint. |
| 3 | Ghorasal 78.5 MW PP(MAX) | QRPP | 2*40 | 0 | 0 | 0 | Contract Expired |
| 4 | Ghorasal 108MW PP (Regent) | IPP | 343.35 | 108 | 104 | 1989500 | |
| 5 | Haripur GTPP | SBU_PDB | 2*32 | 20 | 0 | 0 | Under maint. |
| 6 | Haripur 412 MW CAPP | EGCB | 1*273+1*139 | 412 | 0 | 0 | Dirty in Gas |
| 7 | Haripur 360MW CAPP(HPL) | IPP | 1*235+1*125 | 360 | 344 | 7680000 | |
| 8 | Meghnaghat 450 MW CAPP(MP) | IPP | 2*150+1*150 | 450 | 290 | 6735050 | Gas shortage |
| 9 | Meghnaghat 100 MW(EL) | QRPP | 12*8.9 | 100 | 100 | 1142400 | |
| 10 | Meghnaghat CAPP(Summit) | IPP | 2*110+1*110 | 305 | 245 | 5801687 | Gas shortage |
| 11 | Madanganj 102 PP(Summit) | QRPP | 6*17 | 0 | 0 | 0 | Contract Expired |
| 12 | Madanganj-55 MW PP(Summit) | (IPP) | 3*17.08+1*11.3 | 55 | 55 | 1186361 | |
| 13 | Keraniganj 100 MW PP (Powerpa) | QRPP | 8*13.45 | 100 | 0 | 0 | Reserve. |
| 14 | Narshingdi 22 MW PP (Doreen) | SIPP_REB | 8*2.90 | 22 | 19 | 358200 | |
| 15 | 210 MW Siddhirganj TPP | PDB | 1*210 | 115 | 0 | 0 | Under maint. |
| 16 | Siddhirganj 2*120 MW GTPP | EGCB | 2*105 | 210 | 180 | 3341000 | Gas shortage |
| 17 | Siddhirganj 100 PP(Dutch Bangla) | QRPP | 12*8.9 | 100 | 100 | 1104960 | |
| 18 | Siddhirganj 335 MW CAPP | EGCB | 1*217+1*118 | 335 | 218 | 4980966 | ST under maint. |
| 19 | Gagnagar 102 MW PP (Digital P) | IPP | 12*8.924 | 102 | 102 | 1126656 | |
| 20 | Katpott 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 0 | 0 | Fuel shortage |
| 21 | Kamatnagar 54 MW PP(Banco E) | IPP | 3*18 | 54 | 54 | 1035000 | |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 64 | 605760 | Low demand |
| 23 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 35 | 379091 | Low demand |
| 24 | Nababganj 55 MW PP (Southern) | IPP | 3*19.3 | 55 | 55 | 766231 | |
| 25 | Bosila 108MW PP(CLC) | IPP | 12*8.75+1*3.5 | 108 | 0 | 0 | Fuel shortage |
| 26 | Summit Power SIPP(Shahid-Ashul) | SIPP_REB | 3*6.74+8*7.3 | 80 | 53 | 1061860 | Engine problem |
| 27 | Maona 33 MW PP(Summit) | SIPP_REB | 4*8.73 | 33 | 33 | 799500 | |
| 28 | Ruganaj 33 MW PP(Summit) | SIPP_REB | 4*8.73 | 33 | 33 | 756200 | |
| 29 | Gazipur 52 MW PP | IPP | 6*8.9 | 52 | 51 | 395136 | |
| 30 | Tongi 80 MW GTPP | PDB | 1*105 | 105 | 0 | 0 | Under maint. |
| 31 | Kodda 300 MW PP Unit-2 (Summ) | IPP | 18*17.076 | 300 | 280 | 2441344 | Engine problem |
| 32 | Keraniganj 300 MW PP (APR) | IPP | 25*11.4 | 300 | 0 | 0 | Reserve. |
| 33 | Bramhangonj 100 MW PP (Agg) | IPP | 100 | 100 | 0 | 0 | Reserve. |
| 34 | Aurahati 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 0 | 0 | Reserve. |
| 35 | Kodda 149 MW PP Unit-1 (Summ) | IPP | 149 | 149 | 141 | 2940480 | Engine problem |
| 36 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 105 | 1676400 | |
| 37 | Meghnaghat 104 MW PP (OPCL) | IPP | 18.5*5 | 104 | 89 | 1023380 | |
| 38 | Manikganj 162MW PP(MPGL) | IPP | 9*18 | 162 | 162 | 1854000 | Engine problem |
| | Spectra Solar Plant Ltd. | IPP | 35 | 35 | 0 | 245103 | |
| Dhaka area Total | | | | 5829 | 3082 | 55821145 | |
| 39 | Chattogram TPP-1 | PDB | 1*210 | 180 | 0 | 400000 | Gas shortage. |
| | Chattogram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | Gas shortage |
| | Razzan 25 MW PP | IPP | 3*8.9 | 25 | 17 | 288373 | Engine problem |
| 41 | Teknaf 20MW PP (SolarTech) | SolarTech Energy | 20 | 20 | 0 | 118665 | |
| 42 | Patenga 50MW PP (Baraka) | IPP | 6*8.98 | 50 | 12 | 396000 | Low demand |
| 43 | Kaptai Hydro Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 35 | 856000 | Unit-2 under maint |
| 44 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 212 | 4672024 | FGMO |
| 45 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 120 | 2986752 | |
| 46 | Sikalbaha 105 MW PP (Baraka S) | IPP | 105 MW | 105 | 105 | 1761381 | |
| 47 | Hathazari 100 MW peaking PP | PDB | 11*8.9 | 98 | 0 | 0 | |
| 48 | Dohazari-Kalaish 100 MW Peak | PDB | 6*17 | 102 | 66 | 683133 | Engine problem |
| 49 | Juldah 100 MW Unit-1 (Accom) | QRPP | 8*13.45 | 100 | 72 | 1996200 | Low demand |
| 50 | Juldah 100 MW PP Unit-3 (Accom) | IPP | 0 | 100 | 100 | 2064000 | |
| 51 | Barakunda 22 MW PP (Regent) | SIPP_PDB | 8*2.90 | 22 | 21 | 481440 | |
| ** | Malancha, Ctg. ETP | IPP | 5*8.73*9.34 | 0 | 35 | 540000 | |
| 52 | Chattogram 108 MW PP (ECPV) | IPP | 6*17 | 108 | 70 | 722880 | Engine problem |
| 53 | Kaptai 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 39000 | |
| 54 | Anwara 300 MW PP (United) | IPP | 300 MW | 300 | 0 | 0 | Reserve. |
| 55 | Jodiac Power | IPP | 3*18.55+1*3.6 | 54 | 54 | 1166713 | |
| 56 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 35 | 265962 | Low demand |
| 57 | Juldah unit-2 (Accom) | IPP | 8*13.6 | 100 | 100 | 1795200 | |
| | Anlima Energy Ltd. | IPP | 6*21.2 | 116 | 116 | 703800 | |
| Chattogram area Total | | | | 2382 | 1170 | 21947523 | |
| 58 | Ashuganj TPP Unit- 3 | APSCL | 1*150 | 135 | 135 | 2669220 | |
| | Ashuganj TPP Unit- 4 | APSCL | 1*150 | 129 | 0 | 0 | Gas shortage |
| | Ashuganj TPP Unit- 5 | APSCL | 1*150 | 134 | 0 | 0 | Gas shortage |
| 59 | Ashuganj 225 MW CAPP | APSCL | 1*144+2*75 | 221 | 195 | 4526000 | |
| 60 | Ashuganj 450 MW CAPP(North) | APSCL | 1*360 | 360 | 330 | 7428900 | FGMO |
| 61 | Ashuganj 450 MW CAPP(South) | APSCL | 1*360 | 360 | 305 | 7055000 | FGMO |
| 62 | Ashuganj 50 MW PP | APSCL | 14*3.968 | 45 | 26 | 558360 | Engine problem |
| 63 | Ashuganj 55 MW PP (Precision) | RPP | 154 | 55 | 52 | 950880 | |
| 64 | Ashuganj 158MW PP (APCL-U) | IPP | 20*9.34+116 | 195 | 26 | 516545 | Gas shortage |
| 65 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 0 | 0 | Line fault |
| 66 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 0 | 0 | Line fault |
| 67 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 0 | 85216 | Reserve. |
| 68 | Chandpur 150 MW CAPP | PDB | 1*106+1*57 | 163 | 95 | 2245580 | Gas shortage |
| 69 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 180 | 3422400 | Engine problem |
| 70 | Feni 22MW PP (Doreen) | SIPP_PDB | 8*2.90 | 22 | 22 | 444024 | |
| 71 | Feni 11 MW PP (Doreen) | SIPP_REB | 4*2.90 | 11 | 10 | 235080 | |
| ** | Impoort (Tripura) | Imported power | 0 | 160 | 80 | 2735040 | |
| 72 | Jangalia 33MW PP (Summit) | SIPP_PDB | 4*8.73 | 33 | 33 | 809700 | |
| 73 | Jangalia 52 MW PP (Lakdanavi) | IPP | 6*8.92 | 52 | 52 | 1023917 | Engine problem |
| 74 | Cumilla 25 MW PP (Summit) | SIPP_PDB | 3*6.87+2*6.97 | 25 | 20 | 454450 | Reserve. |
| 75 | Daudkandi 200 MW PP (B.Trac) | IPP | 15*11.4 | 200 | 0 | 0 | Reserve. |
| 76 | Feni Lanka Power | IPP | 7*18.15+1*9.78 | 114 | 52 | 429780 | Low demand |
| 77 | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 113 | 1884120 | |
| | Bhairab 54.5 MW | IPP | 3*18.2 | 54 | 36 | 878960 | Engine problem |
| Cumilla Area Total | | | | 3034 | 1762 | 38351172 | |
| 78 | RPCL 210MW CAPP | IPP | 4*35+1*70 | 202 | 172 | 4405120 | Gas shortage |
| 79 | Tangail 22 MW PP (Doreen) | SIPP_PDB | 8*2.90 | 22 | 19 | 35120 | |
| 80 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 95 | 73 | 1699200 | Engine problem |
| 81 | Sarishabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 2650 | |
| 82 | Mymensingh 200 MW PP (Unite) | IPP | 200 | 200 | 190 | 1490400 | Engine problem |
| 83 | Jamalpur 115 MW PP (Unite) | IPP | 115 MW | 115 | 115 | 2241600 | |
| 84 | Sutakhalhi 50 MW Solar PP | IPP | 50 | 50 | 0 | 392840 | |
| 85 | Tangail Pali Power Gen 22 MW | IPP | 4*6.7 | 22 | 24 | 424320 | |
| Mymensingh Area Total | | | | 709 | 593 | 11006302 | |
| 86 | Fenchuganj CAPP Phase-1 | PDB | 2*32+1*33 | 70 | 0 | 0 | Machine problem |
| 87 | Fenchuganj CAPP Phase-2 | PDB | 2*35+1*35 | 90 | 43 | 1012800 | Machine problem |
| 88 | Kushihara 163 MW CAPP (KP) | IPP | 1*108+1*54 | 163 | 163 | 3468191 | |
| 89 | Shahjibazar 330 MW CAPP | PDB | 3*110 | 330 | 335 | 7423050 | |
| 90 | Fenchuganj 51 MW PP (Barakat) | RPP | 19*2.90 | 51 | 53 | 1136400 | |
| 91 | Fenchuganj 44MW (Energyprima) | RPP | 12*3.3+5*2 | 0 | 0 | 0 | Contract Expired |
| 92 | Hobiganj 11MW PP Confidence-E | SIPP_REB | 4*2.90 | 11 | 11 | 182048 | |
| 93 | Shahjibazar GTPP Unit- 8 & 9 | PDB | 2*35 | 66 | 67 | 1494720 | GT-8 Under maint. |
| 94 | Shahjibazar 80MW PP (Shahjiba) | RPP | 32*2.90 | 86 | 78 | 1607400 | |
| 95 | Shahjibazar 100 MW GTPP | PDB | 1*100 | 100 | 0 | 0 | Under Shut down |
| 96 | Sylhet 225 MW CAPP | PDB | 1*142+1*89 | 231 | 225 | 3856050 | |
| 97 | Sylhet 20 MW GTPP | PDB | 1*20 | 20 | 18 | 168000 | |
| 98 | Sylhet 50MW PP (EPL) | RPP | 2*72 | 0 | 0 | 0 | Contract Expired |
| 99 | Shahjahanulla 25 MW PP | SIPP_REB | 3*9.34 | 25 | 16 | 367080 | Engine problem |
| 100 | Bibiyana-II 341 MW CAPP (Summ) | IPP | 1*122+1*119 | 341 | 305 | 7307000 | FGMO |
| 101 | Bibiyana-III 400 MW CAPP | PDB | 400 MW | 400 | 380 | 8867000 | FGMO |
| 102 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 9 | 189540 | |
| | Bibiyana South 400 MW | PDB | 400 MW | 383 | 395 | 6102000 | FGMO |
| Sylhet Area Total | | | | 2377 | 2098 | 43179869 | |
| 103 | Bheramara GTPP Unit-3 | PDB | 1*20 | 16 | 0 | 0 | Reserve. |
| ** | Bheramara (KVCCL) | Imported power | 2*500 | 1000 | 839 | 2026609 | |
| 104 | Khulna 115 PP MW (KPCL-2) | QRPP | 7*17 | 115 | 99 | 1728000 | Engine problem |
| 105 | Faridpur 50 MW Peaking PP | PDB | 6*8.98 | 54 | 0 | 0 | Reserve. |
| 106 | Khulna 225 MW CAPP | NWPGCL | 1*150+1*75 | 230 | 0 | 0 | Reserve. |
| 107 | Gopalganj 100 MW Peaking PP | PDB | 16*6.98 | 109 | 0 | 20736 | Reserve. |
| 108 | Bheramara 410 MW CAPP | NWPGCL | 1*276+1*132 | 410 | 360 | 872322 | FGMO |
| 109 | Noapara 40 MW PP (Kharajaban) | QRPP | 5*8.5 | 40 | 40 | 276250 | Engine problem |
| 110 | Noapara 100 MW PP (Bangla Tr) | IPP | 70*1.4 | 100 | 100 | 516480 | |
| 111 | Rupsha 105 MW PP (Orion rupsa) | IPP | 6*18.445 | 105 | 92 | 1151520 | Engine problem |
| | Madhumati 100 MW PP | SWPGCL | 100 MW | 105 | 0 | 0 | Reserve. |
| Khulna Area Total | | | | 2284 | 1522 | 32682127 | |
| 112 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 110 | 761728 | |
| 113 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 34 | 586622 | |
| 114 | Bhola 225 MW CAPP | PDB | 2*63+1*68 | 194 | 60 | 1384000 | Machine problem |
| 115 | Bhola 95 MW PP (Aggreko) | QRPP | 96*1.10 | 95 | 97 | 1967471 | |
| 116 | Payra 1320 MW | BCPCL | 2*622 | 1244 | 580 | 12707300 | On Test |
| | Bhola Nutan Biddul BD LTD | IPP | 220 | 0 | 0 | 279764 | Low demand |
| | United Payra Power Ltd. | IPP | 8*18.5+1*9.5 | 150 | 35 | 178800 | |
| Barisal Area Total | | | | 1826 | 916 | 17885685 | |
| 117 | Baghabari 71 MW GTPP | PDB | 1*71 | 71 | 0 | 632000 | Gas shortage |
| | Baghabari 100 MW GTPP | PDB | 1*100 | 100 | 0 | 487000 | Gas shortage. |
| 118 | Baghabari 50 MW Peaking PP | PDB | 6*8.9 | 52 | 50 | 295952 | |
| 119 | Bera 70 MW Peaking PP | PDB | 9*8.29 | 71 | 42 | 193341 | |
| 120 | Annura 50 MW PP | | | | | | |