

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 956467, 9551095

Month May, 2021			Day : Friday					Date : 07.05.21				
Probable Maximum Demand : 11800 MW			Probable Maximum Generation : 15418 MW					Rule Curve = (80.86) ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.05.21 (Yesterday)		07.05.21 (Today)		06.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
					Probable start-up date							
(A) Plants in operation:												
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering	
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering	
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	90	98	100	100			
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
5	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint	
6	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	222	211	250	250	149	Gas Shortage	
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	300	300	170	Gas Shortage	
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Diff in gas	
10	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	145	185	200	200	25	Gas Shortage	
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	220	219	220	220	116	ST under maint.	
12	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	100	100	100			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	230	240	250	250	65	diff in gas	
14	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	91	100	100			
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	50	100	100			
17	Gagnagar 102 MW PP (Digital Powe)	HFO (IPP)	12x8.924	102	102	48	102	102	102			
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22			
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	53	55	53	53			
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Ruganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	51	52	52			
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	60	90	105	105			
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	133	150	150			
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	115	250	250			
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	219	149	149			
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
30	Bramhangsan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
31	Aurghat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100			
32	Nababganj 55 MW PP (Southern por)	HFO (IPP)	3x18.3	55	55	25	55	55	55			
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x18.3	55	55	17	55	55	55			
34	Bosila 108MW PP(RCL)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
35	Meghnaghat 104 MW PP (QPSL)	HFO (IPP)	6x18.5	104	104	0	93	90	90			
36	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	162	162			
37	Manikgonj 35MW Solar PP (Inspect)	Solar (IPP)	1x35	35	35	35	0	30	0			
Dhaka Zone Total				6026	5829	2001	2951	3431	3701	821	1071	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	23	23	23	23	207	Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	90	80	80	80			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	27	50	43	43			
44	Sikalbaha 105 MW PP (Baraka Sik)	HFO (IPP)	6x18.415	105	105	89	90	90	90			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	135	130	130	130			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	203	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300			
48	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	0	0			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22			
*	Malanoha, Ctg EPZ (United)	Gas	5x8.73+3x3.34			5	34	15	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	61	91	90	90			
54	Sikalbaha 54 MW Power Plant(Jodae Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	110	110			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
57	Chattogram 116 MW PP (Anlma En)	HFO (IPP)	6x21.06	116	116	116	116	116	116			
Chattogram Zone Total				2442	2382	1079	1195	1608	1588	207	180	
58	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	80	80	80	54	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	187	213	220	220			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	275	330	330			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	270	265	330	330			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	52	55	55			
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	26	8	26	26	187	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	150	100	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	128	88	95	95	75	Gas Shortage	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	102	160	160	160			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11			
72	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	20	20	20			
75	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	86x1.4+40x1.5+15x1.99	200	200	0	0	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	114	114			
77	Chowmahant 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	46	113	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	36	36			
**	Imposrt (Tripura)	India		160	160	130	146	156	187			
Cumilla Zone Total				3094	3034	1499	1939	2130	2361	580	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	137	136	160	160	66	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	19	19			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	65	65	74	74			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	32	115	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	168	200	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	57	0	50	0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	19	24	22	22			
Mymensingh Zone Total				717	709	329	525	642	590	66	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.05.21 (Yesterday)		07.05.21 (Today)		06.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	43	43		26	Under maint.
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.
89	Fenchugonj 51 MW PP (Barakatala)	Gas (RPP)	19x2.90	51	51	31	53	51	51			
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	11	11	11			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	32	32	32			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	269	272	275	275			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	75	76	78			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	217	192	225	225			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	305	341	341			
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	365	367	400	400			
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	370	370	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			
Sylhet Zone Total				2422	2377	1950	1934	2103	2105	0	74	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16			
104	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	360	280	350	350	130		Gas Shortage
105	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	22	20	20			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	2	0	60	60			
107	Khulina 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220			
108	Khulina 115 MW (KPCL-2)	HFO (QRPP)	7x17	115	115	44	83	99	99			
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	99	50	100			
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32	33			
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	47	0	92	92			
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100			
**	Bheramara (HVDC)	India	1000	1000	837	836	851	851				
Khulina Zone Total				2288	2284	1290	1352	1654	1941	130	0	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110			
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	30	35	35			
115	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x98	194	194	69	67	65	65		127	GT-2 & STG Under maint.
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	96	97	95	95			
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	400	540	622	622			
118	Potukhali 150MW PP (JPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	80	80			
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0			
Barishal Zone Total				1826	1826	585	879	1007	1007	0	127	
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50			
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40			
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	42	42	42			
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	100	100			
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	29	29			
126	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43			
127	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	42	0	32			
128	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	122	115	120	120	35		Gas Shortage
129	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	162	166	200	200	54		Gas Shortage
130	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	182	188	200	200			
131	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	376	418	0	400			
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22			
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	52	52			
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	113	113	113			
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	113	113	113			
Rajshahi Zone Total				2173	2173	881	1419	1335	1767	260	0	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	74	71	75	14			Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	149	150	125			Coal Shortage
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10			
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	113	113	113			
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10			
142	Majpara, Tutula 9 MW Solar PP (Symba Po)	Solar (IPP)	1 x 8	8	8	3	0	8	0			
Rangpur Zone Total				685	605	227	333	346	358	224	0	
Sub-total: Plants in operation				21673	21219	9841.0	12527	14256	15418	2288	1452	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9480	12067	13732	14852			
(B) Plants under long term maintenance/ contract expired												
143	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
145	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020
147	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
Sub-Total: Plants under long term maintenance/ contract expired				294	0	0	0	0	0			
Gross Total				21967	21219	9841	12527	14256	15418	2288	1452	
(C) Actual data of 06.05.21 (Yesterday) Thursday :												
01.	Max. Demand at eve. peak (Generation end)	:	12527.00	MW, at = 21:00 hrs	12	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12067.00	MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12527.00	MW, at = 21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	8254.00	MW, at = 6:00 hrs	Dhaka	4209	4209	0	Mymensingh	1034	1034	0
05.	Day-peak Generation (Generation end)	:	9841.00	MW, at = 12:00 hrs	Chatogram	1316	1316	0	Sylhet	498	498	0
06.	Evening-peak Generation (Generation end)	:	12527.00	MW, at = 21:00 hrs	Khulina	1478	1478	0	Barishal	368	368	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 21:00 hrs	Rajshahi	1291	1291	0	Rangpur	701	701	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8176.00	MW, at = 5:00 hrs	Cumilla	1172	1172	0				
09.	Generation shortfall at evening peak due to :	:						Total	12067	12067	0	
a)	Gas limitation	:	1857	MW	13.	Fuel cost :	(a) Gas = 163310153 Taka	(c) Coal = 77439642 Taka				
d)	Coal supply Limitation	:	224	MW		(b) Oil = 410946128 Taka	Total = 651695923 Taka					
b)	Low water level in Kaptai lake	:	207	MW								
c)	Plants under shut down/ maintenance	:	1452	MW	14.	Maximum Temperature in Dhaka was :	33.6° C					
10.	Total Energy (Generation + India Import)	:	249.22	MKWh	15.	Export through East-West interconnections :						
	By Gas = 149.619	MKWh		By Oil = 58.944	MKWh	At evening peak-hour	: -92	MW, at	21:00	hrs		
	By Coal = 16.125	MKWh		By Hydro = 0.487	MKWh	Maximum	: -104	MW, at	19:00	hrs		
	By Solar = 0.741	MKWh				Energy	: 0.037	MKWh				
11.	Total Gas Supplied	:	1243.79	MKWh								
(D) Forecast of 07.05.21 (Today) Friday :												
01.	Maximum Demand	:	11800	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15418	MW (Generation end)	05.	Total Generation	:	234.76	MKWh			
03.	Maximum Shortage	:	-3618	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	33.7° C				

* Captive Power ** Imported Power
 #Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouel Islam Shaker)
 Deputy Secretary, Generation