

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 956467, 9551095

Month May, 2021			Day : Saturday				Date : 08.05.21				
Probable Maximum Demand : 12000 MW			Probable Maximum Generation : 15773 MW						Rule Curve = (8.67) ft.		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Today = 76.00 ft.		08.05.21 (Today)		07.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	0	0	0	0	365	Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	97	100	100	100		
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
5	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint
6	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	242	271	250	250	89	Gas Shortage
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	283	300	412	129	Diff in gas
10	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	140	150	120	150	60	Gas Shortage
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	208	220	220	220	115	ST under maint.
12	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	40	100	100	100		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	220	240	240	240	65	dirt in gas
14	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	16	60	100	100		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
17	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	16	24	102	102		
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22		
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x6.73	80	80	41	51	53	53		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Ruganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	60	70	105	105		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	150	150		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	250	250		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	100	300		
30	Bramhangsan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
31	Aurghat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100		
32	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x18.3	55	55	35	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x18.3	55	55	0	0	55	55		
34	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (QPSL)	HFO (IPP)	8x18.5	104	104	48	94	90	90		
36	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	72	162	162		
37	Manikgonj 35MW Solar PP (Inspect	Solar (IPP)	1x35	35	35	34	0	30	0		
Dhaka Zone Total			6026	5829	2116	2599	3621	4033	513	1070	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	22	23	22	22	207	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	80	80	80	80		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	18	43	43		
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	89	105	90	90		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	100	130		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	215	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300		
48	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	0	0		
49	Juldah 100 MW PP Unit-3(Acom)	HFO (IPP)	8x13.45	100	100	90	100	100	100		
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22		
*	Malanoha, Ctg EPZ (United)	Gas	5x8.73+3x3.34	23	23	41	15	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	50	90	90		
54	Sikalbaha 54 MW Power Plant(Jodiae Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
57	Chattogram 116 MW PP (Anlma En	HFO (IPP)	6x21.06	116	116	21	116	116	116		
Chattogram Zone Total			2442	2382	874	1138	1577	1587	207	180	
58	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	100	80	80	34	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	192	215	220	220		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	280	270	330	330		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	275	265	330	330		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	10	57	55	55		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	0	100	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	93	127	130	130	36	Gas Shortage
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	102	180	160	160		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11		
72	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	46x1.4+40x1.91+16x1.98	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	87	113	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	18	36	36		
**	Imposnt (Tripura)	India		160	160	96	148	156	187		
Cumilla Zone Total			3094	3034	1470	1705	2147	2378	521	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	135	154	160	160	48	Gas Shortage
80	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	0	19	19		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	73	64	74	74		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	72	35	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	0	200	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0		
86	Tangali 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	24	13	22	22		
Mymensingh Zone Total			717	709	375	266	642	590	48	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.05.21 (Yesterday)		08.05.21 (Today)		07.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
89	Fenchugonj 51 MW PP (Barakatala)	Gas (RPP)	19x2.90	51	51	8	53	51	51				
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	32	32	32				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	270	271	275	275				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	78	76	78				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	169	0	225	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	341	341				
100	Bibyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	377	333	400	400				
101	Bibyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	360	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1856	1727	2103	2105	0	75	
103	Bheramara GTTP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	400	350	350	350	60		Gas Shortage	
105	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	5	20	20				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulina 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulina 115 MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	99	99	99				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	20	50	100				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	33	32	33				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	105	105	105				
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	836	836	851	851				
Khulina Zone Total					2288	2284	1358	1448	1667	1938	60	0	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110				
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	32	35	35				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x98	194	194	65	65	65	65		129	GT-2 & STG Under maint.	
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	94	97	95	95				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	460	540	622	622				
118	Potukhali 150MW PP (JPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	80	80				
Bhola Nutan Biddut BD LTD					Gas/HSD (IPP)		0	79	0	0			
Barishal Zone Total					1826	1826	638	861	1007	1007	0	129	
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40				
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42				
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	41	69	100	100				
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	29	29				
126	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	32				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	130	126	130	130	24		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	193	174	200	200	46		Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	179	188	200	200				
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	414	400	400				
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22				
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	10	0	113	113				
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	16	35	113	113				
Rajshahi Zone Total					2173	2173	651	1090	1745	1777	241	0	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	69	73	75	75	12		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	78	68	113	113				
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Majpara, Tutula 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	303	291	346	358	221	0	
Sub-total: Plants in operation					21673	21219	9641.0	11125	14855	15773	1811	1454	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							9318	10752	14357	15244			
(B) Plants under long term maintenance/ contract expired													
143	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
147	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0	0			
Gross Total					21967	21219	9641	11125	14855	15773	1811	1454	
(C) Actual data of 07.05.21 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 11125.00 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 10752.00 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 11204.00 MW, at = 22:00 hrs	Dhaka	4020	4020	0	Mymensingh	475	475	0			
04.	Minimum Generation (Generation end)	: 8176.00 MW, at = 7:00 hrs	Chattoagram	1307	1307	0	Sylhet	508	508	0			
05.	Day-peak Generation (Generation end)	: 9641.00 MW, at = 12:00 hrs	Khulina	1489	1489	0	Barishal	342	342	0			
06.	Evening-peak Generation (Generation end)	: 11125.00 MW, at = 21:00 hrs	Rajshahi	1016	1016	0	Rangpur	455	455	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs	Cumilla	1140	1140	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8185.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 1383 MW	13.	Fuel cost :	(a) Gas = 158968624 Taka	(c) Coal = 82630662 Taka							
d)	Coal supply Limitation	: 221 MW			(b) Oil = 361803473 Taka	Total = 603402759 Taka							
b)	Low water level in Kaptai lake	: 207 MW											
c)	Plants under shut down/ maintenance	: 1454 MW											
10.	Total Energy (Generation + India Import)	: 240.21 MKWh	14.	Maximum Temperature in Dhaka was :	36.3° C								
	By Gas = 145.733 MKWh	By Oil = 52.932 MKWh	15.	Export through East-West interconnections :									
	By Coal = 17.316 MKWh	By Hydro = 0.473 MKWh		At evening peak-hour	: 240 MW, at 21:00 hrs								
	By Solar = 0.809 MKWh			Maximum	: -30 MW, at 18:30 hrs								
11.	Total Gas Supplied	: 1248.50 MCFD		Energy	: 0.026 MKWh								
(D) Forecast of 08.05.21 (Today) Saturday :													
01.	Maximum Demand	: 12000 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 15773 MW (Generation end)	05.	Total Generation	: 257.27 MKWh								
03.	Maximum Shortage	: -3773 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	37.1° C								

* Captive Power ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation