

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 956467, 9551095

Month May, 2021		Day : Wednesday				Date : 12.05.21							
Probable Maximum Demand :		11000 MW		Probable Maximum Generation :		15766 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.74 ft		Today = 75.70 ft		Rule Curve = (79.91 ft)							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.05.21 (Yesterday)		12.05.21 (Today)		11.05.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering		
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering		
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	120	180	180	180				
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.		
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	53	97	100	100				
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem		
5	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.		
6	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	303	351	360	360	9	Gas Shortage		
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage		
8	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	319	345	350	360	67	Diff in gas		
10	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	125	185	180	200	25	Gas Shortage		
11	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	160	221	0	220	114	ST under maint.		
12	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	0	100	100				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	230	0	0	250	305	diff in gas		
14	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	100	100				
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55				
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
17	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	16	0	102	102				
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	19	22	22				
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x6.73	80	80	25	42	42	42				
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	0	33	33				
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52				
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	0	105	105				
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	150	150				
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	35	35				
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	250	250				
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	142	55	149	149				
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	100	300				
30	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
31	Aurghat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100				
32	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x18.3	55	55	20	55	55	55				
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x18.3	55	55	0	0	55	55				
34	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
35	Meghnaghat 104 MW PP (QPSL)	HFO (IPP)	8x18.5	104	104	0	0	90	90				
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	162	162				
37	Manikganj 35MW Solar PP (Inspect	Solar (IPP)	1x35	35	35	21	0	30	0				
Dhaka Zone Total				6026	5829	1997	1918	3370	4140	576	1069		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	23	23	22	23	207		Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	80	0	0	0				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	12	12	43	43				
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	34	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130				
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	205	204	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300				
48	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	92	100	100	100				
49	Juldah 100 MW PP Unit-3(Acom)	HFO (IPP)	8x13.45	100	100	50	50	100	100				
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	20	22	22				
*	Malanchoa Ctg EPZ (United)	Gas	5x8.73+3x3.34			6	32	20	30				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90				
54	Sikalbaha 54 MW Power Plant(Jodiae Power)	HFO (IPP)	3x18.55+1x3.6	54	54	51	54	54	54				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	40	20	100	100				
57	Chattogram 116 MW PP (Anlma En	HFO (IPP)	6x21.06	116	116	0	20	116	116				
Chattogram Zone Total				2442	2382	776	855	1647	1633	207	180		
58	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	100	100	80	100	34	Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	183	179	220	220				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	265	300	330	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	260	265	330	330				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	35	53	55	55				
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	40	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	92	90	92				
69	Chandpur 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	51	160	160	160				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	20	20	20				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	46x1.4+40x1.91+15x1.98	200	200	0	0	100	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	21	36	113	113				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	18	18	18	18				
**	Impoort (Tripura)	India		160	160	108	126	157	188				
Cumilla Zone Total				3094	3034	1201	1541	2140	2343	485	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	151	157	160	160	45		Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	17	17	17				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	13	57	65	65				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	80	115	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0							

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.05.21 (Yesterday)		12.05.21 (Today)		11.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	44	44		26	Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.		
89	Fenchugonj 51 MW PP (Barakatlula)	Gas (RPP)	19x2.90	51	51	50	53	51	51					
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11					
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	32	32	32					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	331	330	330	330					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	75	75	75					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	137	224	225	225					
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	8	8					
98	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x3.34	25	25	16	16	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	305	341	341					
100	Bibyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	318	366	400	400					
101	Bibyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	330	400	400	400					
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total					2422	2377	1754	2069	2156	2156	0	74		
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	245	180	300	300	230		Gas Shortage		
105	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20					
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	2	0	60	60					
107	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220					
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	68	99	99					
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	32	32					
111	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	0	0	105	105					
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India	1000	1000	919	917	920	920	920					
Khulna Zone Total					2288	2284	1166	1165	1686	1956	230	0		
113	Barsal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110					
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	24	33	33					
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x58	194	194	88	89	88	88					
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	23	96	95	95					
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	340	410	622	622					
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	80	80					
Bhola Nutan Biddut BD LTD														
Barishal Zone Total					1826	1826	468	651	1028	1028	0	0		
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50					
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40					
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42					
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	24	100	100					
125	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	30					
126	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43					
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	32					
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	150		Gas Shortage		
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	146	140	200	200	80		Gas Shortage		
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	185	176	200	200	44		Gas Shortage		
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	335	325	400	400					
132	Bogra 22 MW PP (GSB)	Gas (RPP)	6x4.0	22	22	21	21	22	22					
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11					
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52					
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	0	113	113					
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	0	113	113					
Rajshahi Zone Total					2173	2173	692	699	1616	1648	445	0		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage		
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	0	70	113	113					
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
142	Majpara, Tahula 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	6	0	8	0					
Rangpur Zone Total					685	605	156	220	271	283	294	0		
Sub-total: Plants in operation					21673	21219	8443.0	9453	14545	15766	2282	1323		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							8150	9125	14040	15219				
(B) Plants under long term maintenance/ contract expired														
143	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021		
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
145	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021		
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020		
147	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0	0	0	0		
Gross Total					21967	21219	8443	9453	14545	15766	2282	1323		
(C) Actual data of 11.05.21 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)	: 9453.00 MW, at = 21:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :		Zone		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
02.	Max. Demand at eve. peak (Sub-station end)	: 9125.00 MW, at = 21:00 hrs		Dhaka		2908	2908	0	Mymensingh	758	758	0		
03.	Highest Generation (Generation end)	: 9949.00 MW, at = 1:00 hrs		Chattoogram		1309	1309	0	Sylhet	489	489	0		
04.	Minimum Generation (Generation end)	: 6501.00 MW, at = 7:00 hrs		Khulna		960	960	0	Barishal	233	233	0		
05.	Day-peak Generation (Generation end)	: 8443.00 MW, at = 12:00 hrs		Rajshahi		875	875	0	Rangpur	617	617	0		
06.	Evening-peak Generation (Generation end)	: 9453.00 MW, at = 21:00 hrs		Cumilla		976	976	0						
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs		Total		9125	9125	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6558.00 MW, at = 5:00 hrs		13. Fuel cost :		a) Gas = 155388422 Taka		c) Coal = 64100326 Taka		Total = 418381573 Taka				
09.	Generation shortfall at evening peak due to :	:		14. Maximum Temperature in Dhaka was :		32° C								
	a) Gas limitation	: 1781 MW		15. Export through East-West interconnections :		At evening peak-hour		: -24 MW, at 21:00 hrs						
	d) Coal supply Limitation	: 294 MW		Maximum		: -60 MW, at 22:00 hrs								
	b) Low water level in Kaptai lake	: 207 MW		Energy		: 0.674 MKWh								
	c) Plants under shut down/ maintenance	: 1323 MW		11. Total Gas Supplied		: 1149.60 MCFD								
	Total Energy (Generation + India Import)	: 208.50 MKWh												
	By Gas = 143.735 MKWh	By Oil = 26.394 MKWh												
	By Coal = 13.740 MKWh	By Hydro = 0.476 MKWh												
	By Solar = 0.612 MKWh													
(D) Forecast of 12.05.21 (Today) Wednesday :														
01.	Maximum Demand	: 11000 MW (Generation end)		04. Maximum Load-shed		: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 15766 MW (Generation end)		05. Total Generation		: 230.53 MKWh								
03.	Maximum Shortage	: -4766 MW (Generation end)		06. Probable Max. Temperature in Dhaka :		: 33.8° C								

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation