

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2021		Day : Sunday		Date : 16.05.21							
Probable Maximum Demand :		11200	MW	Probable Maximum Generation : 15285							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.37	ft	Today = 75.26	ft.						
		Rule Curve = 79.34									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.05.21 (Yesterday)		16.05.21 (Today)		15.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	120	180	180	180		
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	81	104	100	100		
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
5	Hanpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
6	Hanpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	341	353	360	360		
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Hanpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	350	333	350	360	79	Dirty in gas
10	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	150	185	120	150	25	Gas Shortage
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	209	190	220	220	165	ST under maint.
12	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	0	100	100		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	265	240	240	240	65	dirty in gas
14	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	100	100		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
17	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	0	0	102	102		
18	Narshingdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.90	22	22	19	0	22	22		
19	Summit Power, (Madhabdi+Ashula)	Gas (SIIP, REB)	6x3.57+3x3.73	80	80	28	30	42	42		
20	Masna 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.25	33	33	20	20	33	33		
21	Rupganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.25	33	33	17	25	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	150	150		
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.89	54	54	0	0	35	35		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	250	250		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	16	149	149		
29	Keraniganj 300 MW PP (AR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
30	Branhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
31	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100		
32	Nabaganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	0	0	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55		
34	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	90	90		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	162	162		
37	Manikganj 35MW Solar PP (Inspect	Solar (IPP)	1x35	35	35	32	0	30	0		
Dhaka Zone Total				6026	5829	1912	1951	3770	4080	339	1120
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	23	23	23	23	207	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	6	0	5	0		
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	43	43		
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	0	34	105	105		
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	120	140		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	216	205	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	300	300		
48	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	100	100		
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	10	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	22	19	22	22		
*	Malancha, Ctg.EPZ (Unite)	Gas	5x8.73+3x9.34			42	42	25	40		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90		
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	25	54	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	100	100		
57	Chattogram 116 MW PP (Anlima En	HFO (IPP)	6x21.06	116	116	0	0	116	116		
Chattogram Zone Total				2442	2382	531	712	1643	1653	207	180
58	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	80	80	80	80	54	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	197	191	0	145		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	285	330	330		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	340	280	330	330		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	154	55	55	30	5	55	55		
64	Ashuganj 195MW PP (APSCL-Unit)	Gas (IPP)	20*9.73+116	195	195	55	8	55	55	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	7	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	150	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	88	90	92	75	Gas Shortage
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	84	51	160	160		
70	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	20	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	5	0	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	33	15	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	19	16	20	20		
75	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	99x1.4+6x1.51+15x1.05	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	36	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	18	18		
**	Impoort (Tripura)	India		160	160	102	74	145	179		
Cumilla Zone Total				3094	3034	1425	1253	1955	2286	580	0
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	203	207	200	200		
80	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	16	19	19	19		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	48	65	65	65		
82	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	0	75	115	115		
83	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	0	0	200	200		
84	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0		
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	0	5	22	22		
Mymensingh Zone Total				717	709	322	371	673	621	0	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.05.21 (Yesterday)		16.05.21 (Today)		15.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0			Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42			Under maint.	
89	Fenchugonj 51 MW PP (Barakatulle)	Gas (RPP)	19x2.90	51	51	8	52	51	51				
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	51	51	51	51				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	331	332	330	330				
94	Shahjibazar 96MW PP (Shahjibazar)	Gas (RPP)	32x2.90	96	86	5	78	75	75				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	216	223	225	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	7	8	8				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0				
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	388	400	400				
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	96	350	350				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	861	1477	1740	1740	0	118	
103	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	385	350	350	350	60		Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	99	99	99				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	33	32	32				
111	Rupsha 105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	105	105				
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	704	727	763	860				
Khulna Zone Total					2288	2284	1089	1226	1579	1946	60	0	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110				
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	25	34	33	33				
115	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	83	88	88	88	106		GT-2 & STG Under maint.	
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	70	94	95	95				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	380	622	622				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	80	80				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0				
Barishal Zone Total					1826	1826	498	644	1028	1028	0	106	
119	a) Baghabani 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabani 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
120	Baghabani 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50				
121	Baghabani 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40				
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42				
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	25	100	100				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	30				
126	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	41	0	32				
128	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	150		Gas Shortage	
129	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	185	165	200	200	55		Gas Shortage	
130	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	195	192	200	200				
131	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	406	417	400	400				
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	18	22	22				
133	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	0	113	113				
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	0	113	113				
Rajshahi Zone Total					2173	2173	812	869	1616	1648	376	0	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	113	113	113				
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Majpara, Tatula 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total					685	605	157	263	271	283	294	0	
Sub-total: Plants in operation					21673	21219	7607.0	8766	14275	15285	1856	1524	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							7268	8375	13638	14603			
(B) Plants under long term maintenance/ contract expired													
143	Ghorashal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
144	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0	0	0	0	
Gross Total					21967	21219	7607	8766	14275	15285	1856	1524	
(C) Actual data of 15.05.21 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 8766.00	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 8375.00	MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 9208.00	MW, at = 23:00 hrs		Dhaka	2402	2402	0	Mymensingh	762	762	0	
04.	Minimum Generation (Generation end)	: 6568.00	MW, at = 7:00 hrs		Chattogram	894	894	0	Sylhet	366	366	0	
05.	Day-peak Generation (Generation end)	: 7607.00	MW, at = 12:00 hrs		Khulna	1215	1215	0	Barishal	344	344	0	
06.	Evening-peak Generation (Generation end)	: 8766.00	MW, at = 21:00 hrs		Rajshahi	959	959	0	Rangpur	652	652	0	
07.	Evening Peak Load-shed (Sub-station end)	: 0.00	MW, at = 21:00 hrs		Cumilla	781	781	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	: 7153.00	MW, at = 5:00 hrs						Total	8375	8375	0	
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation	: 1355	MW										
	d) Coal supply Limitation	: 294	MW										
	b) Low water level in Kaptai lake	: 207	MW										
	c) Plants under shut down/ maintenance	: 1524	MW										
10.	Total Energy (Generation + India Import)	: 190.17	MKWh										
	By Gas =	135.954	MKWh										
	By Coal =	13.572	MKWh										
	By Solar =	0.788	MKWh										
	By Oil =		20.946	MKWh									
				0.472	MKWh								
11.	Total Gas Supplied	: 1141.58	MMCFD										
(D) Forecast of 16.05.21 (Today) Sunday :													
01.	Maximum Demand	: 11200	MW (Generation end)	04.	Maximum Load-shed	: 0	MW	At evening peak (Sub-station end)					
02.	Maximum Generation	: 15285	MW (Generation end)	05.	Total Generation	: 231.32	MKWh						
03.	Maximum Shortage	: -4085	MW (Generation end)	06.	Probable Max. Temperature in Dhaka	: 36.8° C							

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation