

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 18-May-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit	PDB	1210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1210	190	100	2252250	Dry wash
4	Ghorasal 365 MW CCPP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorashah 78.5 MW PPMAX	QRPP	240	0	0	0	Contract Expired
6	Ghorashah 108MW PP (Regen)	IPP	343.35	108	100	2183954	
7	Haripur GTTP	SBU_PDB	232	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1273+1139	412	46	6572030	Synchronized at 19:14
9	Haripur 360MW CCPP(HPL)	IPP	1235+1125	360	350	7360000	
10	Meghnaghat 450 MW CCPP(MP)	IPP	2150+1150	450	290	6837250	Gas shortage
11	Meghnaghat 100 MW (EL)	QRPP	128.9	100	0	0	Contract Expired
12	Meghnaghat CCPP(Summit)	IPP	2110+1110	305	275	6403869	FGMO
13	Madanganj 102 PP(Summit)	QRPP	617	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	317.08+111.3	55	45	1108136	Engine problem
15	Keraniganj 100 MW PP (Powerpa	QRPP	813.45	100	50	212069	Low demand
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	0	219132	Reserve.
17	210 MW Siddhirganj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirganj 2120 MW GTTP	EGCB	2105	210	175	3464000	FGMO
19	Siddhirganj 100 PP(Dutch Bangla	QRPP	128.9	100	80	1384224	Low demand
20	Siddhirganj 335 MW CCPP	EGCB	1217+118	335	221	5141966	ST Under Maint.
21	Gagnagar 102 MW PP (Digital P	IPP	128.924	102	0	141120	Reserve.
22	Katpotti 52 MW PP (Siraha)	IPP	77.9	51	0	0	Fuel shortage
23	Kamatnagar 54 MW PP(Banco E	IPP	319.8	54	17	519840	Reserve.
24	Kodda 150MW PP	BPDB-RPCL	917.06	149	0	100800	Reserve.
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	0	95966	Reserve.
26	Nabaganj 55 MW PP (Southern)	IPP	319.3	55	55	884054	
27	Bosila 108MW PP(CLG)	IPP	128.775+13.5	108	0	0	Fuel shortage
28	Summit Power, (Madhabdi+Ashul	SIPP, REB	33.67+48.73	80	30	736080	Engine problem
29	Machha 33 MW PP(Summit)	SIPP, REB	47.9	33	33	681900	
30	Ruganaj 33 MW PP(Summit)	SIPP, REB	48.73	33	17	488200	Engine problem
31	Gazipur 52 MW PP	IPP	68.9	52	0	179520	Reserve.
32	Tongi 80 MW GTTP	PDB	1105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Sumr	IPP	1817.076	300	0	205745	Reserve.
34	Keraniganj 300 MW PP (AFR)	IPP	2561.4	300	0	0	Reserve.
35	Bramhangaganj 100 MW PP (Agg	IPP	100	100	0	0	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Sumr	IPP	149	149	132	2538720	Engine problem
38	Gazipur 100 MW PP	RPCL	100 MW	105	52	925200	Low demand
39	Meghnaghat 104 MW PP (OPCL	IPP	18.515	104	94	1211520	Low demand
40	Manikganj 162MW PP(MPCL)	IPP	918	162	162	1370400	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	184036	
Dhaka area Total				5919	2324	53816821	
41	Chattoogram TPP-1	PDB	1210	180	0	0	Under maint.
42	Chattoogram TPP-2	PDB	1210	180	0	0	Gas shortage
43	Raozan 25 MW PP	IPP	38.9	25	17	401481	Engine problem
44	Tektari 20MW PP (Solar)Khatol Solar	IPP	20	20	0	103950	
45	Patenga 50MW PP (Baraka)	IPP	86.98	50	19	279840	Low demand
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	240+3*50	230	20	476340	Low water level & Unit-2 unc
47	Sikalbaha 225MW	PDB	1150+1175	225	208	4918711	FGMO
48	Sikalbaha Peaking GT	PDB	1150	150	110	2642958	
49	Sikalbaha 105 MW PP (Baraka S	IPP	105 MW	105	105	2479818	
50	Hathazari 100 MW peaking PP	PDB	118.9	98	0	0	Under S/D
51	Dohazari-Kalaish 100 MW Peak	PDB	617	102	85	870352	Engine problem
52	Juldah 100 MW Unit-1 (Acorn)	QRPP	813.45	100	100	2177280	
53	Juldah 100 MW PP Unit-3 (Acorn	IPP	0	100	100	2041920	
54	Barakunda 22 MW PP (Regent	SIPP, PDB	0	22	20	459976	
55	Mataraha, Ctg. EZZ	IPP	58.72+19.34	0	35	487680	
56	Chattoogram 108 MW PP (ECPV)	IPP	67	108	0	93120	Reserve.
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	35400	
58	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	0	0	Reserve.
59	Jodiak Power	IPP	318.55+13.6	54	54	1298632	
60	Karnaphuli Power Ltd.	IPP	110	110	17	216290	Low demand
61	Juldah unit-2 (Acorn)	IPP	813.6	100	100	1791360	
62	Anlima Energy Ltd.	IPP	621.2	116	74	2054945	Low demand
Chattoogram area Total				2382	1064	22831053	
61	Ashuganj TPP Unit- 3	APSCL	1150	135	0	0	Gas Shortage
62	Ashuganj TPP Unit- 4	APSCL	1150	129	0	0	Gas shortage
63	Ashuganj TPP Unit- 5	APSCL	1150	134	120	2664788	
64	Ashuganj 225 MW CCPP	APSCL	1144+2175	221	199	3484000	FGMO
65	Ashuganj 450 MW CCPP(North)	APSCL	1360	360	305	7701100	FGMO
66	Ashuganj 450 MW CCPP(South)	APSCL	1360	360	310	7247000	FGMO
67	Ashuganj 50 MW PP	APSCL	143.968	45	26	585720	Engine problem
68	Ashuganj 55 MW PP (Precision)	RPP	154	55	55	1202400	
69	Ashuganj 150MW PP (APCL-U)	IPP	2074+1116	195	16	334545	Gas shortage
70	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	51	1172362	
71	Ashuganj 150MW PP (Midland)	IPP	237.015	150	150	1207709	
72	Tilas 50 MW Peaking PP	PDB	68.92	52	0	0	Reserve.
73	Chandpur 150 MW CCPP	PDB	1106+157	163	90	2088730	Machine problem
74	Chandpur 200MW (Desh energy)	IPP	0	200	120	2891040	Engine problem
75	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	22	495144	
76	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	8	174780	Engine problem
77	Impropt (Tripura)	Imported power	0	160	162	2547840	
78	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	33	812700	
79	Jangalia 52 MW PP (Lakdanavi)	IPP	68.92	52	43	849547	Engine problem
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	33.67+26.97	25	0	327630	Engine problem
81	Cumilla 200 MW PP (B.Trac)	IPP	1541.1	200	0	0	Reserve.
82	Feni Lanka Power	IPP	718.415+19.78	114	0	43320	Reserve.
83	Chowmuhani 113 MW	IPP	129.78+23.1	113	119	2136120	
84	Bhairab 54.5 MW	IPP	318.2	54	0	548280	33 kV feeder fault.
Cumilla Area Total				3034	1819	38514775	
82	RPCL 210MW CCPP	IPP	435+1170	202	203	4579120	
83	Tangail 22 MW PP (Doreen)	SIPP, PDB	82.90	22	19	349800	Engine problem
84	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	95	55	1363200	Engine problem
85	Sarishabari 3 MW Solar Plant	IPP	13	3	0	10950	
86	Mymensingh 200 MW PP (Unite	IPP	200	200	70	492000	Low demand
87	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	115	2392800	
88	Sutakhirali 50 MW Solar PP	IPP	50	50	0	140300	
89	Tangail Palli Power Gen 22 MW	IPP	46.7	22	24	533040	
Mymensingh Area Total				709	486	9916968	
90	Fenchugonj CCPP Phase-1	PDB	232+133	70	0	286000	
91	Fenchugonj CCPP Phase-2	PDB	235+135	90	22	519480	
92	Kushkhara 163 MW CCPP (KP)	IPP	1109+1154	163	163	3645081	
93	Shahjibazar 330 MW CCPP	PDB	3110	330	330	7510000	
94	Fenchugonj 51 MW PP (Barakat	RPP	192.90	51	50	1033200	
95	Fenchugonj 44MW (Energyprim	RPP	1213.3+52	0	0	0	Contract Expired
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	5	160500	Engine problem
97	Shahjibazar GTTP Unit- 8 & 9	PDB	235	66	40	934176	Engine problem
98	Shahjibazar 80MW PP (Shahjiba	RPP	322.90	86	76	1556160	Engine problem
99	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under Shut down
100	Sylhet 225 MW CCPP	PDB	1142+1189	231	140	3446710	
101	Sylhet 20 MW GTTP	PDB	120	20	18	410000	
102	Sylhet 50MW PP (EPL)	RPP	272	0	0	0	Contract Expired
103	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	16	352255	Engine problem
104	Bibiana-II 341 MW CCPP (Summ	IPP	1222+1119	341	0	0	Under maint.
105	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	375	8931000	FGMO
106	Sylhet 10MW PP (Desh)	RPP	61.95	10	7	138960	Engine problem
107	Bibiyana South 400 MW	PDB	400 MW	383	400	9221300	
Sylhet Area Total				2377	1642	38144822	
108	Bheramara GTTP Unit-3	PDB	120	16	0	0	
109	Bheramara (NWDCL)	Imported power	21500	1000	844	2109090	
110	Khulna 115 PP MW (KPCL-2)	QRPP	717	115	99	2096640	Engine problem
111	Fariapur 50 MW Peaking PP	PDB	68.89	54	0	0	Reserve.
112	Khulna 225 MW CCPP	NWPGCL	1150+1175	230	0	0	Reserve.
113	Gopalganj 100 MW Peaking PP	PDB	169.98	109	0	0	Reserve.
114	Bheramara 410 MW CCPP	NWPGCL	1278+1132	410	305	6524064	FGMO
115	Noapara 40 MW PP (Karnaphu	QRPP	518.5	40	0	277500	Reserve.
116	Noapara 100 MW PP (Bangla Tr	IPP	701.4	100	0	239040	Reserve.
117	Rupsha 105 MW PP (Orion rupa	IPP	618.445	105	105	1644960	
118	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1353	31863363	
118	Barisal 110 MW PP (Summit)	IPP	717.076	110	48	1186664	Line over load.
119	Bhola 33 MW PP (Venture)	RPP	134.50	33	34	719956	
120	Bhola 225 MW CCPP	PDB	263+1168	194	87	2022327	Machine problem
121	Bhola 95 MW PP (Aggreko)	QRPP	961.10	95	83	2125660	Engine problem
122	Payra 1320 MW	BCPCL	2622	1244	490	13230800	
123	Bhola Nutan Biddut BD LTD	IPP	220	0	0	0	On Test
124	United Payra Power Ltd.	IPP	618.5+19.5	150	0	376600	
Barisal Area Total				1826	742	19651907	
124	Baghabari 71 MW GTTP	PDB	171	71	0	0	Gas shortage
125	Baghabari 100 MW GTTP	PDB	1100	100	0	0	Gas shortage.
126	Baghabari 50 MW Peaking PP	PDB	68.9	52	50	498752	
127	Bera 70 MW Peaking PP	PDB	98.29	71	0	0	Reserve.
128	Annara 50 MW PP(Siraha)	QRPP	77.79	50	0	0	Reserve.
129	Katakhal 50 MW PP (Northern)	QRPP	68.9	50	0	0	Reserve.
130	Katakhal 50 MW Peaking PP	PDB	68.7	50	0	22295	Reserve.
131	Sirajgonj Unit-1 225MW	NWPGCL	1150+1175	210	115	2479200	Gas shortage
132	Sirajgonj Unit-2 225MW	NWPGCL	1150+1175	220	136	3463764	FGMO
133	Sirajgonj Unit-3 225MW	NWPGCL	1141	220	145	3698236	FGMO
134	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1282+1132	414	406	9176600	FGMO
135	Santalhar 50 MW Peaking PP	PDB	68.7	50	28	102281	
136	Bogra 22 MW PP (GBB)	RPP	64	22	18	396240	Engine problem
137	Bogra 20 MW PP (Energyprima	RPP	53.3+52	0	0	0	Contract Expired
138	Uliapara 11 MW PP (Summit)	SIPP, REB	42.90	11	11	202500	
139	Natore 52 MW PP (Sajjanka)	IPP	68.92	52	52	807360	
140	Chapainawabganj 100 MW Peak	PDB	128.924	104	96	770232	
141	Baghabari 200 MW PP (Paramo	IPP	200 MW	200	0	0	Reserve.
142	Bagura 113 MW PP (Confidenc	IPP	113 MW	113	113	1123008	
143	Confidence Power Bogura Unit-1	IPP	618.55	113	113	804480	
144	Sirajgonj 6.55 MW Solar	NWPGCL	16	6	0	17040	
Rajshahi Area Total				2179	1285	23891988	
144	Barapukuria TPP Unit-1	PDB	1125	85	0	0	Coal shortage
145	Bar						