

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 21-May-21

Page -2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present | Peak | Energy | Remarks |
|------------------------------|--|----------------|---------------------|-------------|-------------|-----------------|------------------------------|
| | | | | Capacity | Hour | Generated | |
| | | | Unit No. X Capacity | MW | MW | KWH | |
| 1 | Ghorasal Repowered CAPP Unit-1 | PDB | 1260 | 260 | 0 | 0 | Under maint. |
| 2 | Ghorasal Repowered CAPP Unit-2 | PDB | 1210 | 180 | 0 | 0 | Under maint. |
| 3 | Ghorasal TPP Unit-5 | PDB | 1210 | 190 | 190 | 4441500 | |
| 4 | Ghorasal 365 MW CAPP Unit-7 | PDB | 1243+1122 | 365 | 0 | 0 | Under maint. |
| 5 | Ghorasal 78.5 MW PP(MAX) | QRPP | 240 | 0 | 0 | 0 | Contract Expired |
| 6 | Ghorasal 108MW PP (Regen) | IPP | 343.35 | 108 | 101 | 2017727 | |
| 7 | Haripur GTPP | SBU, PDB | 232 | 20 | 0 | 0 | Under maint. |
| 8 | Haripur 412 MW CAPP | EGCB | 1273+1139 | 412 | 350 | 8200199 | FGMO |
| 9 | Haripur 360MW CAPP(HPL) | IPP | 1235+1125 | 360 | 340 | 7640000 | Gas shortage |
| 10 | Meghnaghat 450 MW CAPP(MP) | IPP | 2150+1150 | 450 | 300 | 7081750 | Gas shortage |
| 11 | Meghnaghat 100 MW (EL) | QRPP | 128.9 | 100 | 0 | 0 | Contract Expired |
| 12 | Meghnaghat CAPP(Summit) | IPP | 2110+1110 | 305 | 260 | 6469440 | FGMO |
| 13 | Madanganj 102 PP(Summit) | QRPP | 617 | 0 | 0 | 0 | Contract Expired |
| 14 | Madanganj-55 MW PP(Summit) | (IPP) | 317.08+111.3 | 55 | 55 | 1169386 | |
| 15 | Keraniganj 100 MW PP (Powerpa) | QRPP | 813.45 | 100 | 0 | 0 | Reserve. |
| 16 | Narsingdi 22 MW PP (Doreen) | SIPP, REB | 82.90 | 22 | 19 | 404424 | Engine problem |
| 17 | 210 MW Siddhirganj TPP | PDB | 1210 | 115 | 0 | 0 | Under maint. |
| 18 | Siddhirganj 2120 MW GTPP | EGCB | 2105 | 210 | 150 | 3120000 | Gas shortage. |
| 19 | Siddhirganj 100 PP(Dutch Bangla) | QRPP | 128.9 | 100 | 95 | 1111680 | |
| 20 | Siddhirganj 335 MW CAPP | EGCB | 1217+118 | 335 | 212 | 4730893 | ST under Maint. |
| 21 | Gagnagar 102 MW PP (Digital P) | IPP | 128.924 | 102 | 72 | 419616 | Low demand |
| 22 | Katpott 52 MW PP (Sinha) | IPP | 77.9 | 51 | 0 | 0 | Fuel shortage |
| 23 | Kamatnagar 54 MW PP(Banco E) | IPP | 319.8 | 54 | 32 | 59120 | Engine problem |
| 24 | Kodda 150MW PP | BPDB-RPCL | 917.06 | 149 | 98 | 684960 | Low demand |
| 25 | Manikganj 55 MW PP (Northern) | IPP | 319.3 | 55 | 35 | 474097 | |
| 26 | Nabaganj 55 MW PP (Southern) | IPP | 319.3 | 55 | 35 | 789764 | Engine problem |
| 27 | Bosila 108MW PP(CLG) | IPP | 128.775+13.5 | 108 | 0 | 0 | Fuel shortage |
| 28 | Summit Power, Madhabdi+Ashul | SIPP, REB | 33.67+48.73 | 80 | 39 | 992620 | Engine problem |
| 29 | Machha 33 MW PP(Summit) | SIPP, REB | 47.83 | 33 | 33 | 793000 | |
| 30 | Ruganaj 33 MW PP(Summit) | SIPP, REB | 47.83 | 33 | 33 | 519000 | Engine problem |
| 31 | Gazipur 52 MW PP | IPP | 67.9 | 52 | 41 | 700800 | |
| 32 | Tongi 80 MW GTPP | PDB | 1105 | 105 | 0 | 0 | Under maint. |
| 33 | Kodda 300 MW PP Unit-2 (Sumr) | IPP | 1817.076 | 300 | 185 | 928363 | Low demand |
| 34 | Keraniganj 300 MW PP (AFR) | IPP | 2581.4 | 300 | 0 | 0 | Reserve. |
| 35 | Bramhangonj 100 MW PP (Agg) | IPP | 100 | 100 | 0 | 0 | Reserve. |
| 36 | Auraha 100MW PP (Aggreko) | IPP | 0.8523+0.9591 | 100 | 0 | 0 | Reserve. |
| 37 | Kodda 149 MW PP Unit-1 (Sumr) | IPP | 149 | 149 | 149 | 2760912 | |
| 38 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 105 | 607200 | |
| 39 | Meghnaghat 104 MW PP (OPCL) | IPP | 18.576 | 104 | 72 | 563520 | |
| 40 | Manikganj 162MW PP(MPCL) | IPP | 918 | 162 | 162 | 1104480 | Engine problem |
| 41 | Spectra Solar Plant Ltd. | IPP | 35 | 35 | 0 | 224803 | |
| Dhaka area Total | | | | 5919 | 3186 | 58540854 | |
| 41 | Chattogram TPP-1 | PDB | 1210 | 180 | 0 | 0 | Under maint. |
| 42 | Chattogram TPP-2 | PDB | 1210 | 180 | 0 | 0 | Gas shortage |
| 43 | Raazan 25 MW PP | IPP | 37.9 | 25 | 17 | 346327 | Engine problem |
| 44 | Teknaf 20MW PP (Solar)Teknaf Solar Tech Energy | IPP | 20 | 20 | 0 | 110160 | |
| 45 | Patenga 50MW PP (Baraka) | IPP | 86.98 | 50 | 12 | 85440 | Low demand |
| 46 | Kaptai Hydro: Unit-1,2,3,4, 5 | PDB | 240+3*50 | 230 | 25 | 608000 | Low water level & Unit-2 unc |
| 47 | Sikalbaha 225MW | PDB | 1150+1175 | 225 | 140 | 1809585 | FGMO |
| 48 | Sikalbaha Peaking GT | PDB | 1150 | 150 | 110 | 2560178 | |
| 49 | Sikalbaha 105 MW PP (Baraka S) | IPP | 105 | 69 | 69 | 1966290 | Engine problem |
| 50 | Hathazari 100 MW peaking PP | PDB | 118.9 | 98 | 0 | 0 | Under S/D |
| 51 | Dohazari-Kalaish 100 MW Peak | PDB | 617 | 102 | 68 | 573501 | Engine problem |
| 52 | Juidah 100 MW Unit-1 (Acorn) | QRPP | 813.45 | 100 | 100 | 2141040 | |
| 53 | Juidah 100 MW PP Unit-3 (Acorn) | IPP | 0 | 100 | 100 | 2406720 | |
| 54 | Barakunda 22 MW PP (Regent) | SIPP, PDB | 82.90 | 22 | 17 | 446556 | |
| 55 | Malancha, Ctg. E22 | IPP | 578.722+19.34 | 0 | 0 | 743040 | |
| 56 | Chattogram 108 MW PP (ECPV) | IPP | 67 | 108 | 50 | 317760 | Low demand |
| 57 | Kaptai 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 35039 | |
| 58 | Anwara 300 MW PP (Uniled) | IPP | 300 MW | 300 | 0 | 87818 | Reserve. |
| 59 | Jodiak Power | IPP | 318.55+13.6 | 54 | 54 | 1199394 | |
| 60 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 17 | 1288835 | Low demand |
| 61 | Juidah unit-2 (Acorn) | IPP | 813.6 | 100 | 100 | 2310240 | |
| 62 | Anlima Energy Ltd. | IPP | 621.2 | 116 | 99 | 2204236 | |
| Chattogram area Total | | | | 2382 | 1036 | 21304259 | |
| 61 | Ashuganj TPP Unit- 3 | APSCL | 1150 | 135 | 0 | 0 | Gas Shortage |
| 62 | Ashuganj TPP Unit- 4 | APSCL | 1150 | 129 | 0 | 0 | Gas shortage |
| 63 | Ashuganj TPP Unit- 5 | APSCL | 1150 | 134 | 80 | 2213978 | Gas shortage |
| 64 | Ashuganj 225 MW CAPP | APSCL | 1142+175 | 221 | 187 | 4768600 | FGMO |
| 65 | Ashuganj 450 MW CAPP(North) | APSCL | 1360 | 360 | 260 | 6914000 | FGMO |
| 66 | Ashuganj 450 MW CAPP(South) | APSCL | 1360 | 360 | 265 | 6800000 | FGMO |
| 67 | Ashuganj 50 MW PP | APSCL | 143.968 | 45 | 26 | 567000 | Engine problem |
| 68 | Ashuganj 55 MW PP (Precision) | RPP | 154 | 55 | 54 | 1226400 | Gas shortage |
| 69 | Ashuganj 150MW PP (APCL-U) | IPP | 2073+1116 | 185 | 6 | 217454 | Gas shortage |
| 70 | Ashuganj 51 MW PP (Midland) | IPP | 69.34 | 51 | 51 | 1204696 | |
| 71 | Ashuganj 150MW PP (Midland) | IPP | 237.015 | 150 | 143 | 1114036 | |
| 72 | Tilas 50 MW Peaking PP | PDB | 67.92 | 52 | 0 | 0 | Reserve. |
| 73 | Chandpur 150 MW CAPP | PDB | 1106+157 | 163 | 89 | 2106880 | Machine problem |
| 74 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 120 | 2563200 | Engine problem |
| 75 | Feni 22MW PP (Doreen) | SIPP, PDB | 82.90 | 22 | 22 | 437148 | |
| 76 | Feni 11 MW PP (Doreen) | SIPP, REB | 42.90 | 11 | 10 | 151020 | |
| 77 | Impoort (Tripura) | Imported power | 0 | 160 | 168 | 3576960 | |
| 78 | Jangalia 33MW PP (Summit) | SIPP, PDB | 47.83 | 33 | 33 | 816900 | |
| 79 | Jangalia 52 MW PP (Lakdanavi) | IPP | 67.92 | 52 | 52 | 971102 | |
| 80 | Cumilla 25 MW PP (Summit) | SIPP, PDB | 33.67+26.97 | 25 | 19 | 464800 | Engine problem |
| 81 | Cumilandi 200 MW PP (B.Trac) | IPP | 15411.4 | 200 | 0 | 0 | Reserve. |
| 82 | Feni Lanka Power | IPP | 718.415+19.78 | 114 | 114 | 788880 | |
| 83 | Chowmuhani 113 MW | IPP | 129.78+23.1 | 113 | 119 | 2151240 | |
| 84 | Bhairab 54.5 MW | IPP | 318.2 | 54 | 36 | 519480 | 33 kV feeder fault. |
| Cumilla Area Total | | | | 3034 | 1866 | 39571154 | |
| 82 | RPCL 210MW CAPP | IPP | 435+1170 | 202 | 176 | 466350 | Gas shortage |
| 83 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 82.90 | 22 | 19 | 423388 | Engine problem |
| 84 | Jamalpur 95 MW PP(Powerpac) | IPP | 128.924 | 63 | 63 | 1429440 | Engine problem |
| 85 | Sarishabari 3 MW Solar Plant | IPP | 13 | 3 | 0 | 10550 | |
| 86 | Mymensingh 200 MW PP (Unite) | IPP | 200 | 131 | 700800 | Low demand | |
| 87 | Jamalpur 115 MW PP (Uniled) | IPP | 115 MW | 115 | 115 | 2065200 | |
| 88 | Sutakhirali 50 MW PP | IPP | 50 | 50 | 0 | 311310 | |
| 89 | Tangail Palli Power Gen 22 MW | IPP | 46.7 | 22 | 23 | 572160 | |
| Mymensingh Area Total | | | | 709 | 527 | 9572508 | |
| 90 | Fenchugonj CAPP Phase-1 | PDB | 232+133 | 70 | 42 | 1007000 | Machine problem |
| 91 | Fenchugonj CAPP Phase-2 | PDB | 235+135 | 90 | 0 | 514080 | Machine problem |
| 92 | Kushkhara 163 MW CAPP (KP) | IPP | 1109+154 | 163 | 130 | 3296945 | frequency control. |
| 93 | Shahjibazar 330 MW CAPP | PDB | 3110 | 330 | 328 | 8615050 | |
| 94 | Fenchugonj 51 MW PP (Barakat) | RPP | 192.90 | 51 | 50 | 1053600 | |
| 95 | Fenchugonj 44MW (Energyprima) | RPP | 1213.3+52 | 0 | 0 | 0 | Contract Expired |
| 96 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 42.90 | 11 | 11 | 207100 | |
| 97 | Shahjibazar GTPP Unit- 8 & 9 | PDB | 235 | 66 | 52 | 696384 | Engine problem |
| 98 | Shahjibazar 80MW PP (Shahjiba) | RPP | 322.90 | 86 | 76 | 1579200 | Engine problem |
| 99 | Shahjibazar 100 MW GTPP | PDB | 1100 | 100 | 0 | 0 | Under Shut down |
| 100 | Sylhet 225 MW CAPP | PDB | 1142+1189 | 231 | 140 | 2963270 | |
| 101 | Sylhet 20 MW GTPP | PDB | 120 | 20 | 18 | 396000 | Machine problem |
| 102 | Sylhet 50MW PP (EPL) | RPP | 272 | 0 | 0 | 0 | Contract Expired |
| 103 | Shahjibazar 25 MW PP | SIPP, REB | 37.94 | 25 | 16 | 367416 | Engine problem |
| 104 | Bibiana-II 341 MW CAPP (Summ) | IPP | 1122+1119 | 341 | 310 | 7357500 | FGMO |
| 105 | Bibiyana-III 400 MW CAPP | PDB | 400 MW | 400 | 367 | 8728000 | FGMO |
| 106 | Sylhet 10MW PP (Desh) | RPP | 61.95 | 10 | 7 | 155340 | Engine problem |
| 107 | Bibiyana South 400 MW | PDB | 400 MW | 383 | 396 | 8636000 | FGMO |
| Sylhet Area Total | | | | 2377 | 1943 | 43572835 | |
| 108 | Bheramara GTPP Unit-3 | PDB | 120 | 16 | 0 | 0 | |
| 109 | Bheramara (NWD) | Imported power | 2150 | 1000 | 915 | 22213636 | |
| 110 | Khulna 115 PP MW (KPCL-2) | QRPP | 717 | 115 | 73 | 1044960 | Engine problem |
| 111 | Fariapur 50 MW Peaking PP | PDB | 67.98 | 54 | 0 | 0 | Reserve. |
| 112 | Khulna 225 MW CAPP | NWPGCL | 1150+1175 | 230 | 0 | 0 | Reserve. |
| 113 | Gopalganj 100 MW Peaking PP | PDB | 167.98 | 109 | 0 | 0 | Reserve. |
| 114 | Bheramara 410 MW CAPP | NWPGCL | 1278+1132 | 410 | 350 | 7636480 | FGMO |
| 115 | Noapara 40 MW CAPP (Karnaphu) | QRPP | 51.8 | 40 | 32 | 328250 | Engine problem |
| 116 | Noapara 100 MW PP (Bangla Tr) | IPP | 701.4 | 100 | 98 | 574080 | |
| 117 | Rupsha 105 MW PP (Orion rupsa) | IPP | 618.445 | 105 | 105 | 1466880 | |
| 118 | Madhumati 100 MW PP | NWPGCL | 100 MW | 105 | 0 | 0 | Reserve. |
| Khulna Area Total | | | | 2284 | 1573 | 34362286 | |
| 118 | Barisal 110 MW PP (Summit) | IPP | 717.076 | 110 | 110 | 1457164 | |
| 119 | Bhola 33 MW PP (Venture) | RPP | 134.50 | 33 | 34 | 690386 | |
| 120 | Bhola 225 MW CAPP | PDB | 263+1168 | 194 | 85 | 2062489 | |
| 121 | Bhola 95 MW PP (Aggreko) | QRPP | 961.10 | 95 | 96 | 2222010 | |
| 122 | Payra 1320 MW | BCPCL | 2622 | 1244 | 520 | 12662400 | |
| 123 | Bhola Nutan Biddut BD LTD | IPP | 220 | 0 | 27 | 301718 | On Test |
| 124 | Uniled Payra Power Ltd. | IPP | 618.5+19.5 | 150 | 44 | 555600 | Low demand |
| Barisal Area Total | | | | 1826 | 916 | 19960787 | |
| 124 | Baghabari 71 MW GTPP | PDB | 171 | 71 | 0 | 0 | Gas shortage |
| 125 | Baghabari 100 MW GTPP | PDB | 1100 | 100 | 0 | 0 | Gas shortage. |
| 126 | Baghabari 50 MW Peaking PP | PDB | 67.9 | 52 | 50 | 312384 | |
| 127 | Bera 70 MW Peaking PP | PDB | 97.29 | 71 | 0 | 0 | Reserve. |
| 128 | Annara 50 MW PP(Sinha) | QRPP | 77.79 | 50 | 0 | 0 | Reserve. |
| 129 | Katakhal 50 MW PP (Northern) | QRPP | 67.9 | 50 | 0 | 0 | Reserve. |
| 130 | Katakhal 50 MW Peaking PP | PDB | 67.8 | 50 | 0 | 0 | Reserve. |
| 131 | Sirajgonj Unit-1 225MW | NWPGCL | 1150+1175 | 210 | 80 | 2667600 | Gas shortage |
| 132 | Sirajgonj Unit-2 225MW | NWPGCL | 1150+1175 | 220 | 146 | 3931882 | FGMO |
| 133 | Sirajgonj Unit-3 225MW | NWPGCL | 1141 | 220 | 130 | 4244309 | FGMO |
| 134 | Sirajgonj 400 MW CAPP Unit-4 | SNWPGCL | 11282+1132 | 414 | 397 | 8883455 | FGMO |
| 135 | Sanlahar 50 MW Peaking PP | PDB | 67.8 | 50 | 0 | 0 | Engine problem |
| 136 | Bogra 22 MW PP (GBB) | RPP | 64 | 22 | 20 | 423360 | Engine problem |
| 137 | Bogra 20 MW PP (Energyprima) | RPP | 53.3+52 | 0 | 0 | 0 | Contract Expired |
| 138 | Uliapara 11 MW PP (Summit) | SIPP, REB | 42.90 | 11 | 11 | 226008 | |
| 139 | Natore 52 MW PP (Rajshahi) | IPP | 67.92 | 52 | 52 | 847200 | |
| 140 | Chapainawabganj 100 MW Peak | PDB | 128.924 | 104 | 96 | 734248 | |
| 141 | Baghabari 200 MW PP (Paramo) | IPP | 200 MW | 200 | 0 | 0 | Reserve. |
| 142 | Bagura 113 MW PP (Confidenc) | IPP | 113 MW | 113 | 112 | 704831 | |
| 143 | Confidence Power Bogura Unit-1 | IPP | 618.55 | 113 | 113 | 575616 | |
| 143 | Sirajgonj 6.55 MW Solar | NWPGCL | 16 | 6 | 0 | 17280 | |
| Rajshahi Area Total | | | | 2179 | 1209 | 23573173 | |
| 144 | Barapukuria TPP Unit-1 | PDB | 1125 | 85 | 0 | 0 | Coal shortage |
| 1 | | | | | | | |