

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 954667, 9551095

Month May, 2021		Day: Saturday				Date: 22.05.21					
Probable Maximum Demand :		13000 MW		Yesterday = 74.57 ft		Today = 74.44 ft		Probable Maximum Generation : 15750 MW		Rule Curve = 78.00 ft.	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.05.21 (Yesterday)		22.05.21 (Today)		21.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	101	100	102		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	339	340	360	360		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	339	350	350	360	62	Dirty in gas
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	70	150	185	200	60	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	209	212	220	220	123	ST under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	2	95	100	100		
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	270	260	260	260		
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
16	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	36	55	55	55		
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	72	102	102		
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	15	20		
20	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	37	39	45	45		
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	33	33	33		
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	41	41	41		
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	105	105		
25	Kodda 150MW PP	HFO (B/PDB-RPCL)	9x17.06	149	149	0	98	150	150		
26	Katpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
27	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	35	35		
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	185	245	245		
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	99	149	149	149		
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300		
31	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Aurshahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
33	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	25	35	35	35		
34	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55		
35	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	72	72	72		
37	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	162	162	162		
38	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	27	0	30	0		
Dhaka Zone Total			6076	5919	2164	3186	3727	4029	272	1168	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	6	0	5	0		
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17		
43	Taknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	12	43	43		
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	70	89	70	90		
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	110	110	110		
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	140	130	210	85	Under maint.
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300		
49	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	100	100	100		
50	Juddah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68		
52	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	17	17	17		
**	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			16	38	22	30		
54	Chatto gram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	1	50	100	100		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	39	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	85	17	110	110		
57	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
58	Chatto gram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	99	99	99	99		
Chatto gram Zone Total			2442	2382	782	1036	1490	1573	205	445	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	100	80	80	80	54	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+175	221	221	185	197	215	215		
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	270	265	330	330		
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	315	260	330	330		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	51	54	55	55		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	143	150	150		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	92	89	90	90	74	Gas Shortage
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	85	120	120	120		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11		
73	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	32	52	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	19	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x14+8x1.515+15x1.058	200	200	0	0	100	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	114	114		
78	Chowmahani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	69	119	113	113		
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	18	36	35	36		
**	Impport (Tripura)	India		160	160	136	168	157	190		
Cumilla Zone Total			3094	3034	1516	1866	2112	2296	579	0	
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	162	176	190	200		
81	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19		
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	55	63	64	64		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	35	115	115	115		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	131	200	200		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0		
86	Sulekhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	22	0	50	0		
87	Tangali 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	22	23	22	22		
Mymensingh Zone Total			717	709	318	527	662	620	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.05.21 (Yesterday)		22.05.21 (Today)		21.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Water/Coal limitation (MW)	Machines shut down (MW)			
88	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42		28	Under maint.	
89	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	0	0	0		90	Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	51	51				
91	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	52	52	52				
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	158	328	154	330				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	74	76	76	76				
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	140	140	0	140				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	6	7	7	7				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bitiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	300	341				
101	Bitiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	368	367	400	400				
102	Bitiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	350	396	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1742	1943	1690	2047	0	118	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	320	350	410	410				
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	73	99	99				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	98	50	100				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32	32				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	105	105				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	100	100	100				
**	Bheramara (HVDC)	India		1000	1000	915	915	932	932				
Khulna Zone Total					2288	2284	1335	1573	1808	2078	0	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	25	34	33	33				
116	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	82	85	88	88			109	GT-2 & STG Under maint.
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	87	96	95	95				
118	Payra 130 MW TPP	Coal (BCPCL)	2x622	1244	1244	430	520	622	622				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	44	0	80				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				6	27	50	50				
Barishal Zone Total					1826	1826	630	916	998	1078	0	109	
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40				
124	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	40	42				
125	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	98	100	100				
126	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	30				
127	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
128	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	32				
129	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	124	80	100	100		70	Gas Shortage	
130	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	159	146	200	200		74	Gas Shortage	
131	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	182	130	200	200		90	Gas Shortage	
132	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	363	397	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	20	20	20				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	9	11	11	11				
135	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	16	52	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	113	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	112	113	113				
138	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	0	0				
Rajshahi Zone Total					2179	2179	873	1209	1712	1746	405	0	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150		124	Coal Shortage	
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	113	113	113				
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
144	Majpara, Tutula 5 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
Rangpur Zone Total					685	605	186	263	271	283	294	0	
Sub-total: Plants in operation					21729	21315	9546.0	12519	14470	15750	1755	1840	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							9115	11954	13817	15039			
(B) Plants under long term maintenance/ contract expired													
145	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired							294	0	0	0	0		
Gross Total					22023	21315	9546	12519	14470	15750	1755	1840	

(C) Actual data of 21.05.21 (Yesterday)				Friday :				Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
Sl. No.	Description	Value	Unit	Sl. No.	Description	Value	Unit	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
01.	Max. Demand at eve. peak (Generation end)	12519.00	MW	at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :		Dhaka	3778	3778	0	Mymensingh	1026	1026	0
02.	Max. Demand at eve. peak (Sub-station end)	11954.00	MW	at = 21:00 hrs				Chattogram	1323	1323	0	Sylhet	497	497	0
03.	Highest Generation (Generation end)	12561.00	MW	at = 23:00 hrs				Khulna	1605	1605	0	Barishal	408	408	0
04.	Minimum Generation (Generation end)	8870.00	MW	at = 8:00 hrs				Rajshahi	1226	1226	0	Rangpur	794	794	0
05.	Day-peak Generation (Generation end)	9546.00	MW	at = 12:00 hrs				Cumilla	1297	1297	0				
06.	Evening-peak Generation (Generation end)	12519.00	MW	at = 21:00 hrs											
07.	Evening Peak Load-shed (Sub-station end)	0.00	MW	at = 21:00 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	9349.00	MW	at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :														
	a) Gas limitation	1256	MW												
	d) Coal supply Limitation	294	MW												
	b) Low water level in Kaptai lake	205	MW												
	c) Plants under shut down/ maintenance	1840	MW												
10.	Total Energy (Generation + India Import)	255.48	MKWh												
	By Gas =	154.951	MKWh												
	By Oil =	57.045	MKWh												
	By Coal =	16.344	MKWh												
	By Solar =	0.744	MKWh												
11.	Total Gas Supplied	1280.25	MMCFD												
(D) Forecast of 22.05.21 (Today) Saturday :															
01.	Maximum Demand	13000	MW	(Generation end)	04.	Maximum Load-shed	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	15750	MW	(Generation end)	05.	Total Generation	264.41	MKWh							
03.	Maximum Shortage	-2750	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	38.7° C								