

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month May, 2021		Day : Thursday		Date : 27.05.21							
Probable Maximum Demand :		12500 MW		Probable Maximum Generation : 15225 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 73.51 ft		Today = 73.27 ft							
Rule Curve = 77.00 ft.											
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.05.21 (Yesterday)		27.05.21 (Today)		26.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Water/Cool limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	80	104	104	104		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	154	85	150	150		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	351	340	350	350		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	150	185	140	180	25	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	220	220	220	220	115	ST Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	70	91	91	91		
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	245	270	270	270		
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
16	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55		
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	87	86	87		
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	102	102	102		
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	19	20	20		
20	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	37	43	45	45		
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33		
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33		
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	42	41	42		
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	86	86	86	86		
25	Kodda 150MW PP	HFO (BPPDB-RPCL)	9x17.06	149	149	16	150	150	150		
26	Katpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
27	Kamalghat 54 MW PP (Banoo Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35		
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	231	245	245		
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	33	130	130	130		
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300		
31	Bramhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Aurshahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
33	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	8	35	55	55		
34	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	55	55		
35	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	90	90	90		
37	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	4	144	144	144		
38	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	11	0	30	0		
Dhaka Zone Total			6076	5919	2061	3115	3480	3742	175	1160	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0		
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
43	Taknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	0	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	44	50	50		
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	53	53	53	53		
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	120	125	125		
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	204	205	220	220		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300		
49	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	88	88	88		
50	Juddah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	50	20	100	100		
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68		
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			8	31	10	30		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	6	6	6		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	77	68	110	110		
57	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	10	10	100	100		
58	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	35	17	116	116		
Chattogram Zone Total			2442	2382	793	848	1489	1484	385	180	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	80	80	80	80	49	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	80	100	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	25	26	26	26		
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1175	221	221	201	165	215	215		
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	265	290	330	330		
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	275	270	360	360		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50	Gas shortage
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	150	150	150		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	90	80	90	90	73	Gas Shortage
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	85	85	85	85		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
73	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33		
74	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	21	20	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x14+86x1.515+15x1.058	200	200	0	0	100	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	88	114	114	114		
78	Chowmahani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	102	120	113	113		
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
**	Impoort (Tijura)	India		160	160	102	132	145	181		
Cumilla Zone Total			3094	3034	1526	1760	2125	2332	628	0	
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	135	135	150	150	70	Gas Shortage
81	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	19	19	19		
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	22	24	24	24		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	115	115	115		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	186	200	200		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	33	0	50	0		
87	Tangali 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	0	24	22	22		
Mymensingh Zone Total			717	709	239	500	582	530	70	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.05.21 (Yesterday)		27.05.21 (Today)		26.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42		28	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	110	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	56	56	56				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	160	163	163	163				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	77	76	77				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	145	140	140	140		91	STG Under maint.	
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	5	7	7	7				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	341	341				
101	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	369	370	400	400				
102	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	383	394	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1843	1799	1926	1927	0	167	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	220	235	410	410	175		Gas Shortage	
106	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	16	115	115	115				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
111	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32	32				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	70	105	105				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	514	798	523	812				
Khulna Zone Total					2288	2284	750	1250	1415	1974	175	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	30	33	33				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	85	88	88		109	GT-2 & STG Under	
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	32	53	95	95				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	310	500	622	622				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	110	165				
Barisal Zone Total					1826	1826	446	716	1058	1223	0	109	
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40				
124	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	40	42				
125	Chapanawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	81	98	100	100				
126	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	30				
127	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	85	84	100	100	66		Gas Shortage, STG S/D	
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	146	144	200	200	76		Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	160	160	200	200	60		Gas Shortage	
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	407	417	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	20	20	20				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	0	113	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	9	94	94	94				
138	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total					2179	2179	967	1278	1699	1730	373	0	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x2x3	113	113	0	113	113	113				
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
144	Maipara, Tatula 6 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total					685	665	155	263	271	283	294	0	
Sub-total: Plants in operation					21729	21315	8780.0	11529	14045	15225	2100	1616	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss					8383	11008	13410	14537					
(B) Plants under long term maintenance/ contract expired													
145	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0				
Gross Total					22023	21315	8780	11529	14045	15225	2100	1616	
(C) Actual data of 26.05.21 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	: 11529.00 MW, at = 21:00 hrs				12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	: 11008.00 MW, at = 21:00 hrs				Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	: 11529.00 MW, at = 21:00 hrs				Dhaka	3827	3827	0	Mymensingh	957	957	0
04.	Minimum Generation (Generation end)	: 8403.00 MW, at = 8:00 hrs				Chattogram	1199	1199	0	Sylhet	508	508	0
05.	Day-peak Generation (Generation end)	: 8780.00 MW, at = 12:00 hrs				Khulna	1294	1294	0	Barisal	267	267	0
06.	Evening-peak Generation (Generation end)	: 11529.00 MW, at = 21:00 hrs				Rajshahi	1131	1131	0	Rangpur	783	783	0
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs				Cumilla	1042	1042	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8441.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation	: 1601 MW											
	d) Coal supply Limitation	: 294 MW											
	b) Low water level in Kaptai lake	: 205 MW											
	c) Plants under shut down/ maintenance	: 1616 MW											
10.	Total Energy (Generation + India Import)	: 235.04 MKWh											
	By Gas =	147.927 MKWh		By Oil =		53.975 MKWh							
	By Coal =	13.613 MKWh		By Hydro =		0.600 MKWh							
	By Solar =	0.499 MKWh											
11.	Total Gas Supplied	: 1225.63 MMCFD											
13.	Fuel cost :	(a) Gas = 159209031 Taka (b) Oil = 397453895 Taka (c) Coal = 63558967 Taka Total = 620221893 Taka											
14.	Maximum Temperature in Dhaka was :	30° C											
15.	Export through East-West interconnections :												
	At evening peak-hour	: -155 MW, at		21:00 hrs									
	Maximum	: -155 MW, at		21:00 hrs									
	Energy	: 0.247 MKWh											
(D) Forecast of 27.05.21 (Today) Thursday :													
01.	Maximum Demand	: 12500 MW (Generation end)		04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 15225 MW (Generation end)		05. Total Generation : 254.83 MKWh									
03.	Maximum Shortage	: -2725 MW (Generation end)		06. Probable Max. Temperature in Dhaka : 35.4° C									

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation