

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 27-May-21

Page -2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present | Peak | Energy | Remarks |
|-------------------------------|---------------------------------|------------------|---------------------|-------------|-------------|-----------------|------------------------------|
| | | | | Capacity | Hour | Generated | |
| | | | Unit No. X Capacity | MW | MW | KWH | |
| 1 | Ghorasal Repowered CCGP-Unit | PDB | 1'260 | 260 | 0 | 0 | Under maint. |
| 2 | Ghorasal Repowered CCGP Unit | PDB | 1'210 | 180 | 0 | 0 | Under maint. |
| 3 | Ghorasal TPP Unit-5 | PDB | 1'210 | 190 | 185 | 4189500 | |
| 4 | Ghorasal 365 MW CCGP Unit-7 | PDB | 1'243+1'122 | 365 | 0 | 0 | Under maint. |
| 5 | Ghorasal 78.5 MW PP(MAX) | QRPP | 2'40 | 0 | 0 | 0 | Contract Expired |
| 6 | Ghorasal 108MW PP (Regen) | IPP | 343.35 | 108 | 104 | 2356454 | |
| 7 | Haripur GTTP | SBU_PDB | 2'32 | 20 | 0 | 0 | Under maint. |
| 8 | Haripur 412 MW CCGP | EGCB | 1'273+1'139 | 412 | 364 | 8200490 | FGMO |
| 9 | Haripur 360MW CCGP(HPL) | IPP | 1'235+1'125 | 360 | 85 | 2560000 | Gas shortage |
| 10 | Meghnaghat 450 MW CCGP(MP) | IPP | 2'150+1'150 | 450 | 300 | 7089500 | Gas shortage |
| 11 | Meghnaghat 100 MW(EL) | QRPP | 12'8.9 | 100 | 0 | 0 | Contract Expired |
| 12 | Meghnaghat CCGP(Summit) | IPP | 2'110+1'110 | 305 | 240 | 5833611 | FGMO |
| 13 | Madanganj 102 PP(Summit) | QRPP | 6'17 | 0 | 0 | 0 | Contract Expired |
| 14 | Madanganj-55 MW PP(Summit) | (IPP) | 3'17.08+1'11.3 | 55 | 30 | 418995 | Low demand |
| 15 | Keraniganj 100 MW PP (Powerpa | QRPP | 8'13.45 | 100 | 0 | 21616 | Reserve. |
| 16 | 210 MW Siddhirganj TPP | PDB | 1'210 | 115 | 0 | 0 | Under maint. |
| 17 | Siddhirganj 2'120 MW GTTP | EGCB | 2'105 | 210 | 186 | 3649000 | FGMO |
| 18 | Siddhirganj 100 PP(Dutch Bangla | QRPP | 12'8.9 | 100 | 100 | 1861517 | |
| 19 | Siddhirganj 335 MW CCGP | EGCB | 1'217+1'118 | 335 | 215 | 4761838 | ST under Maint. |
| 20 | Gagnagar 102 MW PP (Digital Pa | IPP | 12'8.924 | 102 | 40 | 769824 | |
| 21 | Katpott 52 MW PP (Sinha) | IPP | 77.9 | 51 | 0 | 0 | Fuel shortage |
| 22 | Kamatnagar 54 MW PP(Banco E | IPP | 3'19 | 54 | 35 | 792000 | Engine problem |
| 23 | Kodda 150MW PP | BFDB-RPCL | 9'17.06 | 149 | 100 | 1533880 | Low demand |
| 24 | Manikganj 55 MW PP (Northern) | IPP | 3'19.3 | 55 | 0 | 38674 | Reserve. |
| 25 | Nabaganj 55 MW PP (Southern) | IPP | 3'19.3 | 55 | 35 | 311144 | Engine problem |
| 26 | Bosila 108MW PP(CLG) | IPP | 12'8.775+1'3.5 | 108 | 0 | 0 | Fuel shortage |
| 27 | Summit Power, (Madhabdi+Ashul | SIPP,REB | 3'3.67+4'8.73 | 80 | 45 | 925200 | Engine problem |
| 28 | Machna 33 MW PP(Summit) | SIPP,REB | 4'8.73 | 33 | 33 | 813700 | |
| 29 | Ruganjan 33 MW PP(Summit) | SIPP,REB | 4'8.73 | 33 | 33 | 785500 | |
| 30 | Gazipur 52 MW PP | IPP | 6'8.9 | 52 | 42 | 874080 | Engine problem |
| 31 | Tongi 80 MW GTTP | PDB | 1'105 | 105 | 0 | 0 | Under maint. |
| 32 | Kodda 300 MW PP Unit-2 (Sumr | IPP | 18'17.076 | 300 | 195 | 1844181 | Low demand |
| 33 | Keraniganj 300 MW PP (AFR) | IPP | 25'11.4 | 300 | 0 | 0 | Reserve. |
| 34 | Bramhangaganj 100 MW PP (Agg | IPP | 100 | 100 | 0 | 0 | Reserve. |
| 35 | Aurahati 100MW PP (Aggreko) | IPP | 0.85'23+0.95'91 | 100 | 0 | 0 | Reserve. |
| 36 | Kodda 149 MW PP Unit-1 (Sumr | IPP | 149 | 100 | 100 | 1442304 | Low demand |
| 37 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 84 | 1998600 | Engine problem |
| 38 | Meghnaghat 104 MW PP (OPCL | IPP | 18'5.15 | 104 | 20 | 478080 | Low demand |
| 39 | Manikganj 162MW PP(MPCL) | IPP | 9'18 | 162 | 144 | 1857600 | Engine problem |
| 40 | Spectra Solar Plant Ltd. | IPP | 35 | 35 | 0 | 102810 | |
| Dhaka area Total | | | | 5919 | 2734 | 55874786 | |
| 41 | Chattoagram TPP-1 | PDB | 1'210 | 180 | 80 | 700000 | Under maint. |
| 42 | Chattoagram TPP-2 | PDB | 1'210 | 180 | 0 | 0 | Gas shortage |
| 43 | Raizan 25 MW PP | IPP | 3'8.9 | 25 | 17 | 372551 | Engine problem |
| 44 | Tektari 20MW PP (SolarTech)Khat | SolarTech Energy | 20 | 20 | 0 | 124605 | |
| 45 | Patenga 50MW PP (Baraka) | IPP | 8'6.98 | 50 | 45 | 909600 | Engine problem |
| 46 | Kaptai Hydro: Unit-1,2,3,4, 5 | PDB | 2'40+3'50 | 230 | 25 | 600000 | Low water level & Unit-2 unc |
| 47 | Sikalbaha 225MW | PDB | 1'150+1'175 | 225 | 228 | 4873345 | FGMO |
| 48 | Sikalbaha Peaking GT | PDB | 1'150 | 150 | 120 | 2975249 | |
| 49 | Sikalbaha 105 MW PP (Baraka S | IPP | 105 MW | 105 | 53 | 1305545 | Engine problem |
| 50 | Hathazari 100 MW peaking PP | PDB | 1'118.9 | 98 | 0 | 0 | Under S/D |
| 51 | Dohazari -Kalaish 100 MW Peak | PDB | 6'17 | 102 | 68 | 833949 | Engine problem |
| 52 | Juidah 100 MW Unit-1 (Acorn) | QRPP | 8'13.45 | 100 | 80 | 1791840 | Engine problem |
| 53 | Juidah 100 MW PP Unit-3 (Acorn | IPP | 0 | 100 | 70 | 977280 | Low demand |
| 54 | Barakunda 22 MW PP (Regent | SIPP, PDB | 0 | 22 | 22 | 444048 | |
| 55 | Matarha, Ctg. ETC | IPP | 5'8.72+3'9.34 | 0 | 28 | 468920 | |
| 56 | Chattoagram 108 MW PP (ECPV) | IPP | 6'7 | 108 | 6 | 151680 | Low demand |
| 57 | Kaptai 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 35521 | |
| 58 | Anwara 300 MW PP (Uniled) | IPP | 300 MW | 300 | 0 | 0 | Reserve. |
| 59 | Jodiak Power | IPP | 3'18.55+1'3.6 | 54 | 54 | 1299301 | |
| 60 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 108 | 1932627 | |
| 61 | Juidah unit-2 (Acorn) | IPP | 8'13.6 | 100 | 50 | 546240 | Low demand |
| 62 | Anlima Energy Ltd. | IPP | 6'21.2 | 116 | 17 | 283527 | Low demand |
| Chattoagram area Total | | | | 2382 | 1069 | 20648888 | |
| 63 | Ashuganj TPP Unit- 3 | APSCL | 1'150 | 135 | 0 | 0 | Gas Shortage |
| 64 | Ashuganj TPP Unit- 4 | APSCL | 1'150 | 129 | 80 | 2028475 | Gas shortage |
| 65 | Ashuganj TPP Unit- 5 | APSCL | 1'150 | 134 | 0 | 0 | Gas shortage |
| 66 | Ashuganj 225 MW CCGP | APSCL | 1'142+1'175 | 221 | 163 | 4831000 | FGMO |
| 67 | Ashuganj 450 MW CCGP(North) | APSCL | 1'360 | 360 | 330 | 6969700 | FGMO |
| 68 | Ashuganj 450 MW CCGP(South) | APSCL | 1'360 | 360 | 335 | 6712000 | FGMO |
| 69 | Ashuganj 50 MW PP | APSCL | 14'3.968 | 45 | 19 | 528696 | Engine problem |
| 70 | Ashuganj 55 MW PP (Precision) | RPP | 154 | 55 | 25 | 447360 | Gas shortage |
| 71 | Ashuganj 190MW PP (APSCL-U) | IPP | 20'37+1'116 | 195 | 8 | 217454 | Gas shortage |
| 72 | Ashuganj 51 MW PP (Midland) | IPP | 6'9.34 | 51 | 51 | 1215174 | |
| 73 | Ashuganj 150MW PP (Midland) | IPP | 23'7.015 | 150 | 100 | 1681090 | Low demand |
| 74 | Titas 50 MW Peaking PP | PDB | 6'8.92 | 52 | 42 | 221624 | Low demand |
| 75 | Chandpur 150 MW CCGP | PDB | 1'106+1'57 | 163 | 90 | 1504720 | Machine problem |
| 76 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 85 | 1454400 | Engine problem |
| 77 | Feni 22MW PP (Doreen) | SIPP, PDB | 8'2.90 | 22 | 21 | 488952 | |
| 78 | Feni 11 MW PP (Doreen) | SIPP, REB | 4'2.90 | 11 | 11 | 182700 | |
| 79 | Impoprt (Tripura) | Imported power | 0 | 160 | 152 | 2888640 | |
| 80 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4'8.73 | 33 | 33 | 799600 | |
| 81 | Jangalia 52 MW PP (Lakdanavi) | IPP | 6'8.92 | 52 | 46 | 1231406 | Engine problem |
| 82 | Cumilla 25 MW PP (Summit) | SIPP, PDB | 3'3.67+2'6.97 | 25 | 21 | 420990 | |
| 83 | Caudkandi 200 MW PP (B.Trac) | IPP | 15'41.4 | 200 | 0 | 0 | Reserve. |
| 84 | Feni Lanka Power | IPP | 7'18.415+1'9.78 | 114 | 100 | 1920900 | |
| 85 | Chowmuhani 113 MW | IPP | 12'9.78+2'3.1 | 113 | 119 | 2420040 | |
| 86 | Bhairab 54.5 MW | IPP | 3'18.2 | 54 | 35 | 880920 | 33 kV feeder fault. |
| Cumilla Area Total | | | | 3034 | 1866 | 39045841 | |
| 87 | RPCL 210MW CCGP | IPP | 4'35+1'170 | 202 | 125 | 3263200 | Gas shortage |
| 88 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8'2.90 | 22 | 18 | 332100 | Engine problem |
| 89 | Jamalpur 95 MW PP(Powerpac) | IPP | 12'8.924 | 95 | 24 | 566400 | Engine problem |
| 90 | Sarisbari 3 MW Solar Plant | IPP | 1'3 | 3 | 0 | 7050 | |
| 91 | Mymensingh 200 MW PP (Unite | IPP | 200 | 105 | 105 | 1790400 | Engine problem |
| 92 | Jamalpur 115 MW PP (Uniled) | IPP | 115 MW | 115 | 115 | 2607600 | |
| 93 | Sutakhal 50 MW Solar PP | IPP | 50 | 50 | 0 | 145880 | |
| 94 | Tangail Palli Power Gen 22 MW | IPP | 4'6.7 | 22 | 24 | 489600 | |
| Mymensingh Area Total | | | | 709 | 411 | 9147350 | |
| 95 | Fenchuganj CCGP Phase-1 | PDB | 2'32+1'33 | 70 | 42 | 1006000 | Machine problem |
| 96 | Fenchuganj CCGP Phase-2 | PDB | 2'35+1'35 | 90 | 42 | 1004400 | Machine problem |
| 97 | Kushkhara 163 MW CCGP (KP) | IPP | 1'109+1'54 | 163 | 163 | 3505827 | |
| 98 | Shahjibazar 330 MW CCGP | PDB | 3'110 | 330 | 162 | 3582020 | ST under S/D. |
| 99 | Fenchuganj 51 MW PP (Barakat | RPP | 19'2.90 | 51 | 53 | 1153200 | |
| 100 | Fenchuganj 44MW (Energyprim | RPP | 12'3.3+5'2 | 0 | 0 | 0 | Contract Expired |
| 101 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4'2.90 | 11 | 11 | 264000 | |
| 102 | Shahjibazar GTTP Unit- 8 & 9 | PDB | 2'35 | 66 | 57 | 1334976 | Engine problem |
| 103 | Shahjibazar 80MW PP (Shahjiba | RPP | 3'2+2.90 | 86 | 78 | 1746240 | Engine problem |
| 104 | Shahjibazar 100 MW GTTP | PDB | 1'100 | 100 | 0 | 0 | Under Shut down |
| 105 | Sylhet 225 MW CCGP | PDB | 1'142+1'189 | 231 | 136 | 2506020 | Machine problem |
| 106 | Sylhet 20 MW GTTP | PDB | 1'20 | 20 | 17 | 395000 | |
| 107 | Sylhet 50MW PP (EPL) | RPP | 2'72 | 0 | 0 | 0 | Contract Expired |
| 108 | Shahjahanulla 25 MW PP | SIPP, REB | 3'9.34 | 25 | 16 | 380288 | Engine problem |
| 109 | Bibiana-II 341 MW CCGP (Summ | IPP | 1'122+1'119 | 341 | 315 | 7165500 | FGMO |
| 110 | Bibiyana-III 400 MW CCGP | PDB | 400 MW | 400 | 413 | 6986000 | FGMO |
| 111 | Sylhet 10MW PP (Desh) | RPP | 6'1.95 | 10 | 7 | 157860 | Engine problem |
| 112 | Bibiyana South 400 MW | PDB | 400 MW | 383 | 391 | 9403100 | FGMO |
| Sylhet Area Total | | | | 2377 | 1903 | 42590411 | |
| 113 | Bheramara GTTP Unit-3 | PDB | 1'20 | 16 | 0 | 0 | |
| 114 | Bheramara (NWPC) | Imported power | 2'500 | 1000 | 888 | 1925063 | |
| 115 | Khulna 115 PP MW (KPCL-2) | QRPP | 7'17 | 115 | 105 | 1638600 | |
| 116 | Fariapur 50 MW Peaking PP | PDB | 8'6.89 | 54 | 0 | 28320 | Reserve. |
| 117 | Khulna 225 MW CCGP | NWPGCL | 1'150+1'175 | 230 | 0 | 0 | Reserve. |
| 118 | Gopalganj 100 MW Peaking PP | PDB | 16'6.98 | 109 | 0 | 7552 | Reserve. |
| 119 | Bheramara 410 MW CCGP | NWPGCL | 1'278+1'132 | 410 | 305 | 8400224 | Gas shortage |
| 120 | Noapara 40 MW CCGP | QRPP | 5'11.8 | 40 | 32 | 147520 | Engine problem |
| 121 | Noapara 100 MW PP (Bangla Tr | IPP | 70'1.4 | 100 | 4 | 227520 | Low demand |
| 122 | Rupsha 105 MW PP (Orion rupsa | IPP | 6'18.445 | 105 | 92 | 475680 | Low demand |
| 123 | Madhumati 100 MW PP | NWPGCL | 100 MW | 105 | 0 | 0 | Reserve. |
| Khulna Area Total | | | | 2284 | 1436 | 28128209 | |
| 124 | Bansail 110 MW PP (Summit) | IPP | 7'17.076 | 110 | 64 | 483072 | Engine problem |
| 125 | Bhola 33 MW PP (Venture) | RPP | 1'34.50 | 33 | 34 | 542757 | Engine problem |
| 126 | Bhola 225 MW CCGP | PDB | 2'63+1'68 | 194 | 85 | 2110525 | Engine problem |
| 127 | Bhola 95 MW PP (Aggreko) | QRPP | 96'1.10 | 95 | 95 | 1705287 | |
| 128 | Payra 1320 MW | BCPCL | 2'622 | 1244 | 570 | 11757700 | |
| 129 | Bhola Nutan Biddut BD LTD | IPP | 220 | 0 | 0 | 0 | On Test |
| 130 | United Payra Power Ltd. | IPP | 6'18.5+1'9.5 | 150 | 0 | 12600 | Low demand |
| Bansail Area Total | | | | 1826 | 851 | 16722941 | |
| 131 | Baghabari 71 MW GTTP | PDB | 1'71 | 71 | 0 | 0 | Gas shortage |
| 132 | Baghabari 100 MW GTTP | PDB | 1'100 | 100 | 0 | 0 | Gas shortage. |
| 133 | Baghabari 50 MW Peaking PP | PDB | 6'8.9 | 52 | 0 | 581184 | Reserve. |