

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2021		Day : Monday				Date : 31.05.21					
Probable Maximum Demand :		13200 MW		Yesterday = 72.79 ft		Today = 72.69 ft		Probable Maximum Generation : 14397 MW		Rule Curve = 76.20 ft.	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.05.21 (Yesterday)		31.05.21 (Today)		30.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	91	99	104	104		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	92	118	110	120	242	Gas Shortage
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Dirty in Gas
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	120	185	120	185	25	Gas Shortage
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	209	214	220	220	121	ST under maint.
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	24	100	100	100		
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	145	260	260	260		
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
16	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	79	80	100	100		
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102		
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	20	20		
20	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	46	45	45	45		
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	41	42	42		
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	84	83	85	85		
25	Kodda 150MW PP	HFO (BPPDB-RPCL)	9x17.06	149	149	150	150	150	150		
26	Katpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
27	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35		
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	228	245	245	245		
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	21	108	100	300		
31	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	38	100	100	100		
32	Aurshahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	53	102	50	100		
33	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
34	Maniganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
35	Bosila 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
37	Maniganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	144	144	144	144		
38	Maniganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0		
Dhaka Zone Total			6076	5919	2599	3111	3406	849	1166		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	20	20	20	20	210	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	90	90	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	6	0	5	0		
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
43	Taknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	18	0	20	0		
44	Palenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	45	46	50	50		
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	94	105	105	105		
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	204	204	220	220		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300		
49	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	100	100	100		
50	Juddah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	68	85		
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			7	26	10	25		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	6	6		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	91	110	110		
57	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	60	80	100	100		
58	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	17	17	116	116		
Chattogram Zone Total			2442	2382	882	1057	1523	1530	210	330	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	80	80	80	80	49	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	20	26	26		
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+17x5	221	221	189	211	210	210		
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	290	275	300	300		
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	335	265	300	300		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	25	43	49	49	12	Gas shortage
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	140	132	150	150		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	44	47	0	50		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	90	90	90	90	73	ST under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	92	100	100	100		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11		
73	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	44	47	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86'14+86'155+156'106	200	200	50	200	100	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	84	100	114	114		
78	Chowmahani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	108	120	113	113		
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
**	Impport (Tipura)	India		160	160	156	172	145	181		
Cumilla Zone Total			3094	3034	1922	2074	2009	2196	517	73	
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	116	130	150	150	72	Gas Shortage
81	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	19	19		
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	16	24	24		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
84	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	171	196	200	200		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0		
86	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0		
87	Tangali 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	22	24	22	22		
Myensingh Zone Total			717	709	494	582	530	72	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.05.21 (Yesterday)		31.05.21 (Today)		30.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	42	42	42		28	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	56	56	56				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	160	161	163	163				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	78	80	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	212	210	210				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	7	7				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	341	341				
101	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	365	400	400				
102	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	387	395	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1920	1918	2000	2000	0	76	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	370	365	350	350				
106	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	20	20	20				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	99	115	115				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
111	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	0	0				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	105	90	105				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	832	820	609	685				
Khulna Zone Total					2288	2284	1359	1509	1394	1755	0	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	96	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	34	33	33				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	85	88	88		109	GT-2 & STG Under	
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	89	66	95	95				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	520	570	622	622				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	110				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				10	109	0	0				
Barishal Zone Total					1826	1826	718	977	948	1058	0	109	
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	50	50	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	100	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	48	40	40				
124	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	24	40	42				
125	Chapanawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	45	87	100	100				
126	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	40	40				
127	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	43	43				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		150	Gas Shortage, STG S/D	
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	186	187	190	190				
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	201	189	190	190				
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	390	420	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	21	20	20				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
138	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total					2179	2179	1170	1522	1608	1639	321	0	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150		124	Coal Shortage	
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	15	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	113	113	113	113				
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
144	Maipara, Tatula 6 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total					685	665	268	278	271	283	294	0	
Sub-total: Plants in operation					21729	21315	11332.0	12994	13446	14397	2263	1754	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							10743	12319	12747	13649			
(B) Plants under long term maintenance/ contract expired													
145	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0				
Gross Total					22023	21315	11332	12994	13446	14397	2263	1754	
(C) Actual data of 30.05.21 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 12994.00 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 12319.00 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 13016.00 MW, at = 22:00 hrs	Dhaka	4121	4121	0	Mymensingh	1005	1005	0			
04.	Minimum Generation (Generation end)	: 10128.00 MW, at = 8:00 hrs	Chattogram	1342	1342	0	Sylhet	552	552	0			
05.	Day-peak Generation (Generation end)	: 11332.00 MW, at = 12:00 hrs	Khulna	1564	1564	0	Barishal	412	412	0			
06.	Evening-peak Generation (Generation end)	: 12994.00 MW, at = 21:00 hrs	Rajshahi	1251	1251	0	Rangpur	809	809	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs	Cumilla	1263	1263	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9893.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :		13.	Fuel cost : (a) Gas = 159995092 Taka (c) Coal = 80267050 Taka Total = 1032023852 Taka									
	a) Gas limitation	: 1759 MW											
	b) Low water level in Kaptai lake	: 294 MW											
	c) Plants under shut down/ maintenance	: 1754 MW	14.	Maximum Temperature in Dhaka was : 35.4° C									
10.	Total Energy (Generation + India Import)	: 285.35 MKWh	15.	Export through East-West interconnections : At evening peak-hour : 20 MW, at 21:00 hrs Maximum : -40 MW, at 3:00 hrs Energy : 0.066 MKWh									
	By Gas = 147.687 MKWh	By Oil = 95.336 MKWh											
	By Coal = 17.421 MKWh	By Hydro = 0.484 MKWh											
	By Solar = 0.734 MKWh												
11.	Total Gas Supplied	: 1200.00 MMCFD											
(D) Forecast of 31.05.21 (Today) Monday :													
01.	Maximum Demand	: 13200 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 14397 MW (Generation end)	05.	Total Generation : 289.38 MKWh									
03.	Maximum Shortage	: -1197 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 35.5° C									

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation