

Date : 31-May-21		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Rewerend CAPP Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Rewerend CAPP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	185	4673000	
4	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	95	1943500	
7	Harihar GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Harihar 412 MW CAPP	EGCB	1*273+1*139	412	0	0	Shut down due to gas problem
9	Harihar 360MW CAPP(HPL)	IPP	1*235+1*125	360	0	2478000	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	280	6647050	Gas shortage
11	Meghnaghat 100 MW(LEL)	QRPP	12*8.9	100	0	0	Contract Expired
12	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	230	5745484	FGMO
13	Madangan 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madangan 35 MW PP(Summit)	(PP)	3*11.08+1*11.3	55	55	1137965	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	74	917524	Engine problem
16	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	20	394164	
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	153	3524000	FGMO
19	Siddhirgonj 100 PPI(Dutch Bangla)	QRPP	12*8.9	100	100	1449600	
20	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	221	5109348	ST Under Maint.
21	Gagunagar 102 MW PP (Digital Po)	IPP	12*8.924	102	102	2001456	
22	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	35	861444	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	2944800	
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	927953	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	957994	
27	Bostia 108MW PP(CLO)	IPP	12*9.775+1*9.5	108	0	0	Fuel shortage
28	Summit Power (Madhabadi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	47	945420	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	755500	
30	Ruggan 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	822600	
31	Gazipur 52 MW PP	IPP	6*8.9	52	42	900000	Engine problem
32	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summ)	IPP	18*17.076	300	245	4523889	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.
35	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	100	352646	
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	53	423582	Low demand
37	Kodda 149 MW PP Unit-1 (Summ)	IPP	149	149	149	2476370	
38	Gazipur 100 MW PP	RPCL	100 MW	105	82	1961784	Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	104	2012160	
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	126	2894400	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	102968	
Dhaka area Total				5919	2824	59884601	
42	Chattogram TPP-1	PDB	1*210	180	100	2400000	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
44	Rozani 25 MW PP	IPP	3*8.9	25	17	404674	Engine problem
45	Teknaf 20MW PP (Solartech/Teknaf Solartech Energ	IPP	8*6.88	50	50	732000	Engine problem
46	Patenga 50MW PP (Baraka)	IPP	2*40+3*50	230	20	488000	Low water level & Unit-2 und
47	Kaptai Hydro Unit-1,2,3,4, 5	PDB	1*150+1*175	225	204	4873142	FGMO
48	Sikalbaha 225MW	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha Peaking GT	IPP	105 MW	105	105	2581854	
50	Sikalbaha 105 MW PP (Baraka S)	IPP	118.9	98	0	0	Under S/D
51	Hathazari 100 MW Peaking PP	PDB	6*17	102	85	1280909	Engine problem
52	Dohazari-Kalesh 100 MW Peakin	QRPP	8*13.45	100	100	2147760	
53	Judah 100 MW Unit-1 (Acorn)	IPP	0	100	100	2305920	
54	Judah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2305920	
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	496848	
56	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	29	433440	
57	Chattogram 108 MW PP (ECPV)	IPP	18*5.6	108	0	0	Fuel shortage
58	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	30719	
59	Anwara 300 MW PP (Unite)	IPP	300 MW	300	0	0	transformer O/L
60	Jodac Power	IPP	3*18.55+1*3.6	54	54	1284740	
61	Karnaphuli Power Ltd.	IPP	110	110	93	2269052	Engine problem
62	Judah unit-2 (Acorn)	IPP	8*13.6	100	10	1091520	Line O/L
63	Anilma Energy Ltd.	IPP	6*21.2	116	17	423955	Line O/L
Chattogram area Total				2382	1006	23341743	
64	Ashuganj TPP Unit-3	APSCl	1*150	135	0	0	Gas Shortage
65	Ashuganj TPP Unit-4	APSCl	1*150	129	80	1939420	Gas shortage
66	Ashuganj TPP Unit-5	APSCl	1*150	134	0	0	Gas shortage
67	Ashuganj 225 MW CAPP	APSCl	1*142+1*75	221	220	4866000	
68	Ashuganj 450 MW CAPP(North)	APSCl	1*360	360	260	6960300	FGMO
69	Ashuganj 450 MW CAPP(South)	APSCl	1*360	360	270	6738000	FGMO
70	Ashuganj 50 MW PP	APSCl	14*3.988	45	20	437400	Engine problem
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	975390	Gas shortage
72	Ashuganj 195MW PP (APSCl-UR)	IPP	20*9.73+1*16	195	8	217454	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1213859	
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	140	2060800	Engine problem
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	50	423600	
76	Chandpur 150 MW CAPP	IPP	1*106+1*57	163	85	2087110	
77	Chandpur 200MW (Desh energy)	IPP	0	200	104	2416800	Machine problem
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	451908	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	5	154980	
80	Import (Tripura)	Imported power	0	160	136	3264000	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	790700	
82	Jangalia 52 MW PP (Kadkanaw)	IPP	6*8.92	52	43	1040237	Engine problem
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	12	369440	Low demand
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	50	513024	Low demand
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	100	2168280	Engine problem
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	120	2774520	
87	Bhairab 54.5 MW	IPP	3*18.2	54	17	667080	33 kV feeder fault.
Cumilla Area Total				3034	1630	42330272	
88	RPCL 210MW CAPP	IPP	4*35+1*70	202	120	3184420	
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	398772	Gas shortage
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	16	376320	Engine problem
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	6000	
92	Mymensingh 200 MW PP (Unite)	IPP	200	200	196	2589600	Engine problem
93	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	107	2242800	
94	Sylhet 50 MW Solar PP	IPP	50	50	0	140670	
95	Tangail Fali Power 22 MW	IPP	4*6.7	22	24	620400	
Mymensingh Area Total				709	483	9531002	
96	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	42	1009000	Machine problem
97	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	42	1004820	Machine problem
98	Kushihara 163 MW CAPP (KP)	IPP	1*109+1*54	163	163	3620618	
99	Shahjibazar 330 MW CAPP	PDB	3*110	330	162	3510000	GT-1 under maint
100	Fenchugonj 51 MW PP (Barakati)	IPP	19*2.90	51	53	1262900	
101	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	0	201000	
103	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	62	1405824	Engine problem
104	Shahjibazar 86MW PP (Shahjibaz)	RPP	32*2.90	86	80	1905600	
105	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	Under Shut down
106	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	164	4381630	
107	Sylhet 20 MW GTPP	PDB	1*20	20	18	403000	Engine problem
108	Sylhet 50MW PP (LEPL)	RPP	2*22	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	337872	Engine problem
110	Bibiana-II 341 MW CAPP (Summ)	IPP	1*222+1*119	341	295	7293000	FGMO
111	Bibiana-III 400 MW CAPP	PDB	400 MW	400	366	8971000	FGMO
112	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	7	162720	Engine problem
113	Bibiana South 400 MW	PDB	400 MW	383	400	93745400	FGMO
Sylhet Area Total				2377	1870	44844584	
114	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	
115	Bheramara (HVDC)	Imported power	2*500	1000	606	17143273	
116	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	99	1772160	Engine problem
117	Fairpur 50 MW Peaking PP	PDB	6*8.89	54	0	44160	Engine problem
118	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	225	0	0	Reserve.
119	Gopiganj 100 MW Peaking PP	PDB	16*8.98	109	0	0	Reserve.
120	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	355	8921088	FGMO
121	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Tre)	IPP	70*1.4	100	70	483840	
123	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	105	1064160	
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1235	29428681	
125	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	98	1119936	Engine problem
126	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	32	584731	
127	Bhola 225 MW CAPP	PDB	2*63+1*68	194	86	2074109	Machine problem
128	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	96	1763649	Machine problem
129	Payra 1320 MW	BCPCL	2*622	1244	510	12473600	
130	Bhola Nutan Biddu BD LTD	IPP	220	0	0	0	On Test
131	United Payra Power Ltd.	IPP	8*18.8+1*9.5	150	17	410400	Low demand
Barisal Area Total				1826	837	18426425	
132	Baghbari 71 MW GTPP	PDB	1*71	71	65	435000	
133	Baghbari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage.
134	Bera 70 MW Peaking PP	PDB	6*8.9	52	50	968208	
135	Amnara 50 MW PP(Sinha)	QRPP	7*7.79	50	35	320200	Engine problem
136	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	34	247968	Raj. 132 kV Bus O/L
137	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	38	388500	Engine problem
138	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
139	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	186	4475118	FGMO
140	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	187	4666836	FGMO
141	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1*282+1*132	414	420	9214028	FGMO
142	Santihar 50 MW Peaking PP	PDB	6*8.9	50	35	338732	Engine problem
143	Bogra 22 MW PP (GBB)	RPP	6*4	22	21	487920	
144	Bogura 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired
145	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	207540	
146	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	1068480	
147	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	88	1672536	Engine problem
148	Baghbari 200 MW PP (Paramou)	IPP	200 MW	200	0	0	Reserve.
149	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	1442400	
150	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	1267296	
151	Sirajgonj 6.55 MW Solar	NWPGCL	1*6	6	0	12540	
Rajshahi Area Total </							