

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 956467, 9551095

Month June, 2021		Day: Sunday		Date: 06.06.21							
Probable Maximum Demand: 13500 MW		Yesterday = 7243 ft		Today = 7246 ft							
Water Level of Kaptai Lake at 06:00 AM		Probable Maximum Generation: 15748 MW		Rule Curve = 77.33 ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.06.21 (Yesterday)		06.06.21 (Today)		05.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		
					Day	Evening	Day	Evening	Gas/Water/Cool limitation (MW)	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	102	104	104		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	227	204	280	350	156	Gas Shortage
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	308	292	310	310	120	Dirty in Gas
11	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	250	335	300	335		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	90	100	100	100		
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	220	220	280	300		
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
16	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	20	55	55	55		
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	58	102	102		
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	20	20		
20	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	45	55	55	55		
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	33	42	42	42		
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	60	85	85	85		
25	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	64	150	150	150		
26	Katpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
27	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	50	50		
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	60	245	245		
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	20	117	149	149		
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
31	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Aurshahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
33	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
34	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	17	55	55		
35	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	104	104		
37	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	10	17	144	144		
38	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	27	0	30	0		
Dhaka Zone Total			6076	5919	2111	2563	3596	3941	656	1045	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	20	20	20	20	210	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0		
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
43	Taknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	11	0	20	0		
44	Palenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50		
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	120	120	125		
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	223	197	220	220		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300		
49	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	100	100	100		
50	Juddah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	50	20	100	100		
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85		
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	21	32	40		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	93	34	110	110		
57	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	10	10	100	100		
58	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	10	17	116	116		
Chattogram Zone Total			2442	2382	913	972	1676	1664	210	180	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	100	100	125	125	29	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	26	26	26		
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1175	221	221	202	182	220	220		
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	310	295	300	360		
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x360	360	360	295	260	360	360		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	52	55	55	55		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	42	142	150	150		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	90	90	90	90	73	ST under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	83	158	160	160		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	6	19	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11		
73	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	5	21	20	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+86x1.55+15x1.058	200	200	0	0	100	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	100	114	100	100		
78	Chowmahani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	115	119	113	113		
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	22	35	35	35		
**	Impoort (Tirupura)	India		160	160	92	124	152	181		
Cumilla Zone Total			3094	3034	1672	1933	2174	2414	485	73	
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	154	152	159	159	50	Gas Shortage
81	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	20	20		
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	16	16	16		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	66	115	115	115		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	72	200	200		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	26	0	50	0		
87	Tangal 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	22	24	22	22		
Mymensingh Zone Total			717	709	305	398	584	532	50	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.06.21 (Yesterday)		06.06.21 (Today)		05.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	42	44	44		28	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	53	51	51				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	63	63	63				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	110	110	110				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	83	83	83				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	165	225	200	210				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	7	7	7				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	5	8	16	16				
100	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	341	341				
101	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	398	365	400	400				
102	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	401	380	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1665	1840	1949	1959	0	76	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	310	325	400	400	85		Gas Shortage	
106	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	20	20	20				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	70	50	100				
111	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	0	0				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	75	105	105	105				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	905	907	934	934				
Khulna Zone Total					2288	2284	1294	1427	1669	1939	85	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	32	33	33				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	67	50	88	88		144	GT-2 & STG Under	
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	21	23	30	30				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	420	400	622	622				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				156	225	228	233				
Barishal Zone Total					1826	1826	680	730	1111	1226	0	144	
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	50	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	45	45				
124	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42				
125	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	88	90	90				
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40				
127	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0	35				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	112	70	144	144	80		Gas Shortage, STG S/D	
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	159	138	195	195	82		Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	197	167	197	197				
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	391	385	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	20	20				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	52	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	35	50	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	31	70	113	113				
138	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total					2179	2179	1020	1136	1761	1790	333	0	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	70	113	113	113				
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
144	Maipara, Tatula 6 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total					685	665	227	263	271	283	294	0	
Sub-total: Plants in operation					21729	21315	9887.0	11262	14791	15748	2113	1518	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss					9688	11035	14492	15431					
(B) Plants under long term maintenance/ contract expired													
145	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0				
Gross Total					22023	21315	9887	11262	14791	15748	2113	1518	
(C) Actual data of 05.06.21 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	11262.00 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	11035.00 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	11821.00 MW, at = 1:00 hrs		Dhaka	3988	3988	0	Mymensingh	922	922	0	
04.	Minimum Generation (Generation end)	:	8346.00 MW, at = 9:00 hrs		Chattogram	1207	1207	0	Sylhet	424	424	0	
05.	Day-peak Generation (Generation end)	:	9887.00 MW, at = 12:00 hrs		Khulna	1305	1305	0	Barishal	336	336	0	
06.	Evening-peak Generation (Generation end)	:	11262.00 MW, at = 21:00 hrs		Rajshahi	1185	1185	0	Rangpur	654	654	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 21:00 hrs		Cumilla	1014	1014	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8658.00 MW, at = 5:00 hrs						Total	11035	11035	0	
09.	Generation shortfall at evening peak due to :	:		13.	Fuel cost :		(a) Gas = 159411165 Taka	(c) Coal = 69086212 Taka					
	a) Gas limitation	:	1609 MW				(b) Oil = 422145444 Taka	Total = 650642821 Taka					
	b) Coal supply Limitation	:	294 MW	14.	Maximum Temperature in Dhaka was : 34° C								
	c) Low water level in Kaptai lake	:	210 MW	15.	Export through East-West interconnections :								
	c) Plants under shut down/ maintenance	:	1518 MW		At evening peak-hour		: 56 MW, at 21:00 hrs						
10.	Total Energy (Generation + India Import)	:	246.76 MKWh		Maximum		: -153 MW, at 15:00 hrs						
	By Gas = 152.882 MKWh		By Oil = 53.487 MKWh		Energy		: 0.4245 MKWh						
	By Coal = 14.881 MKWh		By Hydro = 0.496 MKWh										
	By Solar = 0.418 MKWh												
11.	Total Gas Supplied	:	1214.92 MMCFD										
(D) Forecast of 06.06.21 (Today) Sunday :													
01.	Maximum Demand	:	13500 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	:	15748 MW (Generation end)	05.	Total Generation : 281.81 MKWh								
03.	Maximum Shortage	:	-2248 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 41.4° C								

* Captive Power ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazool Islam Shaker)
Deputy Secretary, Generation