

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel.: 9564667, 9551095

Month June, 2021		Day : Sunday				Date : 13.06.21					
Probable Maximum Demand :		13500 MW		Probable Maximum Generation :		15227 MW					
Water Level of Kaptai Lake at 06:00 AM											
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Yesterday = 73.97 ft.		Today = 74.48 ft.		Rule Curve = 79.19 ft.		Status of Machines under shut-down/ Maintenance	
				Derated/ Present Capacity (MW)	12.06.21 (Yesterday)		13.06.21 (Today)		Gen. shortfall for : Gas/water/Coal limitation MW		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1x 210	210	190	185	185	185	185		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	96	101	104	104		
5	Tongi 80 MW GTPP	Gas (PDB)	1x 105	105	105	0	0	0	0	105	CB Problem
6	Haripur GTPP	Gas (PDB)	1x 32	32	20	0	0	0	0	20	Under Maint.
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x225+1x125	360	360	172	127	150	150	233	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Under maint.
11	Siddhirgonj 210 MW GTPP	Gas (EGCB)	2 x 105	210	210	182	90	150	180	120	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1x 217+1x118	335	335	328	332	335	335		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	50	96	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	290	260	260	260		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	55	55		
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	62	85	85		
17	Ganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	102	102	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	20	21	21	21		
19	Summit Power, (Madhadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	55	54	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Ruganaj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	42	42	42		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	85	85		
24	Kodda 150MW PP	HFO (BDOB-RPCL)	9x17.06	149	149	150	150	150	150		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	225	250	250		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	107	129	133	133		
29	Keranganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	100	100	300		
30	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	50	100	100		
31	Aurabai 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	100	50	100		
32	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
33	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	20	104	104	104		
36	Manikgonj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	108	126	162	162		
37	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	20	0	30	0		
<b>Dhaka Zone Total</b>				<b>5976</b>	<b>5819</b>	<b>2548</b>	<b>3159</b>	<b>3338</b>	<b>3588</b>	<b>503</b>	<b>1457</b>
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low Water Level
	a) Chattogram TPP-1	Gas (PDB)	1x 210	210	180	95	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	6	0	5	0		
41	Raczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	8	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1x 150	150	150	100	100	100	100		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1x 150+1x 75	225	225	212	203	220	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	300	300		
48	Judhad 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	100	100	100		
49	Judhad 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	22	22		
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	28	20	35		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	6	6		
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110		
56	Judhad unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	30	100	100	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	0	116	116		
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>938</b>	<b>1177</b>	<b>1655</b>	<b>1645</b>	<b>205</b>	<b>180</b>
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1x 150	150	135	80	80	80	80	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	205	206	220	220		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	290	270	300	300		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	295	260	260	320		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	10	10	55	55		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+11'6	195	195	8	8	26	26	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	135	147	143	143		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	133	133	135	140		
69	Chandpur 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	180	180	185	185		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	41	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	21		
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x13.5+1x18.88	200	200	0	80	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	100	100	100		
77	Chowmahani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	119	117	113	113		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35		
**	Impopt (Tijura)	India		160	160	92	152	151	179		
<b>Cumilla Zone Total</b>				<b>3094</b>	<b>3034</b>	<b>1754</b>	<b>2029</b>	<b>2109</b>	<b>2353</b>	<b>505</b>	<b>0</b>
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	126	118	180	180	84	Gas Shortage
80	Tangai 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	0	20	20		
81	Jamalpur 55 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	156	200	200		
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0		
85	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	30	0	50	0		
86	Tangai 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	18	5	22	22		
<b>Mymensingh Zone Total</b>				<b>717</b>	<b>709</b>	<b>327</b>	<b>402</b>	<b>597</b>	<b>545</b>	<b>84</b>	<b>0</b>

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.06.21 (Yesterday)		13.06.21 (Today)		12.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	42	42			70	Under maint.
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42			48	Under maint.
89	Fenchugonj 51 MW PP (Barakattulah)	Gas (RPP)	1x2.90	51	51	47	47	51	51				
90	Kushiana 163 MW CCPP (KPP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	5	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	56	62	62				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	161	164	162	162				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	78	81	80	83				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	219	220	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	15	15				
99	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	341	341				
100	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	404	400	400				
101	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	398	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
<b>Sylhet Zone Total</b>				<b>2422</b>	<b>2377</b>	<b>1907</b>	<b>1919</b>	<b>2017</b>	<b>2025</b>	<b>0</b>	<b>118</b>		
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	305	295	350	400	115			Gas Shortage
105	Fandpur 50 MW Peaking PP	HFO (PDB)	6x8.98	54	54	0	2	20	20				
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWP/CGCL)	1 x 159+1x75	230	230	0	80	0	220				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.44+7x1.515	100	100	0	100	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	91	105	105				
110	Machumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	0	100	100				
<b>** Bheramara (HVDC) India</b>				<b>1000</b>	<b>1000</b>	<b>426</b>	<b>899</b>	<b>916</b>	<b>916</b>				
<b>Khulna Zone Total</b>				<b>2133</b>	<b>2129</b>	<b>731</b>	<b>1467</b>	<b>1601</b>	<b>1921</b>	<b>115</b>	<b>0</b>		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	33	33	33				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	84	85	85			110	GT-2 & STG Under
114	Bhola 95 MW PP (Aggregate)	Gas (QRPP)	1.1x96	95	95	12	12	22	22				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	530	622	622				
116	Potokhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
<b>Bhola Nutan Biddut BD LTD</b>						<b>167</b>	<b>221</b>	<b>220</b>	<b>220</b>				
<b>Barishal Zone Total</b>				<b>1826</b>	<b>1826</b>	<b>630</b>	<b>896</b>	<b>1092</b>	<b>1202</b>	<b>0</b>	<b>110</b>		
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	71				Gas Shortage
117	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100			Gas Shortage
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	51	51				
121	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	12	35	35	35				
122	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	88	50	100				
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	40	40				
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	0	0	0	150				Gas Shortage, STG S/D
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/CGCL)	1x150+1x75	220	220	184	187	200	200				
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	194	190	200	200				
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	397	400	400				
130	Bogra 22 MW PP (CBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	8	0	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6*18.55	113	113	50	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	3	0	6	0				
<b>Rajshahi Zone Total</b>				<b>2179</b>	<b>2179</b>	<b>1034</b>	<b>1356</b>	<b>1586</b>	<b>1665</b>	<b>321</b>	<b>0</b>		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85				Coal Shortage
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85				Coal Shortage
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124			Coal Shortage
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	45	113	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Maipara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
<b>Rangpur Zone Total</b>				<b>685</b>	<b>605</b>	<b>199</b>	<b>263</b>	<b>271</b>	<b>283</b>	<b>294</b>	<b>0</b>		
<b>Sub-total: Plants in operation</b>				<b>21474</b>	<b>21060</b>	<b>10068.0</b>	<b>12668</b>	<b>14266</b>	<b>15227</b>	<b>2027</b>	<b>1865</b>		
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>													
<b>(B) Plants under long term maintenance/ contract expired</b>													
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Fenchugonj 44MW (Energypirima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020
146	Bogra 20 MW PP (Energypirima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
147	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>				<b>549</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>				
<b>Gross Total</b>				<b>22023</b>	<b>21060</b>	<b>10068</b>	<b>12668</b>	<b>14266</b>	<b>15227</b>	<b>2027</b>	<b>1865</b>		
<b>(C) Actual data of 12.06.21 (Yesterday) Saturday :</b>													
01.	Max. Demand at eve. peak (Generation end)	:	12668.00 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12044.00 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	12668.00 MW, at =	21:00 hrs	Dhaka	4337	4337	0	Mymensingh	915	915	0	
04.	Minimum Generation (Generation end)	:	8472.00 MW, at =	7:00 hrs	Chattogram	1239	1239	0	Sylhet	526	526	0	
05.	Day-peak Generation (Generation end)	:	10068.00 MW, at =	12:00 hrs	Khulna	1504	1504	0	Barishal	349	349	0	
06.	Evening-peak Generation (Generation end)	:	12668.00 MW, at =	21:00 hrs	Rajshahi	1194	1194	0	Rangpur	800	800	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at =	21:00 hrs	Cumilla	1180	1180	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9302.00 MW, at =	5:00 hrs					<b>Total</b>	<b>12044</b>	<b>12044</b>	<b>0</b>	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 163174054 Taka	(c) Coal = 67097920 Taka	(b) Oil = 481791751 Taka	Total = 712063725 Taka			
a) Gas limitation	:		1528 MW										
b) Low water level in Kaptai lake	:		205 MW										
c) Plants under shut down/ maintenance	:		1865 MW										
10.	Total Energy (Generation + India Import)	:	253.19 MKWh		14.	Maximum Temperature in Dhaka was :	33.8° C						
	By Gas = 154.599 MKWh				15.	Export through East-West interconnections :							
	By Coal = 14.419 MKWh					At evening peak-hour	:	-90 MW, at	21:00 hrs				
	By Solar = 0.568 MKWh					Maximum	:	-126 MW, at	11:00 hrs				
11.	Total Gas Supplied	:	1177.54 MMCFD			Energy	:	0.741 MKWh					
<b>(D) Forecast of 13.06.21 (Today) Sunday :</b>													
01.	Maximum Demand	:	13500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15227 MW (Generation end)		05.	Total Generation	:	269.82 MKWh					
03.	Maximum Shortage	:	-1727 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	34.8° C						

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazoul Islam Shaker)  
Deputy Secretary, Generation