

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2021		Day : Saturday				Date : 19.06.21					
Probable Maximum Demand :		12700 MW		Probable Maximum Generation :		15411 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 74.72 ft		Today = 74.63 ft		Rule Curve = 80.76 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.06.21 (Yesterday)		19.06.21 (Today)		18.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	70	97	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	353	300	300	7	Gas Shortage
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	100	300	300	350	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	158	360	360	254	Under maint.
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	135	220	220		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	80	100	100	100		
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	140	280	280		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	18	0	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	74	75		
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	0	100	102		
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	16	16		
19	Summit Power.(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	55	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	20	33	33		
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	51	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	88	90		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	48	133	133		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	45	250	250		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	16	0	132	132		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
30	Bramhangoan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
31	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	48	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	88	0	90	90		
36	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	86	72	126	129		
37	Manikgonj 35MW Solar PP (Inspectra :)	Solar (IPP)	1x35	35	35	34	0	30	0		
Dhaka Zone Total				5976	5819	926	1784	3576	3754	567	1299
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	2	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	46	46		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100		
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	203	204	220	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300		
48	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	50	100	100		
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	50	100	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	100	100		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	22	22		
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			13	40	15	30		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	104	108	110	110		
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	50	100	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	17	116	116		
Chattogram Zone Total				2442	2382	887	1076	1655	1645	205	180
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	80	80	80	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	26	26	26		
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	183	183	220	220		
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	295	265	300	330		
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	310	275	310	330		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	56	55	55		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*11.6	195	195	83	145	180	200	50	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	60	10	120	130		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	85	85	90	90		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	191	180	180		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	12	17	17		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.515+15x1.056	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	100	17	80		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	106	116	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	35	36		
**	Impoprt (Tripura)	India		160	160	80	114	151	180		
Cumilla Zone Total				3094	3034	1635	1851	2154	2477	368	0
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	170	203	150	180	-1	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	85	115	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	84	175	175		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0		
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	14	22	22		
Mymensing Zone Total				717	709	334	445	543	521	-1	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.06.21 (Yesterday)		19.06.21 (Today)		18.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	53	51	51				
90	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	62	62				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	162	160	162	162				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	81	83				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	192	225	192	200				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	15	16				
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	341	341				
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	367	366	400	400				
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	370	400	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total				2422	2377	1791	1900	1948	1959	0	118		
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	270	385	380	390				
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	21				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	91	90	90				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	892	893	918	918				
Khulna Zone Total				2133	2129	1162	1369	1618	1899	0	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	12	26	33	33				
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	86	86	85	86		108	GT-2 & STG Under maint.	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	430	622	622				
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				151	200	220	220				
Barishal Zone Total				1826	1826	510	753	1081	1192	0	108		
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	70	50	50	1		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	40				
121	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	35	35				
122	Chapainawabganj 100 MW Peaking PF	HFO (PDB)	12x8.924	104	104	0	88	90	100				
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40				
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	35				
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	150		Gas Shortage, STG S/D	
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	170	191	200	200				
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	187	190	200	200				
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	334	420	400	400				
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	43	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	35	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	70	90	90				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total				2179	2179	720	1187	1632	1681	251	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	0	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
Rangpur Zone Total				685	605	150	263	271	283	294	0		
Sub-total: Plants in operation				21474	21060	8115.0	10628	14478	15411	1684	1705		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7742	10139	13811	14702				
(B) Plants under long term maintenance/ contract expired													
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
146	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0			Contract Expired on 28/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				549	0	0	0	0	0				
Gross Total				22023	21060	8115	10628	14478	15411	1684	1705		

(C) Actual data of 18.06.21 (Yesterday) Friday :															
01.	Max. Demand at eve. peak (Generation end)	:	10628.00	MW,	at =	21:00 hrs									
02.	Max. Demand at eve. peak (Sub-station end)	:	10139.00	MW,	at =	21:00 hrs									
03.	Highest Generation (Generation end)	:	10703.00	MW,	at =	1:00 hrs									
04.	Minimum Generation (Generation end)	:	7369.00	MW,	at =	9:00 hrs									
05.	Day-peak Generation (Generation end)	:	8115.00	MW,	at =	12:00 hrs									
06.	Evening-peak Generation (Generation end)	:	10628.00	MW,	at =	21:00 hrs									
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs									
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7676.00	MW,	at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:													
	a) Gas limitation	:	1185	MW											
	d) Coal supply Limitation	:	294	MW											
	b) Low water level in Kaptai lake	:	205	MW											
	c) Plants under shut down/ maintenance	:	1705	MW											
10.	Total Energy (Generation + India Import)	:	214.28	MKWh											
	By Gas =	139.012	MKWh	By Oil =	37.762	MKWh									
	By Coal =	12.578	MKWh	By Hydro =	0.608	MKWh									
	By Solar =	0.428	MKWh												
11.	Total Gas Supplied	:	1125.33	MMCFD											
							12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
							Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
								MW	MW	MW		MW	MW	MW	
							Dhaka	3478	3478	0	Mymensingh	880	880	0	
							Chattogram	1124	1124	0	Sylhet	438	438	0	
							Khulna	1208	1208	0	Barishal	292	292	0	
							Rajshahi	1075	1075	0	Rangpur	698	698	0	
							Cumilla	946	946	0					
									Total	10139	10139	0			
							13.	Fuel cost :		(a) Gas =	144954213	Taka	(c) Coal =	59013669	Taka
									(b) Oil =	302882852	Taka	Total =	506850734	Taka	
							14.	Maximum Temperature in Dhaka was : 31° C							
							15.	Export through East-West interconnections :							
							At evening peak-hour		:	94	MW,	at	21:00	hrs	
							Maximum		:	12	MW,	at	19:30	hrs	
							Energy		:	0.1535	MKWh				

(D) Forecast of 19.06.21 (Today) Saturday :												
01.	Maximum Demand	:	12700	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	15411	MW	(Generation end)	05.	Total Generation	:	254.27	MKWh		
03.	Maximum Shortage	:	-2711	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32.4° C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation