

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2021		Day : Tuesday		Date : 22.06.21								
Probable Maximum Demand :			12500 MW	Probable Maximum Generation : 15299 MW								
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.09 ft.	Today = 75.18 ft.	Rule Curve = 81.57 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Rated/ Present Capacity (MW)	21.06.21 (Yesterday)		22.06.21 (Today)		Gen. shortfall for : Gas/water/Coal limitation MW	21.06.21 (Yesterday) Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	0	0	0	0		260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0		180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	30	0		335	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	93	99	100	100			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0		105	CB Problem	
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0		20	Under Maint.	
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	248	252	350	360	108	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115	Under Overhauling	
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	354	338	350	380		74	Under maint.
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0		210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	222	223	0	220			
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	90	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	267	290	290	300			
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55			
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	30	70	100			
17	Ganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	102	100	102			
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	16	19			
19	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+4x7.13	80	80	48	55	55	55			
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	45	51	51	51			
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	80	105	90	105			
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	82	150	133	150			
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54			
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	110	265	290	290			
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	70	115	135	135			
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	100	300			
30	Bramangan 100 MW PP (Aggreko)	HSD (IPP)	23x10.85+9+1x 9.69	100	100	0	0	100	100			
31	Auralah 100MW PP (Aggreko)	HSD (IPP)	23x10.85+9+1x 9.69	100	100	0	0	100	100			
32	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	91	90	104			
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	126	126	162			
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0			
Dhaka Zone Total				5976	5819	2585	3136	3446	4003	468	1089	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	51	46	46	179	Low Water Level	
	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
41	Racozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	4	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	39	40	45			
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	203	203	220	220			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	300	300			
48	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	100	100	100	100			
49	Juddah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	60	100	100	100			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	85	85	85			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
	* Malancha Cig EPZ (United)	Gas	5x8.73+3x3.94			6	26	10	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
56	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	90	100	100			
57	Chattogram 116 MW PP (Anilma Ener)	HFO (IPP)	6x21.06	116	116	17	17	116	116			
Chattogram Zone Total				2442	2382	967	1219	1650	1640	179	180	
58	a) Ashuganj TPP Unit-3	Gas (APSCCL)	1 x 150	150	135	110	80	80	80	55	Gas Shortage	
	b) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	26	26	26			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	195	217	220	220			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	285	270	310	330			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x360	360	360	320	260	310	330			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	35	52	40	55			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	0	0			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	24	24	0	0			
67	Titaa 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	6	50	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	91	86	90	90			
69	Chandpur 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	170	178	160	180			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	25	0	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	17	21			
75	Daukiandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x13.95+1x10.88	200	200	0	0	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	100	34	100			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	121	120	113	113			
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	18	36	35	35			
**	Impoort (Tijpura)	India		160	160	110	120	151	180			
Cumilla Zone Total				3094	3034	1651	1786	1760	2127	505	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	136	156	120	150	46	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
81	Jamalpur 55 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	16	177	175	192			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0			
86	Tangail 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	22	24	22	22			
Mymensingh Zone Total				717	709	361	501	513	508	46	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.06.21 (Yesterday)		22.06.21 (Today)		21.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation (MW)	Machines shut down (MW)		
87	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	15	43	44	44	27		Under maint.	
88	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42	48		Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	1x52	51	51	50	53	51	51				
90	Kushiana 163 MW CCGP (KIP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	62	62				
93	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	162	162	162	164				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	78	78	81	83				
95	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	223	219	192	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	15	16				
99	Bitiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	341	341				
100	Bitiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	354	367	400	400				
101	Bitiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	371	400	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total				2422	2377	1874	1925	1992	2030	0	75		
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	380	365	380	380	45		Gas Shortage	
105	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	0	80	0	160				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	48	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	91	90	90				
110	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
** Bheramara (HVDC) India				1000	1000	894	794	842	909				
Khulna Zone Total				2133	2129	1274	1378	1542	1819	45	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	29	25	25				
113	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	86	85	85	86	109		GT-2 & STG Under	
114	Bhola 95 MW PP (Aggregate)	Gas (QRPP)	1x196	95	95	11	12	12	12				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	220	470	622	622				
116	Potuaiali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
Bhola Nutan Biddut BD LTD						221	222	220	220				
Barishal Zone Total				1826	1826	556	818	1074	1185	0	109		
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	50	71			Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	50	50				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	29	30	40				
121	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	35	35	35				
122	Chapanawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	48	87	90	100				
123	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	40	40				
124	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	35					
126	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	150			Gas Shortage, STG S/D	
127	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	165	184	200	200				
128	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	174	185	200	200				
129	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	389	378	400	400				
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	25	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	10	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	36	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total				2179	2179	878	1330	1655	1704	321	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	18	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Maipara, Tatala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
Rangpur Zone Total				685	605	168	263	271	283	294	0		
Sub-total: Plants in operation				21474	21060	10314.0	12356	13903	15299	1858	1453		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9655	11566	13014	14321				
(B) Plants under long term maintenance/ contract expired													
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
145	Sylhet 50MW PP (EPL)	Gas (RPP)	2x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
146	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
149	Noapara 40 MW PP (Khajashan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0			Contract Expired on 28/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				549	0	0	0	0	0				
Gross Total				22023	21060	10314	12356	13903	15299	1858	1453		
(C) Actual data of 21.06.21 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	12356.00	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11566.00	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12356.00	MW, at =	21:00 hrs	Dhaka	4166	4166	0	Mymensingh	983	983	0
04.	Minimum Generation (Generation end)	:	8241.00	MW, at =	7:00 hrs	Chattogram	1163	1163	0	Sylhet	510	510	0
05.	Day-peak Generation (Generation end)	:	10314.00	MW, at =	12:00 hrs	Khulna	1353	1353	0	Barishal	298	298	0
06.	Evening-peak Generation (Generation end)	:	12356.00	MW, at =	21:00 hrs	Rajshahi	1256	1256	0	Rangpur	784	784	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Cumilla	1053	1053	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8623.00	MW, at =	5:00 hrs					Total	11566	11566	0
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	1385	MW	13.	Fuel cost :	a) Gas =	162403667	Taka	c) Coal =	62263155	Taka	
	b) Low water level in Kapta lake	:	179	MW		b) Oil =	391374456	Taka	Total =	616041298	Taka		
	c) Plants under shut-down/ maintenance	:	1453	MW	14.	Maximum Temperature in Dhaka was :	31.6° C						
10.	Total Energy (Generation + India Import)	:	246.30	MKWh	15.	Export through East-West interconnections :							
	By Gas =	155.819	MKWh	By Oil =	52.636	MKWh	At evening peak-hour : -192 MW, at 21:00 hrs						
	By Coal =	13.321	MKWh	By Hydro =	0.774	MKWh	Maximum : -196 MW, at 19:30 hrs						
	By Solar =	0.541	MKWh						Energy : 0.772 MKWh				
11.	Total Gas Supplied	:	1238.47	MMCFD									
(D) Forecast of 22.06.21 (Today) Tuesday :													
01.	Maximum Demand	:	12500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15299	MW	(Generation end)	05.	Total Generation	:	249.17	MKWh			
03.	Maximum Shortage	:	-2799	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	35.2° C					

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazool Islam Shaker)
Deputy Secretary, Generation