

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 30-Jun-21							Page - 2
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1280	250	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1210	180	0	0	Under maint.
3	Ghorasal TFP Unit-5	PDB	1210	190	185	4347000	
4	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	300	6814864	Machine problem
5	Ghorasal 78.5 MW PPMAX)	QRPP	240	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	94	1765772	
7	Haripur GTTP	SBU, PDB	232	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1273+1139	412	350	8205098	FGMO
9	Haripur 360MW CAPP(HPL)	IPP	1235+1125	360	292	3738000	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2150+1150	450	300	7106250	Gas shortage
11	Meghnaghat 100 MW (EL)	QRPP	128.9	0	0	0	Contract Expired
12	Meghnaghat CAPP(Summit)	IPP	2110+1110	305	240	6470778	FGMO
13	Madanganj 102 PP(Summit)	QRPP	617	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	317.08+111.3	55	40	192712	Low demand
15	Keraniganj 100 MW PP (Powerpac)	QRPP	813.45	100	0	6245	Reserve.
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	16	239004	Engine problem
17	210 MW Siddhirganj TTP	PDB	1210	115	0	0	Under maint.
18	Siddhirganj 2120 MW GTTP	EGCB	2105	210	40	276000	Gas shortage
19	Siddhirganj 100 PP(Dutch Bangla)	QRPP	128.9	100	24	1070400	Low demand
20	Siddhirganj 335 MW CAPP	EGCB	1217+118	335	100	1633001	Machine problem
21	Gagnagar 102 MW PP (Digital Power)	IPP	128.924	102	16	883728	Low demand
22	Katpott 52 MW PP (Sirha)	IPP	77.9	51	0	0	Fuel shortage
23	Kamatnagar 54 MW PP(Banco Energy)	IPP	318	54	54	1192680	
24	Kodda 150MW PP	BDFB-RPCL	917.06	149	16	939360	Low demand
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	0	24623	Reserve.
26	Nabaganj 55 MW PP (Southern power)	IPP	319.3	55	35	965767	Low demand
27	Bosila 108MW PP(CLG)	IPP	128.775+13.5	108	0	0	Fuel shortage
28	Summit Power (Madhabdi+Ashulla)	SIPP, REB	33.07+41.73	80	46	1221800	Engine problem
29	Macna 33 MW PP(Summit)	SIPP, REB	48.73	33	28	2095990	
30	Rupganj 33 MW PP(Summit)	SIPP, REB	48.73	33	33	812800	
31	Gazipur 52 MW PP	IPP	678.9	52	51	549120	
32	Tongi 80 MW GTTP	PDB	11105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	0	263527	Reserve.
34	Keraniganj 300 MW PP (AFR)	IPP	2561.4	300	0	0	Reserve.
35	Bramhanaganj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	132	2124864	Low demand
38	Gazipur 100 MW PP	RPCL	100 MW	105	84	1983408	Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.56	104	0	172900	Reserve.
40	Manikganj 162MW PP(MPCL)	IPP	918	162	0	1075680	Reserve.
41	Spectra Solar Plant Ltd.	IPP	35	35	0	120297	
Dhaka area Total				5819	2476	55251178	
41	Chattoagram TTP-1	PDB	1210	180	100	2400000	Gas shortage
42	Chattoagram TTP-2	PDB	1210	180	0	0	Gas shortage
43	Raozan 25 MW PP	IPP	378.9	25	6	384505	Engine problem
44	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	22140	
45	Patenga 50MW PP (Baraka)	IPP	876.98	50	12	72000	Low demand
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2140+350	230	24	538980	Low water level & Unit-2 unc
47	Sikalbaha 225MW	PDB	1150+1175	225	203	4792409	FGMO
48	Sikalbaha Peaking GT	PDB	1150	150	100	2280810	Machine problem
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	105	2095990	
50	Hathazari 100 MW peaking PP	PDB	118.9	98	0	0	Under S/D
51	Dohazari-Kalaish 100 MW Peaking	PDB	617	102	68	998334	Engine problem
52	Juldah 100 MW Unit-1 (Acom)	QRPP	813.45	100	100	2158680	
53	Juldah 100 MW PP Unit-3 (Acom)	IPP	0	100	0	1920	Reserve.
54	Barakunda 22 MW PP (Regent)	SIPP, PDB	82.90	22	22	501168	
55	Malancha, Cg. EZZ (United)	IPP	578.73+39.34	0	25	392540	
56	Chattoagram 108 MW PP (ECPV)	IPP	167	108	45	1600320	Engine problem
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	12602	
58	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	Transformer OIL
59	Jodioc Power	IPP	318.55+13.6	54	0	0	Reserve.
60	Karnaphuli Power Ltd.	IPP	110	110	34	1381671	Low demand
61	Juldah unit-2 (Acom)	IPP	813.45	100	100	168960	Transformer OIL
62	Anlima Energy Ltd.	IPP	612.2	116	114	2600637	
Chattoagram area Total				2382	960	22393666	
63	Ashuganj TTP Unit-3	APSCCL	1150	135	80	2194692	Gas Shortage
64	Ashuganj TTP Unit-4	APSCCL	1150	129	0	0	Under maint.
65	Ashuganj TTP Unit-5	APSCCL	1150	134	0	0	Under maint.
66	Ashuganj 225 MW CAPP	APSCCL	1142+1175	221	182	4460000	FGMO
67	Ashuganj 450 MW CAPP(North)	APSCCL	1360	360	310	7549000	FGMO
68	Ashuganj 450 MW CAPP(South)	APSCCL	1360	360	300	7150000	FGMO
69	Ashuganj 50 MW PP	APSCCL	143.968	45	26	595008	Engine problem
70	Ashuganj 55 MW PP (Precision)	RPP	55	55	57	1317600	
71	Ashuganj 195MW PP (APSCCL-United)	IPP	2078.7+116	195	8	200727	Gas shortage
72	Ashuganj 51 MW PP (Midland)	IPP	878.34	51	51	234214	
73	Ashuganj 150MW PP (Midland)	IPP	237.015	150	0	883200	Reserve.
74	Titas 50 MW Peaking PP	PDB	678.92	52	0	20320	Reserve.
75	Chandpur 150 MW CAPP	PDB	1106+1157	163	88	2096380	ST under maint
76	Chandpur 200MW (Desh energy)	IPP	0	200	0	684960	Reserve.
77	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	22	492048	
78	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	11	241920	
79	Impoort (Tripura)	Imported power	0	160	70	2313600	bad weather
80	Jangalia 33MW PP (Summit)	SIPP, PDB	478.73	33	0	663000	Engine problem
81	Jangalia 52 MW PP (Lakdanavi)	IPP	678.92	52	0	331642	Reserve.
82	Cumilla 25 MW PP (Summit)	SIPP, PDB	33.07+26.87	25	0	350050	Engine problem
83	Daudkandi 200 MW PP (B. Trac)	IPP	1541.4	200	0	0	Reserve.
84	Feni Lanka Power	IPP	718.415+119.78	114	99	1282500	
85	Chowmuhani 113 MW	IPP	1279.78+23.1	113	117	2439360	
86	Bhairab 54.5 MW	IPP	318.2	54	18	587520	33 kV feeder fault.
Cumilla Area Total				3034	1439	37045841	
87	RPCL 210MW CAPP	IPP	435+1170	202	155	339720	Gas shortage
88	Tangail 22 MW PP (Doreen)	SIPP, PDB	82.90	22	21	462420	
89	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	95	8	192000	Engine problem
90	Sarishabari 3 MW Solar Plant	IPP	13	3	0	950	
91	Mymensingh 200 MW PP (United)	IPP	200	200	80	379200	Low demand
92	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1545900	
93	Sutakhal 50 MW Solar PP	IPP	50	50	0	177170	
94	Tangail Pali Power Gen 22 MW	IPP	47.6	22	0	166800	
Mymensingh Area Total				709	379	6473532	
95	Fenchugonj CAPP Phase-1	PDB	232+133	70	43	1029000	Machine problem
96	Fenchugonj CAPP Phase-2	PDB	235+135	90	42	991320	Machine problem
97	Kushihara 163 MW CAPP (KP)	IPP	1109+154	163	0	0	Under maintenance
98	Shahjibazar 330 MW CAPP	PDB	3110	330	162	3080	GT-1 under maint
99	Fenchugonj 51 MW PP (Barakatalah)	RPP	192.90	51	38	967800	
100	Fenchugonj 44MW (Energyprima)	RPP	123.3+52	0	0	0	Contract Expired
101	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	11	95332	
102	Shahjibazar GTTP Unit- 8 & 9	PDB	235	66	63	1245120	
103	Shahjibazar 80MW PP (Shahjibazar)	RPP	322.90	86	84	1660800	
104	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under Shut down
105	Sylhet 225 MW CAPP	PDB	1142+1189	231	218	4923750	
106	Sylhet 20 MW GTTP	PDB	120	20	18	402000	
107	Sylhet 50MW PP (EPL)	RPP	272	0	0	0	Contract Expired
108	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	8	254568	Engine problem
109	Bibiana-II 341 MW CAPP (Summit)	IPP	1222+1119	341	290	7083500	FGMO
110	Bibiana-III 400 MW CAPP	PDB	400 MW	400	241	777900	FGMO
111	Sylhet 10MW PP (Desh)	RPP	61.95	10	10	251640	
112	Bibiana South 400 MW	PDB	400 MW	383	401	8815800	
Sylhet Area Total				2377	1629	39168630	
113	Bheramara GTTP Unit-3	PDB	120	16	0	0	Reserve.
114	Bheramara (BDFC)	Imported power	21500	1000	901	21740363	
115	Khulna 115 PP MW (KPCL-2)	QRPP	717	0	0	0	Contract Expired
116	Fariapur 50 MW Peaking PP	PDB	876.89	54	4	87840	Low demand
117	Khulna 225 MW CAPP	NWPGCL	1150+1175	230	0	0	Reserve.
118	Gopalganj 100 MW Peaking PP	PDB	1676.98	109	0	0	Reserve.
119	Bheramara 410 MW CAPP	NWPGCL	1278+1132	410	410	9057888	FGMO
120	Noapara 40 MW PP (Kharanjan Ali)	QRPP	578.5	0	0	0	Contract Expired
121	Noapara 100 MW PP (Bangla Trac)	IPP	701.4	100	100	598080	
122	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	90	1439520	Engine problem
123	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2129	1505	32923691	
124	Bansail 110 MW PP (Summit)	IPP	717.076	110	16	249888	Reserve.
125	Bhola 33 MW PP (Venture)	RPP	134.50	33	34	637547	
126	Bhola 225 MW CAPP	PDB	2163+1168	194	82	2022309	Machine problem
127	Bhola 95 MW PP (Aggreko)	QRPP	961.10	95	11	45372	Gas shortage
128	Payra 1320 MW	BCPCL	21622	1244	380	10098400	
129	Bhola Nutan Biddut BD LTD	IPP	220	0	209	4555900	On Test
130	United Payra Power Ltd.	IPP	818.5+119.5	150	0	0	Line OIL
Bansail Area Total				1626	722	17609416	
131	Baghabari 71 MW GTTP	PDB	1171	71	65	1510000	
132	Baghabari 100 MW GTTP	PDB	1100	100	75	1754000	Gas shortage.
133	Baghabari 50 MW Peaking PP	PDB	678.9	52	0	333904	Reserve.
134	Bera 70 MW Peaking PP	PDB	978.29	71	0	137581	Reserve.
135	Amura 50 MW PP(Sirha)	QRPP	777.9	50	0	197160	Reserve.
136	Katakhal 50 MW PP (Northern)	QRPP	678.9	50	0	8412	Reserve.
137	Katakhal 50 MW Peaking PP	PDB	678.7	50	0	284587	Reserve.
138	Sirajgonj Unit-1 225MW	NWPGCL	1150+1175	210	0	0	Gas shortage
139	Sirajgonj Unit-2 225MW	NWPGCL	1150+1175	220	147	4482764	FGMO
140	Sirajgonj Unit-3 225MW	NWPGCL	1141	220	168	4231709	FGMO
141	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	11282+1132	414	306	8384545	FGMO
142	Sanlahar 50 MW Peaking PP	PDB	678.7	50	0	0	Under maint
143	Bogra 22 MW PP (GDB)	RPP	64	22	18	425520	
144	Bogra 20 MW PP (Energyprima)	RPP	53.3+52	0	0	0	Contract Expired
145	Uliapara 11 MW PP (Summit)	SIPP, REB	42.90	11	0	134784	Engine problem
146	Natore 52 MW PP (Rajlanka)	IPP	678.92	52	52	800640	
147	Chapainawabganj 100 MW Peaking PP	PDB	128.924	104	46	869378	Low demand
148	Baghabari 200 MW PP (Confidence)	IPP	200 MW	200	0	0	Reserve.
149	Bagura 113 MW PP (Confidence)-2	IPP	113 MW	113	0	195648	Reserve.
150	Confidence Power Bogura Unit-1 113 MW	IPP	618.55	113	35	357600	Low demand
151	Sirajgonj 6.55 MW Solar	NWPGCL	16	6	0	7620	
Rajshahi Area Total				2176	914	26113850	
152	Barapukuria TTP Unit-1	PDB	1125	85	0	0	Coal shortage