

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 2-Jun-21		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP Unit-1	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1'210	190	185	4441500	
4	Ghorasal 365 MW CCGP Unit-7	QRPP	1'243+1'122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regen)	IPP	343.35	108	99	2221590	
7	Haripur GTTP	SBU, PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1'273+1'139	412	0	0	Gas shortage
9	Haripur 360MW CCGP(HPL)	IPP	1'235+1'125	360	212	5224000	Gas shortage
10	Meghnaghat 450 MW CCGP(MP)	IPP	2'150+1'150	450	280	6647750	Gas shortage
11	Meghnaghat 100 MW (EL)	QRPP	12'8.9	100	0	0	Contract Expired
12	Meghnaghat CCGP(Summit)	IPP	2'110+1'110	305	260	6165673	FGMO
13	Madanganj 102 PP(Summit)	QRPP	6'17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	55	822690	
15	Keraniganj 100 MW PP (Powerpa)	QRPP	8'13.45	100	74	956099	Engine problem
16	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	425016	
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	177	3723000	FGMO
19	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	100	1230720	
20	Siddhirgonj 335 MW CCGP	EGCB	1'217+1'118	335	0	2581856	Under Maint.
21	Gagnagar 102 MW PP (Digital Pa)	IPP	12'8.924	102	102	1357	
22	Katpotti 52 MW PP (Sinha)	IPP	77.9	51	0	0	Fuel shortage
23	Kamatnagar 54 MW PP(Banco E)	IPP	3'19	54	35	875520	Engine problem
24	Kodda 150MW PP	BFDB-RPCL	9'17.06	149	150	2351040	
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	759491	
26	Nabaganj 55 MW PP (Southern)	IPP	3'19.3	55	55	803240	
27	Bosila 108MW PP(CLG)	IPP	12'8.775+1'3.5	108	0	0	Fuel shortage
28	Summit Power, Madhabdi+Ashul	SIPP, REB	3'3.67+8'7.3	80	45	1076100	Engine problem
29	Machra 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	710300	
30	Ruganaj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	794200	
31	Gazipur 52 MW PP	IPP	6'8.9	52	33	759360	Engine problem
32	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	245	3184035	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	25'11.4	300	302	1571087	
35	Bramhangpan 100 MW PP (Agg)	IPP	100	100	100	525088	
36	Auraha 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	102	583257	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	2521008	
38	Gazipur 100 MW PP	RPCL	100 MW	105	84	2002800	Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'15	104	104	1432320	
40	Meghnaghat 162MW PP(MPCL)	IPP	9'18	162	126	1882080	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	215038	
<b>Dhaka area Total</b>			<b>5919</b>	<b>3214</b>	<b>56487195</b>		
41	Chattogram TPP-1	PDB	1'210	180	100	2400000	Gas shortage
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Raazan 25 MW PP	IPP	3'8.9	25	17	395377	Engine problem
44	Teknaf 20MW PP (SolarTech)	SolarTech Energy	20	20	0	33750	
45	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	50	586560	
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	20	480000	Low water level & Unit-2 unc
47	Sikalbaha 225MW	PDB	1'150+1'175	225	203	4716777	FGMO
48	Sikalbaha Peaking GT	PDB	1'150	150	80	1690085	
49	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2467272	
50	Hathazari 100 MW peaking PP	PDB	1'18.9	98	0	0	Under S/D
51	Dohazari-Kalaish 100 MW Peak	PDB	6'17	102	85	648241	Engine problem
52	Juldah 100 MW Unit-1 (Acorn)	QRPP	8'13.45	100	100	2045760	
53	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1611840	
54	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	21	472224	
55	Matarha, Cg. EZZ (Barak)	IPP	5'8.72+9.34	0	28	472690	
56	Chattogram 108 MW PP (ECPV)	IPP	6'7	108	0	0	Fuel shortage
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	25799	
58	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	0	0	Transformer OIL
59	Jodiac Power	IPP	3'18.55+1'3.6	54	54	1286005	
60	Karnaphuli Power Ltd.	IPP	110	110	110	1985525	
61	Juldah unit-2 (Acorn)	IPP	8'13.6	100	20	518520	Line OIL
62	Anlima Energy Ltd.	IPP	6'21.2	116	17	258436	Line OIL
<b>Chattogram area Total</b>			<b>2382</b>	<b>1110</b>	<b>22091971</b>		
61	Ashuganj TPP Unit- 3	APSCL	1'150	135	0	0	Gas Shortage
62	Ashuganj TPP Unit- 4	APSCL	1'150	129	125	2948710	
63	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Under maint.
64	Ashuganj 225 MW CCGP	APSCL	1'142+1'75	221	217	4844000	
65	Ashuganj 450 MW CCGP(North)	APSCL	1'360	360	355	8172200	FGMO
66	Ashuganj 450 MW CCGP(South)	APSCL	1'360	360	0	0	Under maint.
67	Ashuganj 50 MW PP	APSCL	14'3.968	45	23	497952	Engine problem
68	Ashuganj 55 MW PP (Precision)	RPP	15.4	55	49	1050720	
69	Ashuganj 150MW PP (APCL-U)	IPP	20'37+1'16	185	68	1193368	Gas shortage
70	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1183285	
71	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	70	2085890	230 kv line red hot.
72	Tilas 50 MW Peaking PP	PDB	6'8.92	52	48	546432	
73	Chandpur 150 MW CCGP	PDB	1'106+1'57	163	72	1855390	Machine problem
74	Chandpur 200MW (Desh energy)	IPP	0	200	120	2641920	Engine problem
75	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	503244	
76	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	0	104760	Engine problem
77	Impopr (Tripura)	Imported power	0	160	154	2896320	
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	619100	
79	Jangalia 52 MW PP (Lakdanavi)	IPP	6'8.92	52	43	1023374	Engine problem
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	20	472430	Engine problem
81	Dumkandi 200 MW PP (B.Trac)	IPP	154'11.6	200	200	1033344	
82	Feni Lanka Power	IPP	7'18.415+1'9.78	114	100	2225280	Engine problem
83	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	119	2608200	
84	Bhairab 54.5 MW	IPP	3'18.2	54	35	889200	33 kv feeder fault.
<b>Cumilla Area Total</b>			<b>3034</b>	<b>1923</b>	<b>40155569</b>		
82	RPCL 210MW CCGP	IPP	4'35+1'70	202	135	3255640	Gas shortage
83	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	344594	
84	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	16	357120	Engine problem
85	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	13500	
86	Mymensingh 200 MW PP (Unite)	IPP	200	193	193	2275200	
87	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	115	2556000	
88	Sutakhirali 50 MW Solar	IPP	50	0	0	327200	
89	Tangail Palli Power Gen 22 MW	IPP	4'6.7	22	24	396000	
<b>Mymensingh Area Total</b>			<b>709</b>	<b>503</b>	<b>9595044</b>		
90	Fenchugonj CCGP Phase-1	PDB	2'32+1'33	70	42	1014000	Machine problem
91	Fenchugonj CCGP Phase-2	PDB	2'35+1'35	90	42	997080	Machine problem
92	Kushihara 163 MW CCGP (KP)	IPP	1'109+1'54	163	163	3556636	
93	Shahjibazar 330 MW CCGP	PDB	3'110	330	160	3553008	
94	Fenchugonj 51 MW PP (Barakat)	RPP	19'2.90	51	53	1148000	GT-1 under maint
95	Fenchugonj 44MW (Energyprim)	RPP	12'3.3+5'2	0	0	0	Contract Expired
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	210240	
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	56	1432224	
98	Shahjibazar 80MW PP (Shahjiba)	RPP	32'2.90	86	82	1540800	
99	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under Shut down
100	Sylhet 225 MW CCGP	PDB	1'142+1'89	231	218	4818740	
101	Sylhet 20 MW GTTP	PDB	1'20	20	18	402000	
102	Sylhet 50MW PP (EPL)	RPP	2'72	0	0	0	Contract Expired
103	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	356328	Engine problem
104	Bibiana-II 341 MW CCGP (Summ)	IPP	1'222+1'119	341	320	7408580	FGMO
105	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	366	9085000	FGMO
106	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	7	149940	Engine problem
107	Bibiyana South 400 MW	PDB	400 MW	383	400	9489500	FGMO
<b>Sylhet Area Total</b>			<b>2377</b>	<b>1954</b>	<b>45199888</b>		
108	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	
109	Bheramara (NWDCL)	Imported power	2'500	1000	790	19285818	
110	Fariapur 50 MW Peaking PP	QRPP	7'17	115	0	0	Contract Expired
111	Khulna 225 MW CCGP	PDB	8'6.89	54	20	235630	Engine problem
112	Khulna 225 MW CCGP	NWPGCL	1'150+1'75	230	158	822819	Low demand
113	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	23296	Reserve.
114	Bheramara 410 MW CCGP	NWPGCL	1'278+1'132	410	325	8372736	FGMO
115	Noapara 40 MW CCGP (Kharjahan)	QRPP	5'18	40	0	0	Contract Expired
116	Noapara 100 MW PP (Bangla Tr)	IPP	70'1.4	100	100	636480	
117	Rupsha 105 MW PP (Orion rupa)	IPP	6'18.445	105	105	1046880	
118	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
<b>Khulna Area Total</b>			<b>2284</b>	<b>1498</b>	<b>30423659</b>		
118	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	48	250080	Line OIL
119	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	33	572671	
120	Bhola 225 MW CCGP	PDB	2'63+1'68	194	68	1654003	Machine problem
121	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	0	140350	Machine problem
122	Payra 1320 MW	BCPCL	2'622	1244	560	10147000	
123	Bhola Nutan Biddut BD LTD	IPP	220	0	224	5419009	On Test
124	Uniled Payra Power Ltd.	IPP	8'18.5+1'9.5	150	17	81200	Line OIL
<b>Barisal Area Total</b>			<b>1826</b>	<b>950</b>	<b>18274403</b>		
124	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
125	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage.
126	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	50	876139	
127	Bera 70 MW Peaking PP	PDB	9'8.29	71	40	291943	
128	Annara 50 MW PP(Sinha)	QRPP	7'7.79	50	42	445280	Engine problem
129	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	43	319680	Engine problem
130	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	38	283850	Engine problem
131	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'75	210	0	0	Gas shortage
132	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'75	220	170	4215791	FGMO
133	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	170	4726309	FGMO
134	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1'282+1'132	414	418	9675100	FGMO
135	Sanlahar 50 MW Peaking PP	PDB	6'8.7	50	26	160658	Engine problem
136	Bogra 22 MW PP (GDB)	RPP	6'4	22	21	480240	
137	Bogra 20 MW PP (Energyprima)	RPP	5'3+5'2	0	0	0	Contract Expired
138	Uliapara 11 MW PP (Summit)	SIPP, REB	4'2.90	11	8	188964	Engine problem
139	Natore 52 MW PP (Sajjanka)	IPP	6'8.92	52	52	1027680	
140	Chapainawabganj 100 MW Peak	PDB	12'8.924	104	87	328784	Engine problem
141	Baghabari 200 MW PP (Paramo)	IPP	200 MW	200	200	1068392	
142	Bagura 113 MW PP (Confidenc)	IPP	113 MW	113	113	1503936	
143	Confidence Power Bogura Unit-1	IPP	6'18.55	113	113	1408512	
144	Sirajgonj 6.55 MW Solar	NWPGCL	1'6	6			