

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel.: 9564667, 9551095

Month July, 2021		Day : Sunday			Date : 11.07.21						
Probable Maximum Demand :		13300 MW		Probable Maximum Generation :		15385 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 80.24 ft.		Today = 80.24 ft.		Rule Curve = 85.44 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Rated/ Present Capacity (MW)	10.07.21 (Yesterday)		11.07.21 (Today)		Gen. shortfall for : Gas/Water/Coal limitation MW	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1x 210	210	190	0	0	0	0	190	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	98	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x225+1x125	360	360	344	344	360	360		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	240	240	240	240	210	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	366	326	370	370		
11	Siddhirgonj 210 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	329	326	330	330		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	50	100	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	280	290	300	300		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55		
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	84	84	85		
17	Ganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	94	100	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	20	20		
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	53	55	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	8	8		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	100	100		
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	98	150	150	150		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	300	291	250	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	122	132	130	132		
29	Keranganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	52	100	300		
30	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+9+1x 9.69	100	100	0	25	100	100		
31	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+9+1x 9.69	100	100	0	100	100	100		
32	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	90	104		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	144	126	144		
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	18	0	30	0		
Dhaka Zone Total				5976	5819	2638	3672	3828	4085	420	870
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	54	53	55	55	177	Low Water Level
	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Raczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	44	40	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	110	110	110		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	203	217	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	200	300		
48	Judah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	100	100	100		
49	Judah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	50	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
*	Malancha Cig EPZ (United)	Gas	5x8.73+3x9.34			3	23	10	25		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	85	68	110	110		
56	Judah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	20	100	100	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	116	116	116	116		
Chattogram Zone Total				2442	2382	958	1183	1547	1641	177	180
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	100	100	100	35	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	189	211	210	210		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	280	325	330	350		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	290	350	360		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	52	55	55	55		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	34	34	34	34		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	138	150	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	42	50	0	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	90	90	90		
69	Chandpur 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	17	83	170	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	0	21	21		
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	9x13.4+8x13.95+1x19.99	200	200	0	93	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	100	82	90	90		
77	Chowmahani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	99	110	113	113		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	36	18	36	36		
**	Impopt (Tijpura)	India		160	160	160	150	148	172		
Cumilla Zone Total				3094	3034	1599	1972	2140	2374	465	0
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	170	170	190	190	32	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21		
81	Jamalpur 55 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	24	200	175	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0		
85	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0		
86	Tangail 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	1	24	22	22		
Myensingh Zone Total				717	709	376	538	583	556	32	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.07.21 (Yesterday)		11.07.21 (Today)		10.07.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening					
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43			27	Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30			60	Under maint.	
89	Fenchugonj 51 MW PP (Barakattulah)	Gas (RPP)	19x2.90	51	51	44	47	51	51					
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	62	63					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	162	161	160	160					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	84	84					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	225	219	225	225					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
99	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	315	341					
100	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	281	80	290	300			320	Under maint.	
101	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	396	392	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total				2422	2377	1665	1472	1715	1752	0	407			
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	395	395	400	400					
105	Fandpur 50 MW Peaking PP	HFO (PDB)	6x8.98	54	54	4	19	0	20					
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60					
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	50	100	220					
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.44+7x1.515	100	100	0	100	50	100					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	90	105					
110	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
** Bheramara (HVDC) India				1000	1000	753	804	819	819					
Khulna Zone Total				2133	2129	1169	1473	1559	1824	0	0			
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	33	25	33					
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	83	82	85	86			112	GT-2 & STG Under	
114	Bhola 95 MW PP (Aggregate)	Gas (QRPP)	1.1x96	95	95	11	11	11	11					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	310	540	622	622					
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	110					
Bhola Nutan Biddut BD LTD						201	219	220	220					
Barishal Zone Total				1826	1826	626	902	1073	1192	0	112			
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0					
117	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	70	70	70	30			Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	0	43					
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	34	0	40					
121	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	12	35	35	35					
122	Chapanawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	46	92	50	95					
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	0	30					
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	43	43					
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	41	0	41					
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	150				Gas Shortage, STG S/D	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	175	198	210	210					
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	174	170	200	200					
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	387	401	400	400					
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22					
131	Lullipara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	95	95	95					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	91	90	91					
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0					
Rajshahi Zone Total				2179	2179	880	1423	1484	1678	180	0			
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0				Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0				Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	150	150	150	124			Coal Shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
141	Maipara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
Rangpur Zone Total				685	605	189	263	271	283	294	0			
Sub-total: Plants in operation				21474	21060	10100.0	12898	14200	15385	1588	1569			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9752	12453	13710	14854					
(B) Plants under long term maintenance/ contract expired														
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021	
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020	
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021	
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				549	0	0	0	0	0					
Gross Total				22023	21060	10100	12898	14200	15385	1588	1569			
(C) Actual data of 10.07.21 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	12898.00	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12453.00	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	12958.00	MW, at =	22:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	9523.00	MW, at =	8:00 hrs	Dhaka	4254	0	0	Mymensingh	1073	1073	0	
05.	Day-peak Generation (Generation end)	:	10100.00	MW, at =	12:00 hrs	Chattogram	1261	1261	0	Sylhet	592	592	0	
06.	Evening-peak Generation (Generation end)	:	12898.00	MW, at =	21:00 hrs	Khulna	1537	1537	0	Barishal	371	371	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Rajshahi	1361	1361	0	Rangpur	799	799	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9806.00	MW, at =	5:00 hrs	Cumilla	1205	1205	0					
09.	Generation shortfall at evening peak due to :	:								Total	12453	12453	0	
	a) Gas limitation	:	1117	MW		13.	Fuel cost :	a) Gas = 163681862	Taka	(c) Coal =	69291004	Taka		
	b) Coal supply Limitation	:	294	MW			b) Oil = 490630681	Taka	Total =	723603547	Taka			
	c) Low water level in Kaptai lake	:	177	MW										
	c) Plants under shut down/ maintenance	:	1569	MW		14.	Maximum Temperature in Dhaka was :		34.5° C					
10.	Total Energy (Generation + India Import)	:	263.77	MKWh		15.	Export through East-West interconnections :							
	By Gas =	158.186	MKWH	By Oil =	66.561	MKWh	At evening peak-hour		-196	MW, at	21:00 hrs			
	By Coal =	14.926	MKWH	By Hydro =	1.218	MKWh	Maximum		-244	MW, at	20:00 hrs			
	By Solar =	0.629	MKWH				Energy		1.833	MKWh				
11.	Total Gas Supplied	:	1218.39	MMCFD										
(D) Forecast of 11.07.21 (Today) Sunday :														
01.														