

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month July, 2021		Day : Thursday				Date : 15.07.21					
Probable Maximum Demand :		13700 MW		Probable Maximum Generation :		15387 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 81.51 ft.		Today = 82.06 ft.		Rule Curve = 86.24 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Rated/ Present Capacity (MW)	14.07.21 (Yesterday)		15.07.21 (Today)		Gen. shortfall for : Gas/water/Coal limitation MW	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	110	110	190	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	92	105	100	106		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x225+1x125	360	360	212	210	300	300	150	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	220	220	240	240	230	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	275	275	325	325	137	Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	59	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	324	335	335		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	99	100	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	230	230	300	300		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	12	55	55	55		
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	85	84	85		
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	94	94	100	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	20	20		
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	43	55	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	52	51	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	100	100		
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	148	150	150	150		
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banoo Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	217	275	250	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	104	149	149	149		
29	Keranganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	108	100	300		
30	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	40	100	100		
31	Auralah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	99	100	100		
32	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
34	Bosila 108MW PP(RCLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	31	104	104	104		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	126	162	126	126		
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	33	0	30	0		
Dhaka Zone Total				5976	5819	2642	3545	3915	4144	727	870
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	83	88	88	88	142	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	6	0	5	0		
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	110	110	110		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	223	203	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	200	300		
48	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	82	100	100		
49	Juddah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	70	100	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	25	10	25		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	85	110	110	110		
56	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	96	94	116	116		
Chattogram Zone Total				2442	2382	1127	1265	1591	1681	142	180
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	80	100	100	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	167	213	210	210		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	320	280	330	350		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	305	330	0	360		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	20	55	55		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	34	34	34	34		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	133	150	150	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	43	50	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	31	86	90	90		
69	Chandpur 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	51	156	170	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	20	21	21		
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+8x1.95+1x1.95	200	200	0	200	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	114	105	105		
77	Chowmahani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	105	115	113	113		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	15	36	36	36		
**	Impopt (Tijpura)	India		160	160	122	132	148	172		
Cumilla Zone Total				3094	3034	1662	2149	1855	2389	505	0
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	144	148	160	160	54	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	106	106	115	115		
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	110	184	175	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	15	0	50	0		
86	Tangail 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
Myensingh Zone Total				717	709	430	491	553	526	54	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.07.21 (Yesterday)		15.07.21 (Today)		14.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43			27	Under maint.
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30			60	Under maint.
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			163	Under maint.
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	0	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	56	62	63				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	160	163	163	163				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	84	84	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	219	225	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16				
99	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	300	300				
100	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	371	400	400				
101	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	387	397	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total				2422	2377	1768	1740	1813	1814	0	250		
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	370	305	400	400				
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	19	0	20				
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60				
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	155	0	160				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.44+7x1.515	100	100	0	100	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	105	105	105				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
** Bheramara (HVDC) India				1000	1000	815	814	831	831				
Khulna Zone Total				2133	2129	1238	1498	1486	1776	0	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	22	34	25	33				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	86	85	86				
114	Bhola 95 MW PP (Aggregate)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	450	622	622				
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	0	110				
Bhola Nutan Biddut BD LTD						218	220	220	220				
Barishal Zone Total				1826	1826	707	855	1073	1192	0	0		
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71				Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0				Gas Shortage
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	50	50				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	20	40				
121	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
122	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	52	92	95	95				
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	40	40				
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	43	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	0	30				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			150	Gas Shortage, STG S/D
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	133	170	210	210				
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	183	180	200	200				
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	389	413	400	400				
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22				
131	Lullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	95	95	95				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	88	94	94	94				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total				2179	2179	1070	1277	1538	1582	321	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0				Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0				Coal Shortage
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150			124	Coal Shortage
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	50	107	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Maipara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
Rangpur Zone Total				685	605	202	257	271	283	294	0		
Sub-total: Plants in operation				21474	21060	10846.0	13077	14095	15387	2043	1300		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10353	12483	13454	14688				
(B) Plants under long term maintenance/ contract expired													
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				Contract Expired on 14/02/2021
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 04/01/2020
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 12/11/2020
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 07/05/2021
147	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 31/05/2021
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 28/05/2021
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021
Sub-Total: Plants under long term maintenance/ contract expired				549	0	0	0	0	0				
Gross Total				22023	21060	10846	13077	14095	15387	2043	1300		
(C) Actual data of 14.07.21 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	: 13077.00 MW, at = 21:00 hrs		12.		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 12483.00 MW, at = 21:00 hrs		Zone		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	: 13165.00 MW, at = 23:00 hrs		MW		MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	: 9708.00 MW, at = 8:00 hrs		Dhaka		4359	4359	0	Mymensingh	1009	1009	0	
05.	Day-peak Generation (Generation end)	: 10846.00 MW, at = 12:00 hrs		Chattogram		1307	1307	0	Sylhet	470	470	0	
06.	Evening-peak Generation (Generation end)	: 13077.00 MW, at = 21:00 hrs		Khulna		1572	1572	0	Barishal	366	366	0	
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs		Rajshahi		1402	1402	0	Rangpur	782	782	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10230.00 MW, at = 5:00 hrs		Cumilla		1216	1216	0					
09.	Generation shortfall at evening peak due to :									Total	12483	12483	0
	a) Gas limitation	: 1607 MW				13.		Fuel cost :		(a) Gas = 160146726 Taka	(c) Coal = 69869742 Taka	Taka	
	b) Coal supply Limitation	: 294 MW								(b) Oil = 620292436 Taka	Total = 850308904 Taka		
	c) Low water level in Kaptai lake	: 142 MW											
	d) Plants under shut down/ maintenance	: 1300 MW											
10.	Total Energy (Generation + India Import)	: 276.83 MKWh											
	By Gas = 155.089 MKWh	By Oil = 81.245 MKWh											
	By Coal = 15.053 MKWh	By Hydro = 1.999 MKWh											
	By Solar = 0.757 MKWh												
11.	Total Gas Supplied	: 1183.90 MMCFD											
(D) Forecast of 15.07.21 (Today) Thursday :													
01.	Maximum Demand	: 13700 MW (Generation end)		04.		Maximum Load-shed		: 0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	: 15387 MW (Generation end)		05.		Total Generation		: 288.08 MKWh					