

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP Unit-1	PDB	1*260	260	0	0	Gas shortage
2	Ghorasal Repowered CAPP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TFP Unit-5	PDB	1*210	190	0	0	Under maint.
4	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	300	7170491	Machine problem
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	106	1252454	
7	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	277	6758400	Gas shortage
9	Haripur 360MW CAPP (HPL)	IPP	1*235+1*125	360	350	7314000	
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	220	5518000	Gas shortage
11	Meghnaghat 100 MW (IEL)	ORPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	290	6469440	FGMO
13	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	30	426469	High voltage
15	Karanganj 100 MW PP (Powerpa)	ORPP	8*13.45	100	0	122601	Reserve.
16	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.9	22	19	342036	Engine problem
17	210 MW Siddhirgonj TTP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	100	90	2053814	Engine problem
20	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	335	7565331	
21	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	0	536112	Reserve.
22	Kalgaon 52 MW PP (Sri)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalghat 54 MW PP(Banco En	IPP	3*18	54	54	1108800	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	64	2163360	High voltage
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	17	426733	High voltage
26	Nabaganj 55 MW PP (Southern)	IPP	3*19.3	55	17	883294	
27	Bosila 108MW PP(CLO)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
28	Summit Power (Madhatir-Ashuli)	SIPP, REB	3*3.67+4*9.73	80	41	1058320	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	28	813700	
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	801100	
31	Gazipur 52 MW PP	IPP	6*8.9	52	51	1087680	
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	195	2644581	High voltage
34	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
35	Shamshaganj 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	35	941760	High voltage
38	Gazipur 100 MW PP	RPCL	100 MW	105	35	2126400	Low demand
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	70	484800	High voltage
40	Manikganj 162MW PP(MPL)	IPP	9*18	162	162	2796480	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	46860	
Dhaka area Total				5819	2819	62880762	
42	Chattogram TTP-1	PDB	1*210	180	100	2400000	Gas shortage
43	Chattogram TTP-2	PDB	1*210	180	0	0	Gas shortage
44	Raozan 25 MW PP	IPP	3*8.9	25	25	557076	
45	Teknaf 20MW PP (Solartek)	Teknaf Solartek Energ	20	20	0	111510	
46	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	22	179320	Low demand
47	Kapila Hydro Unit-2,3,4, 5	PDB	2*40+3*50	230	123	2888104	Low water level & Unit-2 under maint
48	Sikalbaha 225MW	PDB	1*150+1*175	225	0	3070075	Machine problem
49	Sikalbaha Peaking GT	PDB	1*150	150	120	2867614	Machine problem
50	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2459745	
51	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
52	Dhazari-Kalash 100 MW Peakin	PDB	6*17	102	51	398138	Fuel shortage
53	Juidah 100 MW Unit-1	ORPP	8*13.45	100	82	1913760	Engine problem
54	Juidah 100 MW Unit-3 (Acorn)	IPP	0	100	70	885120	High voltage
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	465024	
56	* Malancha, Cig. EPZ (Uniled)		5*8.73+3*9.34	0	40	608640	
57	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
58	Kapla 7 MW Solar PP	PDB	7*4 MW	7	0	27480	
59	Arwara 300 MW PP (Uniled)	IPP	300 MW	300	104	480	Transformer O/L
60	Jodac Power	IPP	3*18.55+1*3.6	54	36	227545	Engine problem
61	Karnaphuli Power Ltd.	IPP	110	110	110	1968791	
62	Juidah unit-2 (Acorn)	IPP	8*13.6	100	100	1389120	
63	Anlima Energy Ltd.	IPP	6*21.2	116	112	2691000	
Chattogram area Total				2382	1220	25088742	
64	Ashuganj TTP Unit-3	APSC	1*150	135	135	2076060	Gas shortage
65	Ashuganj TTP Unit-4	APSC	1*150	129	0	0	Gas shortage
66	Ashuganj TTP Unit-5	APSC	1*150	134	0	0	Under maint.
67	Ashuganj 225 MW CAPP	APSC	1*142+1*75	221	192	4741000	Gas shortage
68	Ashuganj 450 MW CAPP(North)	APSC	1*360	360	25	4887100	Tripped at 17:13
69	Ashuganj 450 MW CAPP(South)	APSC	1*360	360	285	6596000	FGMO
70	Ashuganj 50 MW PP	APSC	14*3.968	45	26	560592	Engine problem
71	Ashuganj 55 MW PP (Prehistan)	IPP	15.4	55	56	716640	
72	Ashuganj 195MW PP (APSC) Un	IPP	20*9.73+1*116	195	73	692181	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	1043328	Engine problem
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	150	3214981	
75	Titas 50 MW Peaking PP	PDB	6*8.92	50	50	753344	
76	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	90	2105080	Machine problem
77	Chandpur 200MW (Desh energy)	IPP	0	200	141	3069520	Engine problem
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	471168	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	176590	
80	** Impport (Tripura)	Imported power	0	160	130	2694720	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	795800	
82	Jangalia 52 MW PP (Lakdanav)	IPP	6*8.92	52	43	606490	Engine problem
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	434040	
84	Daudkandi 200 MW PP (B. Trae)	IPP	15*14.4	200	0	0	Reserve.
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	1067040	
86	Chowmahani 113 MW	IPP	12*9.78+2*3.1	113	106	2449440	Engine problem
87	Bhairab 54.5 MW	IPP	3*18.2	54	36	536040	33 kV feeder fault.
Cumilla Area Total				3034	1780	39613544	
88	RPCL 210MW CAPP	IPP	4*35+1*70	202	152	3626800	Gas shortage
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	463680	
90	Jamalpur 95 MW PP (Powerpac)	IPP	12*8.924	95	8	180480	Engine problem
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	8600	
92	Mymensingh 200 MW PP (Uniled)	IPP	200	200	194	3002400	Engine problem
93	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	115	2684400	
94	Sutlakhal 50 MW Solar PP	IPP	50	50	0	204400	
95	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	24	501840	
Mymensingh Area Total				798	514	10872800	
96	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	43	1030000	Machine problem
97	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	30	636640	Machine problem
98	Kushira 163 MW CAPP (KP)	IPP	1*109+1*54	163	0	0	Under maint.
99	Shajibazar 330 MW CAPP	PDB	3*110	330	162	3586000	GT-1 under maint
100	Fenchugonj 51 MW PP (Barakat)	RPP	19*2.90	51	53	1156200	
101	Fenchugonj 44MW (Energyprma)	IPP	12*3.35+2	0	0	0	Contract Expired
102	Haliganj 11MW PP (Doreen-E)	SIPP, REB	4*2.90	11	11	155328	
103	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	56	1353792	
104	Shajibazar 66MW PP (Shajibaz)	RPP	32*2.90	86	84	1624320	
105	Shajibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
106	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	218	5066360	
107	Sylhet 20 MW GTTP	PDB	1*20	20	18	392000	
108	Sylhet 50MW PP (CPL)	RPCL	0	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	306384	Engine problem
110	Bibiana-II 341 MW CAPP (Summ	IPP	1*222+1*119	341	290	7105000	FGMO
111	Bibiana-III 400 MW CAPP	PDB	400 MW	400	400	9214000	FGMO
112	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	240120	
113	Bibiana South 400 MW	PDB	400 MW	383	400	9571900	
Sylhet Area Total				2377	1791	41438044	
114	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
115	** Bheramara (HVDC)	Imported power	2*500	1000	808	19554909	
116	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
117	Faridpur 50 MW Peaking PP	PDB	6*8.89	54	16	111910	Engine problem
118	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	230	158	977876	ST not available
119	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
120	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	285	6724800	Gas shortage
121	Noapara 40 MW PP (Khanjahan A)	ORPP	5*8.5	0	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	100	985920	
123	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	2280480	
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	15	177984	High voltage
Khulna Area Total				2129	1487	30813879	
125	Barisal 110 MW PP (Summit I)	IPP	7*17.076	110	48	340320	Line O/L
126	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	34	686660	
127	Bhola 225 MW CAPP	PDB	2*63+1*68	194	0	0	Under maint.
128	Bhola 95 MW PP (Aggreko)	ORPP	9*6*1.10	95	76	1755737	Gas shortage
129	Payra 1320 MW	BCPCL	2*622	1244	280	9867100	Boiler problem
130	Bhola Nufan Biddut BD LTD	IPP	220	0	220	5161200	
131	Uniled Payra Power Ltd.	IPP	8*18.5+1*9.5	150	116	1098000	Engine problem
Barisal Area Total				1828	774	1821017	
132	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
133	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
134	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	566256	
135	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Engine problem
136	Amnura 50 MW PP(Sinha)	ORPP	7*7.79	50	35	669880	Engine problem
137	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	0	0	Fuel shortage
138	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	36	215768	Engine problem
139	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
140	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	140	3694282	Gas shortage
141	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	178	4416491	Gas shortage
142	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1*282+1*132	414	415	8907691	FGMO
143	Santalhar 50 MW Peaking PP	PDB	6*8.7	50	27	272922	Engine problem
144	Bogra 22 MW PP (Doreen)	RPP	6*4	22	22	507600	
145	Bogra 20 MW PP (Energyprma)	RPP	5*3.35+2	0	0	0	Contract Expired
146	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	266040	
147	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	680160	
148	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	92	1432784	Engine problem
149	Baghabari 200 MW PP (Paramou	IPP	200 MW	200	0	0	Reserve.
150	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	45	692992	Low demand
151	Confidence Power Bogura Unit-1	IPP	8*18.5	113	113	1823384	
152	Sirajgonj 8.55 MW Solar	NWPGCL	1*6	6	0		