

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2021		Day : Friday				Date : 13.08.21						
Probable Maximum Demand :		12800 MW		Probable Maximum Generation :		15044 MW						
Water Level of Kaptai Lake at 06:00 AM				Yesterday =	89.75	ft.	Today =	90.04	ft.	Rule Curve =	92.84	ft.
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.08.21 (Yesterday)		13.08.21 (Today)		12.08.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0		260	Under maint.
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Gas Shortage
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	197	192	310	300		168	Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	240	240	240	240		210	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	230	282	280	280		130	Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	326	332	335	335			
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	0	0	0			
14	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	305	305	265	265	300	300			
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	12	85	85			
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	84	102	102	102			
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	21	20	20			
19	Summit Power.(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	45	55	55	55			
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	33	33	33			
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	52	52			
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	91	105	100	100			
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	32	150	150	150			
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
26	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	250	300	285	285			
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	143	149	149			
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	102	100	300			
30	Bramhangaoan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	100	100			
31	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	102	50	100			
32	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	56	17	55	55			
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	75	95	94	94			
36	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
37	Manikgonj 35MW Solar PP (Inspectra :)	Solar (IPP)	1x35	35	35	28	0	30	0			
Dhaka Zone Total				5976	5819	2944	3420	3704	3914	846	660	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	118	118	120	120		112	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	110	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	6	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	50	50	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbe)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	71	200	300			
48	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	84	100	100	100			
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	0	21	21			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	30	20	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	84	96	97	97			
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	107	110	110			
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	116	116	116	116			
Chattogram Zone Total				2442	2382	1157	1220	1445	1520	112	555	
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0		135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0		129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	80	80	80		54	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	20	23	23			
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	181	212	215	215			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	295	265	330	330			
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	260	275	330	330			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	30	55	55			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8		187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	138	148	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50			
68	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	90	91	90	90			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	20	21	21			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+6x1.515+15x1.056	200	200	0	200	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	51	114	113	113			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	105	115	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impoprt (Tripura)	India		160	160	128	152	138	164			
Cumilla Zone Total				3094	3034	1779	2158	2194	2320	505	0	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	134	131	156	156			
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	91	111	112	112			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	179	189	175	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	21	0	50	0			
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	24	25	24	24			
Mymensing Zone Total				717	709	479	48					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.08.21 (Yesterday)		13.08.21 (Today)		12.08.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
87	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	Under maint.		
88	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	52	53	51	51					
90	Kushiara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	3	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	63	62	62					
93	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	236	250	260	260					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	83	84	84					
95	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	217	217	200	200					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24					
99	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	295	341	341					
100	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	366	400	400	400					
101	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	230	52	350	350					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total					2422	2377	1842	1715	2059	2059	0	75		
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	305	300	320	320	110		Gas Shortage		
105	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	10	0	20					
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60					
107	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	0	70	0	225					
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	15	60	50	100					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	694	693	705	705					
Khulna Zone Total					2133	2129	1119	1238	1280	1635	110	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	25	34	33	33					
113	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	88	87	89	89		107	Under maint.		
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	12	12					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	400	560	622	622					
116	Potua khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	150	150					
117	Bhola 220MW CCGP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	216	218	220	220					
Barishal Zone Total					2046	2046	740	927	1236	1236	0	107		
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	43	43					
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	33	0	40					
122	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	12	35	35	35					
123	Chapainawabganj 100 MW Peaking PF	HFO (PDB)	12x8.924	104	104	0	95	95	95					
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	35	35					
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	33					
127	Sirajonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			Gas Shortage,STG SD		
128	Sirajonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	147	147	161	161					
129	Sirajonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	181	182	200	200					
130	Sirajonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	389	417	400	400					
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52					
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	113	113	113					
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113					
136	Sirajonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0					
Rajshahi Zone Total					2179	2179	1000	1325	1486	1553	171	0		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	154	155	153	153	119		Coal Shortage		
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2.3	113	113	99	105	113	113					
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
142	Majipara, Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0					
Rangpur Zone Total					685	605	253	260	274	286	289	0		
Sub-total: Plants in operation					21694	21280	11313.0	12748	14226	15044	2033	1397		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							10772	12138	13545	14324				
(B) Plants under long term maintenance/ contract expired														
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
145	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired					337	0	0	0	0	0				
Gross Total					22031	21280	11313	12748	14226	15044	2033	1397		
(C) Actual data of 12.08.21 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	12748.00	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	12138.00	MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	12748.00	MW, at = 21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	9889.00	MW, at = 8:00 hrs	Dhaka	4166	4166	0	Mymensingh	965	965	0		
05.	Day-peak Generation (Generation end)	:	11313.00	MW, at = 12:00 hrs	Chattogram	1251	1251	0	Sylhet	500	500	0		
06.	Evening-peak Generation (Generation end)	:	12748.00	MW, at = 21:00 hrs	Khulna	1576	1576	0	Barishal	369	369	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 21:00 hrs	Rajshahi	1278	1278	0	Rangpur	804	804	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8636.00	MW, at = 5:00 hrs	Cumilla	1229	1229	0						
09.	Generation shortfall at evening peak due to :	:							Total	12138	12138	0		
	a) Gas limitation	:	1632	MW	13.	Fuel cost :	(a) Gas = 156822114 Taka	(c) Coal = 74562257 Taka						
	d) Coal supply Limitation	:	289	MW			(b) Oil = 651064971 Taka	Total = 882449342 Taka						
	b) Low water level in Kaptai lake	:	112	MW										
	c) Plants under shut down/ maintenance	:	1397	MW										
10.	Total Energy (Generation + India Import)	:	275.62	MKWh	14.	Maximum Temperature in Dhaka was :	33.8° C							
	By Gas = 147.537 MKWh				15.	Export through East-West interconnections :								
	By Coal = 16.090 MKWh					At evening peak-hour	: -514 MW, at 21:00 hrs							
	By Solar= 0.460 MKWh					Maximum	: -534 MW, at 22:00 hrs							
						Energy	: 4.2965 MKWh							
11.	Total Gas Supplied	:	1188.65	MMCFD										
(D) Forecast of 13.08.21 (Today) Friday :														
01.	Maximum Demand	:	12800	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15044	MW (Generation end)	05.	Total Generation	:	276.74	MKWh					
03.	Maximum Shortage	:	-2244	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :		32.5° C						

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)

Deputy Secretary, Generation