

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	Generation			
			MW	MW	KWH		
1	Ghorasal Repowered CAPP Unit-3	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-2	PDB	1210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1210	190	100	267500	Gas shortage
4	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	300	732094	Machine problem
5	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
7	Harihar GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Harihar 412 MW CAPP	EGCB	1273+1139	412	381	8921090	
9	Harihar 360MW CAPP(HPL)	IPP	1235+1125	360	251	4918000	Machine problem
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	240	5630750	Gas shortage
11	Meghnaghat 100 MW(LEL)	QRPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	260	6512931	FGMO
13	Madangan 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madangan 35 MW PP(Summit)	(IPP)	3*11.08+1*11.3	55	42	942210	Engine problem
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	43513	Reserve.
16	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	417636	
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirgonj 100 PPI/Dutch Bangla	QRPP	12*8.9	100	0	0	Contract Expired
20	Siddhirgonj 335 MW CAPP	EGCB	1211+118	335	333	7279712	
21	Gagunagar 102 MW PP (Digital Po	IPP	12*8.924	102	32	686880	Low demand
22	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1313280	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	98	1047840	Low demand
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	958572	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	911495	
27	Bostia 108MW PP(CLO)	IPP	12*8.775+1*9.5	108	0	0	Fuel shortage
28	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	47	1043880	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	821900	
30	Ruggan 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	684500	
31	Gazipur 52 MW PP	IPP	6*8.9	52	0	95040	Reserve.
32	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	95	1510472	
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.
35	Bramhangaoan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	95	2216740	Low demand
38	Gazipur 100 MW PP	RPCL	100 MW	105	17	921600	Low demand
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.9	104	93	1056960	Engine problem
40	Manikganj 162MW PP(MPL)	IPP	9*18	162	162	1915200	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	121912	
<b>Dhaka area Total</b>				<b>5819</b>	<b>2798</b>	<b>59970577</b>	
42	Chattogram TPP-1	PDB	1*210	180	100	2400000	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
44	Razzan 25 MW PP	IPP	3*9.9	25	16	97952	Low demand
45	Taknaf 20MW (Solar)Tknaf Solar	Energy		20	0	100170	
46	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	0	74400	Reserve.
47	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	123	2865571	Low water level
48	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	1855046	
51	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	0	0	Under S/D
52	Dohazari-Kalesh 100 MW Peakin	PDB	6*17	102	68	508797	Low demand
53	Judah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	139560	Low demand
54	Judah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1670400	
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	470832	
56	Malancha Ctg. EP2 (Unite)	IPP	5*8.73+3*9.34	0	42	813600	
57	Chattogram 108 MW PP (ECPV)	IPP	18*5.9	108	95	1975680	Engine problem
58	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	21455	
59	Anwara 300 MW PP (Unite)	IPP	300 MW	300	16	722618	Transformer OIL
60	Jodac Power	IPP	3*18.55+1*3.6	54	0	0	Transformer OIL
61	Karnaphuli Power Ltd.	IPP	110	110	110	2229735	
62	Judah unit-2 (Acorn)	IPP	8*13.6	100	100	1422720	
63	Anilma Energy Ltd.	IPP	6*21.2	116	116	2773800	
<b>Chattogram area Total</b>				<b>2382</b>	<b>1021</b>	<b>2042336</b>	
64	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
65	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSCL	1*150	134	120	1993582	Gas shortage
67	Ashuganj 225 MW CAPP	APSCL	1*142+1*75	221	206	4683000	FGMO
68	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	270	5750900	FGMO
69	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	300	6906000	FGMO
70	Ashuganj 50 MW PP (Precision)	APSCL	14*3.988	45	23	447912	Engine problem
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	56	724800	
72	Ashuganj 195MW PP (APSCL-UR)	IPP	20*9.73+1*16	195	45	351272	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	771724	Engine problem
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	115	1577381	Engine problem
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
76	Chandpur 150 MW CAPP	IPP	1*106+1*57	163	138	328120	Engine problem
77	Chandpur 200MW (Desh energy)	IPP	0	200	155	2241600	Engine problem
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	477000	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	268300	
80	Impoport (Tripura)	Imported power	0	160	120	2590080	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	781500	
82	Jangalia 52 MW PP (Lakshman)	IPP	6*8.92	52	25	379814	
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*9.97	25	21	633100	
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	213180	Low demand
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	118	2105040	
87	Bhairab 54.5 MW	IPP	3*18.2	54	17	442800	33 kV feeder fault.
<b>Cumilla Area Total</b>				<b>3034</b>	<b>1647</b>	<b>36511705</b>	
88	RPCL 210MW CAPP	IPP	4*35+1*70	202	134	2698930	
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	479988	Gas shortage
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	6	149760	Engine problem
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	8050	
92	Mymensingh 200 MW PP (Unite)	IPP	200	200	200	2668800	
93	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	79	2157600	Engine problem
94	Sylhet 50 MW Solar PP	IPP	50	50	0	214980	
95	Tangail Fall Power 22 MW	IPP	4*6.7	22	24	523440	
<b>Mymensingh Area Total</b>				<b>709</b>	<b>464</b>	<b>8721658</b>	
96	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	43	1058000	Machine problem
97	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	42	996840	Machine problem
98	Kushihara 163 MW CAPP (KP)	IPP	1*109+1*54	163	163	3908536	
99	Shahbazar 330 MW CAPP	PDB	3*110	330	273	6231000	
100	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	53	702000	
101	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	8	124704	
103	Shahbazar GTPP Unit- 8 & 9	PDB	2*35	66	0	713280	Under maint.
104	Shahbazar 86MW PP (Shahbaz)	RPP	32*2.90	86	81	1473600	
105	Shahbazar 100 MW GTPP	PDB	1*100	100	0	0	Under Shut down
106	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	219	4295170	
107	Sylhet 20 MW GTPP	PDB	1*20	20	0	0	Engine problem
108	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	456844	
110	Bibiana-II 341 MW CAPP (Summ	IPP	1*222+1*119	341	300	7098000	FGMO
111	Bibiana-III 400 MW CAPP	PDB	400 MW	400	367	8724000	
112	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	189720	
113	Bibiana South 400 MW	PDB	400 MW	383	300	78737100	
<b>Sylhet Area Total</b>				<b>2377</b>	<b>1883</b>	<b>43644794</b>	
114	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
115	Bheramara (HVDC)	Imported power	2*500	1000	686	16737454	
116	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
117	Fairpur 50 MW Peaking PP	PDB	6*8.89	54	0	0	Reserve.
118	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	220	100	769920	Low demand
119	Gopalganj 100 MW Peaking PP	PDB	16*8.98	109	0	0	Reserve.
120	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	295	6992640	Gas shortage
121	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	0	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	100	1579200	
123	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	2011680	
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
<b>Khulna Area Total</b>				<b>2128</b>	<b>1286</b>	<b>28908894</b>	
125	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
126	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	31	551861	
127	Bhola 225 MW CAPP	PDB	2*63+1*68	194	88	2129288	Machine problem
128	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	11	283117	Gas shortage
129	Payra 1320 MW	BCPCL	2*622	1244	510	10383800	Line O/L
130	Bhola Nutan Biddu BD LTD	IPP	220	220	222	4356409	
131	Unite Payra Power Ltd.	IPP	8*18.8+1*9.5	150	0	0	Line O/L
<b>Barisal Area Total</b>				<b>2046</b>	<b>862</b>	<b>17704475</b>	
132	Baghbari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage
133	Baghbari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage
134	Baghbari 50 MW Peaking PP	PDB	6*8.9	52	43	243984	Engine problem
135	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
136	Amnara 50 MW PP(Sinha)	QRPP	7*7.79	50	0	0	Fuel shortage
137	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Fuel shortage
138	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	30	151583	Engine problem
139	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
140	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	148	3558036	FGMO
141	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	208	4958473	FGMO
142	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1*282+1*132	414	374	8995927	FGMO
143	Santihar 50 MW Peaking PP	PDB	6*8.2	50	24	82472	Engine problem
144	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	503040	
145	Bogura 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired
146	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	243432	
147	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	43	745440	Engine problem
148	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	93	685520	Engine problem
149	Baghbari 200 MW PP (Paramou	IPP	200 MW	200	0	0	Reserve.
150	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	1357847	
151	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	947904	
152	Sirajgonj 6.55 MW Solar	NWPGCL	1*6	6	0	21240	