

Date : 30-Aug-21		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
			Unit No. X Capacity	MW	Generation	KWH	
				MW	MW	KWH	
1	Ghorasal Repowered CAPP Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	310	7407145	Machine problem
4	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Harihar GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Harihar 412 MW CAPP	EGCB	1*273+1*139	412	0	0	Machine problem
7	Harihar 360MW CAPP(HPL)	IPP	1*235+1*125	360	175	4884000	Gas shortage
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	280	6598500	Gas shortage
9	Meghnaghat 100 MW(LEL)	QRPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	260	6733731	FGMO
11	Madangan 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
12	Madangan 35 MW PP(Summit)	(IPP)	3*11.08+1*11.3	55	40	1001769	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	12	413749	Unit transformer problem.
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	448380	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	92	2204000	Gas shortage
17	Siddhirgonj 100 PPI/Dutch Bangla	QRPP	12*8.9	100	0	0	Contract Expired
18	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	212	3194701	
19	Gaguar 102 MW PP (Digital Po	IPP	12*8.924	102	102	2180592	
20	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1125360	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	98	939840	Fuel shortage
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1246750	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1076315	
25	Bostia 108MW PP(PLC)	IPP	12*9.775+1*9.5	108	0	0	Fuel shortage
26	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	53	1249440	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	818600	
28	Ruggan 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	821600	
29	Gazipur 52 MW PP	IPP	6*8.9	52	45	918240	Engine problem
30	Tongi 80 MW GTPP	PDB	1*105	0	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	300	6754470	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	305	2110843	
33	Bramhangonj 100 MW PP (Aggr	IPP	100	100	100	820547	
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	101	1073304	
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	149	3399408	
36	Gazipur 100 MW PP	RPCL	100	105	90	1855200	Engine problem
37	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	94	2152320	Engine problem
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	3926880	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	196790	
Dhaka area Total				5819	3232	6552474	
40	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
41	Chattogram TPP-2	PDB	1*210	180	120	3000000	Gas shortage
41	Rozair 25 MW PP	IPP	3*8.9	25	25	426877	
42	Taknaf 20MW PP (Solartech/Teknaf Solartech Energ	IPP	20	20	0	1007100	
43	Patenga 50MW PP (Baraka)	IPP	6*8.98	50	50	820320	
44	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	127	3037382	Low water level
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2543381	
48	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dohazari -Kalesh 100 MW Peakin	PDB	6*17	102	68	718588	Engine problem
50	Juidah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	100	1730400	
51	Juidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2416320	
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	453264	Engine problem
*	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	20	355200	
53	Chattogram 108 MW PP (ECPV)	IPP	18*5.6	108	0	0	Fuel shortage
54	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	17879	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	180	3728509	Transformer OIL
56	Jodac Power	IPP	3*18.55+1*3.6	54	0	0	Transformer OIL
57	Karnaphuli Power Ltd.	IPP	110	110	94	2372753	Engine problem
58	Juidah unit-2 (Acorn)	IPP	8*13.6	100	80	2012160	Engine problem
59	Anilma Energy Ltd.	IPP	6*21.2	116	114	2753727	
Chattogram area Total				2382	1203	26487470	
60	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
60	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
61	Ashuganj TPP Unit-5	APSCL	1*150	134	70	1783204	
61	Ashuganj 225 MW CAPP	APSCL	1*142+1*75	221	156	4456000	Gas shortage
62	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	300	4152900	Gas shortage
63	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	270	7127000	FGMO
64	Ashuganj 50 MW CAPP	APSCL	14*3.988	45	23	368184	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	30	966240	
66	Ashuganj 195MW PP (APSCL-UH	IPP	20*9.73+1*16	195	8	317818	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	754320	Engine problem
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	133	3186531	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	50	702920	
70	Chandpur 150 MW CAPP	IPP	1*106+1*57	163	133	3279350	
71	Chandpur 200MW (Desh energy)	IPP	0	200	200	4516160	Machine problem
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	486540	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	0	221040	
**	Impoport (Tripura)	Imported power	0	160	138	2905920	
**	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	606000	Engine problem
75	Jangalia 52 MW PP (Lakshana)	IPP	6*8.92	52	43	799181	Engine problem
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	483940	
77	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	200	1837440	
78	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	2828280	
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	98	2368800	Engine problem
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	443520	33 kV feeder fault.
Cumilla Area Total				3034	2086	43833288	
81	RPCL 210MW CAPP	IPP	4*35+1*70	202	118	29128280	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	490500	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	8	183360	Engine problem
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10650	
85	Mymensingh 200 MW PP (United)	IPP	200	200	175	1742400	Engine problem
86	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1543200	
87	Sylhetbazar 50 MW Solar PP	IPP	50	50	0	204550	
88	Tangail Fall Power 22 MW	IPP	4*6.7	22	24	653520	
Mymensingh Area Total				709	461	7681060	
89	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	43	1029000	Machine problem
90	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	42	989520	Machine problem
91	Kushihara 163 MW CAPP (KP)	IPP	1*109+1*54	163	163	3882190	
92	Shahjibazar 330 MW CAPP	PDB	3*110	330	237	5416000	Machine problem
93	Fenchugonj 51 MW PP (Barakati	IPP	19*2.90	51	22	612100	
93	Fenchugonj 44MW (Energy/Trima	RPP	12*3.3+5*2	0	0	0	Contract Expired
94	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	183216	
95	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	0	0	Under maint.
96	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	81	1934400	
97	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	Under Shut down
98	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	227	5397440	
99	Sylhet 20 MW GTPP	PDB	1*20	20	18	397000	
100	Sylhet 50MW PP (EPL)	RPP	2*72	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	571896	
101	Bibiana-II 341 MW CAPP (Summ	IPP	1*222+1*119	341	341	7312000	FGMO
102	Bibiana-III 400 MW CAPP	PDB	400 MW	400	395	9318000	
103	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	252000	
104	Bibiana South 400 MW	PDB	400 MW	383	350	84243400	
Sylhet Area Total				2377	1964	45977862	
105	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	710	17235636	
106	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
107	Fairdipor 50 MW Peaking PP	PDB	6*8.99	54	23	172320	Engine problem
108	Khulna 225 MW CAPP	NWPGL	1*150+1*75	220	158	902400	Machine problem
109	Gopalganj 100 MW Peaking PP	PDB	16*8.98	100	0	0	Reserve.
110	Bheramara 410 MW CAPP	NWPGL	1*278+1*132	410	235	5962752	Gas shortage
111	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	100	668160	
112	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	88	1826880	
113	Madhumati 100 MW PP	NWPGL	100 MW	105	0	0	Line O/L
Khulna Area Total				2128	1514	26768148	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	34	690497	
116	Bhola 225 MW CAPP	PDB	2*63+1*68	194	88	2125779	Machine problem
117	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	81	1539403	Gas shortage
118	Payra 1320 MW	BCPCL	2*622	1244	580	12803000	
119	Bhola Nutan Bidrut BD LTD	IPP	220	220	100	2677627	GT-2 under maint.
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	60	708000	Line O/L
Barisal Area Total				2046	943	20544506	
121	Baghbari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage
121	Baghbari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage
122	Baghbari 50 MW Peaking PP	PDB	6*8.9	52	34	606784	Engine problem
123	Bera 70 MW Peaking PP	PDB	9*8.29	71	24	226808	Engine problem
124	Amnura 50 MW PP(Sinha)	QRPP	7*7.9	50	0	0	Fuel shortage
125	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Engine problem
126	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	30	167262	Engine problem
127	Sirajgonj Unit-1 225MW	NWPGL	1*150+1*75	210	119	3145700	Gas shortage
128	Sirajgonj Unit-2 225MW	NWPGL	1*150+1*75	220	0	2000	Under maint.
129	Sirajgonj Unit-3 225MW	NWPGL	1*141	220	140	4017609	Gas shortage
130	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1*282+1*132	414	425	9889164	FGMO
131	Santihar 50 MW Peaking PP	PDB	6*8.9	50	33	283520	Engine problem
132	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	503760	
133	Bogura 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired
134	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	204201	
135	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	1245120	
136	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	95	1012924	Engine problem
137	Bogura 200 MW PP (Paramou	IPP	200 MW	200	186	852380	Engine problem
138	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	2734368	
139	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	2736576	
140	Sirajgonj 6.55 MW Solar	NWPGL	1*6	6	0	18120	
Rajshahi Area Total							