

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel.: 9564667, 9551095

Month August, 2021		Day : Tuesday				Date : 31.08.21					
Probable Maximum Demand :		13500 MW		Probable Maximum Generation : 14241 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 96.58 ft.		Today = 97.78 ft.		Rule Curve = 98.34 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Rated/ Present Capacity (MW)	30.08.21 (Yesterday)		31.08.21 (Today)		Gen. shortfall for : Gas/Water/Coal limitation MW	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Powering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	176	175	200	200	185	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Under maint.
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	94	92	100	100	118	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	212	210	210	123	STG Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	290	260	305	305		FGMO
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	38	40	55	55		
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	12	100	100		
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	100	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22		
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	54	53	54	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	45	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	73	90	90	100		
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	0	98	16	100		
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0	51	Fuel Shortage
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	263	300	300	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
29	Keranganj 300 MW PP (APR)	HSD (IPP)	25x12.4	300	300	38	305	100	300		
30	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	100	100	100		
31	Auralah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	25	101	50	100		
32	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
34	Bosila 108MW PP(RCLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0	108	Fuel Shortage
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	94	94	94	95		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	34	0	30	0		
<b>Dhaka Zone Total</b>				<b>5976</b>	<b>5819</b>	<b>2475</b>	<b>3232</b>	<b>3109</b>	<b>3427</b>	<b>791</b>	<b>1354</b>
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	130	127	130	130	103	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0		
41	Raczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25		
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	18	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	40	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	162	180	300	300		Xr Overload
48	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	100	100	100		
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment Issue
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	20	20	20		
*	Malancha Cig EPZ (United)	Gas	5x8.73+3x9.34			3	20	5	30		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	20	97	108	Fuel Shortage
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54		Xr Overload
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	94	94	94	94		
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.5	100	100	80	80	80	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	114	114	116	116		
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>1083</b>	<b>1203</b>	<b>1412</b>	<b>1509</b>	<b>283</b>	<b>483</b>
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	70	70	120	130	64	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	16	23	23	23		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	210	156	215	215	65	Gas Shortage
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	330	270	330	360		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x360	360	360	40	300	330	360		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	35	30	30	30		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	36	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	25	35	35	35		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	133	135	140		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50		
68	Chandour 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	133	140	140		
69	Chandour 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	188	200	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	0	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	31	43	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	21	20	21		
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+8x1.95+1x1.95	200	200	10	200	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	114	114	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	99	98	98	98		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
**	Impopt (Tijura)	India		160	160	110	138	138	163		
<b>Cumilla Zone Total</b>				<b>3094</b>	<b>3034</b>	<b>1666</b>	<b>2086</b>	<b>2204</b>	<b>2405</b>	<b>580</b>	<b>0</b>
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	107	118	100	120	84	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	46	115	45	100		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	47	175	175	180		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	22	0	50	0		
86	Tangail 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	22	24	22	22		
<b>Mymensingh Zone Total</b>				<b>717</b>	<b>709</b>	<b>274</b>	<b>461</b>	<b>423</b>	<b>451</b>	<b>84</b>	<b>0</b>

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.08.21 (Yesterday)		31.08.21 (Today)		30.08.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	44	44		27	GT1 Under maint.
88	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT 4 Under maint.
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	22	51	51			
90	Kushara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage
93	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	235	237	235	235			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	84	84			
95	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	227	227	225	225			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
99	Bitiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	341	341	341			
100	Bitiyana-II 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	395	395	400	400			
101	Bitiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	351	350	350	350			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under maint.
<b>Sylhet Zone Total</b>				<b>2422</b>	<b>2377</b>	<b>1936</b>	<b>1964</b>	<b>1998</b>	<b>1998</b>	<b>66</b>	<b>75</b>	
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	245	235	230	225	175		Gas Shortage
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	23	0	26			
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60			
107	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 159+1x75	230	230	0	158	0	158			
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.44+7x1.515	100	100	0	100	50	100			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	88	88	88			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			Line Overload
<b>** Bheramara (HVDC) India</b>				<b>1000</b>	<b>1000</b>	<b>714</b>	<b>710</b>	<b>727</b>	<b>727</b>			
<b>Khulna Zone Total</b>				<b>2133</b>	<b>2129</b>	<b>1029</b>	<b>1314</b>	<b>1195</b>	<b>1484</b>	<b>175</b>	<b>0</b>	
111	Bairasil 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	25	34	33	33			
113	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	89	88	88	88		106	Under maint.
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	64	81	11	11			
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	400	580	622	622		664	Line Overload
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	60	150	150			
117	Bhola 220MW CCGP (Nutan Bidyut Bt)	Gas/HSD (IPP)	2x75+1x70	220	220	102	100	220	220			
<b>Barishal Zone Total</b>				<b>2046</b>	<b>2046</b>	<b>690</b>	<b>943</b>	<b>1234</b>	<b>1234</b>	<b>0</b>	<b>770</b>	
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71			Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	40	34	43	43			
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	186	200	200			
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	24	40	42			
122	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			
123	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	95	95	95			
124	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31			
125	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33			
127	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	125	119	80	80		75	STG S/D
128	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	120	120		220	under maint.
129	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	169	140	120	120	80		Gas Shortage
130	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	425	370	370			
131	Bogra 22 MW PP (CBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52			
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113			
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	113	113	113	113			
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0			
<b>Rajshahi Zone Total</b>				<b>2179</b>	<b>2179</b>	<b>1061</b>	<b>1397</b>	<b>1415</b>	<b>1445</b>	<b>251</b>	<b>295</b>	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	156	155	155	155	119		Coal Shortage
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10			
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	106	113	113	113			
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10			
142	Mapara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0			
<b>Rangpur Zone Total</b>				<b>685</b>	<b>605</b>	<b>266</b>	<b>268</b>	<b>276</b>	<b>288</b>	<b>204</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>				<b>21694</b>	<b>21280</b>	<b>10470.0</b>	<b>12868</b>	<b>13266</b>	<b>14241</b>	<b>2434</b>	<b>3062</b>	
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>						<b>9954</b>	<b>12234</b>	<b>12612</b>	<b>13539</b>			
<b>(B) Plants under long term maintenance/ contract expired</b>												
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
145	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
146	Khulna 115 MW PP (KPL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>				<b>337</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>				<b>22031</b>	<b>21280</b>	<b>10470</b>	<b>12868</b>	<b>13266</b>	<b>14241</b>	<b>2434</b>	<b>3062</b>	
<b>(C) Actual data of 30.08.21 (Yesterday) Monday :</b>												
01.	Max. Demand at eve. peak (Generation end)	:	12868.00 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12234.00 MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	12868.00 MW, at = 21:00 hrs	Dhaka	4306	4306	0	Mymensingh	1000	1000	0	
04.	Minimum Generation (Generation end)	:	9622.00 MW, at = 8:00 hrs	Chattogram	1284	1284	0	Sylhet	500	500	0	
05.	Day-peak Generation (Generation end)	:	10470.00 MW, at = 12:00 hrs	Khulna	1537	1537	0	Barishal	374	374	0	
06.	Evening-peak Generation (Generation end)	:	12868.00 MW, at = 21:00 hrs	Rajshahi	1275	1275	0	Rangpur	780	780	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 21:00 hrs	Cumilla	1178	1178	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9804.00 MW, at = 5:00 hrs					<b>Total</b>	<b>12234</b>	<b>12234</b>	<b>0</b>	
09.	Generation shortfall at evening peak due to :	:		13.	Fuel cost :	(a) Gas = 142740474 Taka	(c) Coal = 76763772 Taka					
	a) Gas limitation	:	2127 MW		(b) Oil = 733674472 Taka		Total = 953178717 Taka					
	d) Coal supply Limitation	:	204 MW									
	b) Low water level in Kaptai lake	:	103 MW									
	c) Plants under shut down/ maintenance	:	3062 MW	14.	Maximum Temperature in Dhaka was :	32.5° C						
10.	Total Energy (Generation + India Import)	:	270.52 MKWh	15.	Export through East-West interconnections :							
	By Gas = 136.565 MKWh	By Oil = 93.634 MKWh			At evening peak-hour	-232 MW, at 21:00 hrs						
	By Coal = 16.596 MKWh	By Hydro = 3.037 MKWh			Maximum	-334 MW, at 2:00 hrs						
	By Solar = 0.549 MKWh				Energy	1.806 MKWh						
11.	Total Gas Supplied	:	1112.20 MCFD									
<b>(D) Forecast of 31.08.21 (Today) Tuesday :</b>												
01.	Maximum Demand	:	13500 MW (Generation end)	04.	Maximum Load-shed	:	0 MW (Generation end)	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14241 MW (Generation end)	05.	Total Generation	:	283.81 MKWh					
03.	Maximum Shortage	:	-741 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	34.1° C						

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)  
Deputy Secretary, Generation