

Date : 20-Sep-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-1	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TFP Unit-3	PDB	1'210	190	0	0	Gas shortage
4	Ghorasal 365 MW CCGP Unit-7	PDB	1'243+1'122	365	310	7414309	Machine problem
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2'40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	0	0	Gas shortage
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1'273+1'139	412	363	9306110	Gas shortage
9	Haripur 360MW CCGP(HPR)	IPP	1'235+1'125	360	193	5018000	Gas shortage
10	Meghnaghat 43 MW CCGP(MPL)	IPP	2'150+1'150	450	280	6719300	Dirty Gas
11	Meghnaghat 100 MW(IEI)	ORPP	12'8.9	0	0	0	Contract Expired
12	Meghnaghat CCGP(Summit)	IPP	2'110+1'110	305	285	6684887	FGMO
13	Madanganj 102 PP(Summit)	ORPP	6'17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	55	1301904	
15	Karanganj 100 MW PP (Powerpa)	ORPP	8'13.45	100	40	258052	Low demand
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.9	22	0	485432	Engine problem
17	210 MW Siddhirgonj TTP	PDB	1'210	115	0	0	Under maint.
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12'8.9	0	0	0	Contract Expired
20	Siddhirgonj 335 MW CCGP	EGCB	1'217+1'118	335	250	6474503	Gas shortage
21	Gagnagar 102 MW PP (Digital Po)	IPP	12'8.924	102	102	858672	
22	Kalpa 52 MW PP (Sri)	IPP	7'7.9	51	0	0	Fuel shortage
23	Kamalghat 54 MW PP(Banco En)	IPP	3'18	54	35	514440	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	133	760320	Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	682582	
26	Nabaganj 55 MW PP (Southern)	IPP	3'19.3	55	55	566247	
27	Bosila 108MW PP(ICO)	IPP	12'8.775+1'3.5	108	0	0	Fuel shortage
28	Summit Power (Mishra)-Ashuli	SIPP, REB	3'3.67+4'8.73	80	55	1249260	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	810700	
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	832000	
31	Gazipur 52 MW PP	IPP	6'8.9	52	48	547200	
32	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	278	4922834	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	72	131702	Low demand
35	Birampur 100 MW PP (Aggr)	IPP	100	100	25	54660	Low demand
36	Aurahi 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	25	54023	Low demand
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3262032	
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	1164000	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	94	2216640	Engine problem
40	Manikganj 162MW PP(MPL)	IPP	9'18	162	144	2844000	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	148908	
Dhaka area Total				5719	3217	65282727	
42	Chattogram TPP-1	PDB	1'210	180	120	2800000	Gas shortage
43	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
44	Raozan 25 MW PP	IPP	3'8.9	25	24	98276	
45	Teknaf 20MW PP (Solartech)	Teknaf Solartech Ene	20	20	0	57240	
46	Patenga 50MW PP (Baraka)	IPP	8'8.98	50	39	323520	Engine problem
47	Kapla Hydro Unit-2,3,4, 5	PDB	2'40+3'50	230	165	395458	Low water level
48	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	93	2378618	Engine problem
51	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	0	Under S/D
52	Kalazari-Kalash 100 MW Peakin	PDB	8'17	102	65	415865	Engine problem
53	Judah 100 MW Unit-1	ORPP	8'13.45	100	100	633850	
54	Judah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	1715520	Engine problem
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	21	490272	
56	* Malancha, Cig. EPZ (Uniled)	IPP	5'8.73+3'9.34	0	8	504480	
57	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	84	2054400	Engine problem
58	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	17881	
59	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	287	5394545	
60	Jodac Power	IPP	3'18.55+1'3.6	54	51	497801	
61	Karnaphuli Power Ltd.	IPP	110	110	95	2290790	Engine problem
62	Judah unit-2 (Acorn)	IPP	8'13.6	100	100	2000640	
63	Anlima Energy Ltd.	IPP	6'21.2	116	114	2742436	
Chattogram area Total				2382	1476	28370902	
64	Ashuganj TTP Unit-3	APSC	1'150	135	0	0	Gas shortage
65	Ashuganj TTP Unit-4	APSC	1'150	129	0	0	Gas shortage
66	Ashuganj TTP Unit-5	APSC	1'150	134	0	0	Gas shortage
67	Ashuganj 225 MW CCGP	APSC	1'142+1'175	221	182	4695000	Gas shortage
68	Ashuganj 450 MW CCGP(North)	APSC	1'360	360	280	7291300	FGMO
69	Ashuganj 450 MW CCGP(South)	APSC	1'360	360	280	7189000	FGMO
70	Ashuganj 50 MW PP	APSC	14'3.968	45	23	486216	Engine problem
71	Ashuganj 55 MW PP (Prehistan)	IPP	15.4	55	56	1339680	
72	Ashuganj 195MW PP (APSC) Un	IPP	20'8.73+1'116	195	8	853000	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	43	1004288	Engine problem
74	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	130	2995854	Engine problem
75	Titas 50 MW Peaking PP	PDB	6'8.92	52	50	95776	
76	Chandpur 150 MW CCGP	PDB	1'106+1'57	163	140	3330930	Machine problem
77	Chandpur 200MW (Desh energy)	IPP	0	200	190	3434400	
78	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	512280	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	209340	
80	** Impport (Tripura)	Imported power	0	160	138	2787840	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	810200	
82	Jangalia 52 MW PP (Lakdanav)	IPP	6'8.92	52	47	467462	
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	21	522140	
84	Daudkandi 200 MW PP (B. Trae)	IPP	1'54'1.4	200	70	92352	Low demand
85	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	1478580	
86	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	95	2126040	Engine problem
87	Bhairab 54.5 MW	IPP	3'18.2	54	17	432000	33 kV feeder fault.
Cumilla Area Total				3034	1950	42153768	
88	RPCL 210MW CCGP	IPP	4'35+1'70	202	139	2941600	Gas shortage
89	Tangal 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	19	432313	
90	Jamalpur 95 MW PP (Powerpac)	IPP	12'8.924	95	0	0	Engine problem
91	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	10850	
92	Mymensingh 200 MW PP (Uniled)	IPP	200	185	115	3156000	Engine problem
93	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	115	2630400	
94	Sutakhal 50 MW Solar PP	IPP	50	50	0	313600	
95	Tangal Palli Power Gen 22 MW	IPP	4'6.7	22	22	532080	
Mymensingh Area Total				709	480	10016843	
96	Fenchugonj CCGP Phase-1	PDB	2'32+1'33	70	43	725000	Machine problem
97	Fenchugonj CCGP Phase-2	PDB	2'35+1'35	90	0	0	Under maint.
98	Kushiera 163 MW CCGP (KP)	IPP	1'109+1'54	163	163	3368455	
99	Shajibazar 330 MW CCGP	PDB	3'110	330	160	3709000	GT-2 under maint.
100	Fenchugonj 51 MW PP (Barakat)	RPP	19'2.90	51	50	1161600	
101	Fenchugonj 44MW (Energyprima)	IPP	12'3.35+2	0	0	0	Contract Expired
102	Haldiganj 111MW PP (Doreen-E)	SIPP, REB	4'2.90	111	8	174528	Engine problem
103	Shajibazar GTTP Unit-8 & 9	PDB	2'35	66	0	0	Gas shortage
104	Shajibazar 66MW PP (Shajibaz)	RPP	32'2.90	66	80	1854720	
105	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under Shut down
106	Sylhet 225 MW CCGP	PDB	1'142+1'89	231	220	4584120	
107	Sylhet 20 MW GTTP	PDB	1'20	20	0	0	Gas shortage
108	Sylhet 50MW PP (EPL)	RPCL	2'7.2	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	24	566352	
110	Bibiana-II 341 MW CCGP (Summit)	IPP	1'222+1'119	341	280	7176000	FGMO
111	Bibiana-III 400 MW CCGP	PDB	400 MW	400	316	7529000	Gas shortage
112	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	0	0	Gas shortage
113	Bibiana South 400 MW	PDB	400 MW	383	320	7704700	Gas shortage
Sylhet Area Total				2377	1664	38534475	
114	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve.
115	** Bheramara (HVDC)	Imported power	2'500	1000	713	17277818	
116	Khulna 115 PP MW (KPCL-2)	ORPP	7'17	0	0	0	Contract Expired
117	Faridpur 50 MW Peaking PP	PDB	8'6.89	54	24	42720	Engine problem
118	Khulna 225 MW CCGP	NWPGCL	1'150+1'175	230	230	3340800	
119	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Line O/L
120	Bheramara 410 MW CCGP	NWPGCL	1'278+1'132	410	395	9166560	
121	Noapara 40 MW PP (Khanjahan A)	ORPP	5'8.5	0	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Tre)	IPP	70'1.4	100	20	30720	Low demand
123	Rupsha 105 MW PP (Orion rupsh)	IPP	6'18.445	105	105	935520	
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
Khulna Area Total				2129	1487	30734138	
125	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	0	0	Line O/L
126	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	28	533332	Engine problem
127	Bhola 225 MW CCGP	PDB	2'63+1'68	194	66	1588000	Machine problem
128	Bhola 95 MW PP (Aggreko)	ORPP	96'1.10	95	22	407116	Gas shortage
129	Payra 1320 MW	BCPCL	2'622	1244	480	10147600	Line O/L
130	Bhola Nulan Biddut BD LTD	IPP	220	220	223	5134855	
131	Uniled Payra Power Ltd.	IPP	8'18.5+1'9.5	150	17	90000	Low demand
Barisal Area Total				2046	836	17880803	
132	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
133	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
134	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	8	45408	
135	Bera 70 MW Pe						