

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 954687, 9551095

Month October, 2021		Day : Saturday				Date : 16.10.21						
Probable Maximum Demand :		13500 MW		Probable Maximum Generation :		14618 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 105.09 ft		Today = 104.97 ft		Rule Curve = 107.40 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.10.21 (Yesterday)		16.10.21 (Today)		15.10.21 (Yesterday) Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	250	240	250	250	126		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	317	321	340	240	39	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	342	339	0	360	73		
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	100	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	240	240	240	240			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	250	270	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55			
15	Karaniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	10	50	50			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	7	102	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	19	21	21			
18	Summit Power (Madhaboli+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	40	54	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	72	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	32	149	149			
24	Kanailahat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	150	288	250	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	100	132	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	67	100	300			
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	68	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	154	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	32	0	30	0			
<b>Dhaka Zone Total</b>			<b>5717</b>	<b>5560</b>	<b>2453</b>	<b>2979</b>	<b>3248</b>	<b>3678</b>	<b>767</b>	<b>859</b>		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	158	161	160	160	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	120	115	115	60	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	12	0	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	60	62	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	304	304	300	300			
45	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	10	20	80	100			
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
47	Dohazari -Kalash- 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	102			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	16	18			Environment issue
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			23	30	6	10			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	44	36	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	75	59	110	110			
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	96	100	100	100			
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	90	108	116	116			
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>1101</b>	<b>1204</b>	<b>1475</b>	<b>1545</b>	<b>240</b>	<b>415</b>		
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	135	100	100	0	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26			
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1175	221	221	181	200	200	210			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	295	280	310	350			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	280	320	350			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	52	53	55	55			
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	24	26	26	26	169	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
63	Ashuganj 150MW PP (Midland)	Gas (IPP)	23x7.015	150	150	120	120	135	137			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	50	50	50			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	103	155	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	0	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	6	52	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	19	21	21			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.059	200	200	0	0	150	200			
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	34	80	80			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	57	96	95	96			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impopt (Tripura)	India		160	160	108	126	138	164			
<b>Cumilla Zone Total</b>			<b>3094</b>	<b>3034</b>	<b>1571</b>	<b>1753</b>	<b>2142</b>	<b>2301</b>	<b>432</b>	<b>0</b>		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	165	205	200	160	-3	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	8	8	8	8			Dependable cap. :8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	115	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	140	188	190	190			
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0			
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	23	22	22			
<b>Mymensingh Zone Total</b>			<b>717</b>	<b>622</b>	<b>428</b>	<b>560</b>	<b>608</b>	<b>516</b>	<b>-3</b>	<b>0</b>		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.10.21 (Yesterday)		16.10.21 (Today)		15.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT1 Load gear problem	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	42	42		49		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	47	47	47				
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	58	60	60	8		Gas Shortage	
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	156	159	160	160	171		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	81	81	81				
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	219	220	225				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	16	16	16				
96	Bisiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	290	341	341				
97	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	321	322	320	320				
98	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
<b>Sylhet Zone Total</b>					<b>2422</b>	<b>2377</b>	<b>1759</b>	<b>1798</b>	<b>1852</b>	<b>1857</b>	<b>181</b>	<b>76</b>	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	395	400	400	400				
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	33			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	120	225	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	89	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	50	0	100			Line Overload	
**	Bheramara (HVDC)	India	1000	1000	1000	705	705	717	717				
<b>Khulna Zone Total</b>					<b>2133</b>	<b>2129</b>	<b>1237</b>	<b>1364</b>	<b>1497</b>	<b>1720</b>	<b>0</b>	<b>0</b>	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	22	6	33	33				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	62	0	0	65		194	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	18	0	85	17				
112	Payra 1320 MW CAPP	Coal (BCPCL)	2x622	1244	1244	420	540	622	622		704	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	6	0	150				
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	213	0	107	220				
<b>Barishal Zone Total</b>					<b>2046</b>	<b>2046</b>	<b>735</b>	<b>552</b>	<b>957</b>	<b>1217</b>	<b>0</b>	<b>898</b>	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
115	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	30	30	35				
119	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	28	28				
120	Chapsainabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	91	90	95				
121	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40				
122	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	43				
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	17	35				
124	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	144	144	144	66		Gas Shortage	
125	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	210	194	210	210	26		Gas Shortage	
126	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	203	188	0	0				
127	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	373	370	400	400				
128	Bogra 22 MW PP (BBB)	Gas (RPP)	6x4.0	22	22	18	0	22	22				
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	52	52				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	90	95	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	82	112	113	113				
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
<b>Rajshahi Zone Total</b>					<b>2179</b>	<b>2179</b>	<b>992</b>	<b>1402</b>	<b>1486</b>	<b>1591</b>	<b>263</b>	<b>0</b>	
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	76	80	80	9		Coal Shortage	
134	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	56	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Majpara. Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
<b>Rangpur Zone Total</b>					<b>685</b>	<b>605</b>	<b>122</b>	<b>132</b>	<b>201</b>	<b>193</b>	<b>9</b>	<b>359</b>	
<b>Sub-total: Plants in operation</b>					<b>21435</b>	<b>20934</b>	<b>10398.0</b>	<b>11744</b>	<b>13466</b>	<b>14618</b>	<b>1889</b>	<b>2607</b>	
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>							<b>9962</b>	<b>11251</b>	<b>12900</b>	<b>14004</b>			
<b>(B) Plants under long term maintenance/ contract expired</b>													
140	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
141	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>596</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>22031</b>	<b>20934</b>	<b>10398</b>	<b>11744</b>	<b>13466</b>	<b>14618</b>	<b>1889</b>	<b>2607</b>	
<b>(C) Actual data of 15.10.21 (Yesterday) Friday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 11744.00 MW, at = 20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 11251.00 MW, at = 20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	: 12296.00 MW, at = 1:00 hrs	Dhaka	4140	4140	0	Mymensingh	1053	1053	0			
04.	Minimum Generation (Generation end)	: 9548.00 MW, at = 9:00 hrs	Chattogram	1063	1063	0	Sylhet	565	565	0			
05.	Day-peak Generation (Generation end)	: 10398.00 MW, at = 12:00 hrs	Khulna	1433	1433	0	Barishal	110	110	0			
06.	Evening-peak Generation (Generation end)	: 11744.00 MW, at = 20:00 hrs	Rajshahi	1305	1305	0	Rangpur	690	690	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 20:00 hrs	Cumilla	892	892	0	Total	11251	11251	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9068.00 MW, at = 5:00 hrs	13.	Fuel cost : (a) Gas = 162090514 Taka (c) Coal = 68661205 Taka									
09.	Generation shortfall at evening peak due to :	:		(b) Oil = 532442798 Taka Total = 761394517 Taka									
a)	Gas limitation	: 1880 MW	14.	Maximum Temperature in Dhaka was : 37.4° C									
d)	Coal supply Limitation	: 9 MW	15.	Export through East-West interconnections :									
b)	Low water level in Kaptai lake	: 0 MW		At evening peak-hour : -236 MW, at 20:00 hrs									
c)	Plants under shut down/ maintenance	: 2607 MW		Maximum : -280 MW, at 19:30 hrs									
10.	Total Energy (Generation + India Import)	: 265.53 MKWh		Energy : 1.3805 MKWh									
	By Gas = 155.913 MKWh	By Oil = 70.728 MKWh											
	By Coal = 14.533 MKWh	By Hydro = 3.762 MKWh											
	By Solar = 0.827 MKWh												
11.	Total Gas Supplied	: 1166.97 MMCFD											
<b>(D) Forecast of 16.10.21 (Today) Saturday :</b>													
01.	Maximum Demand	: 13500 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 14618 MW (Generation end)	05.	Total Generation : 291.53 MKWh									
03.	Maximum Shortage	: -1118 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 35.2° C									

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)  
Deputy Secretary, Generation